

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:  
Conventional or Direct Filtration**

**System Name:** *Fishhawk Lake*      **ID #:** *CR400124*      **WTP-:** *A*      **Month/Year:** *APR/2023*

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	PO	PO	PO	.023	PO	PO	.027
2	PO	PO	PO	.066	PO	PO	.091
3	PO	PO	PO	.139	.027	.050	.295 B/W
4	.079	.127	.175	.021	.021	PO	.173
5	PO	PO	PO	.022	.022	PO	.029
6	PO	PO	PO	.058	.038	.028	.201 B/W
7	PO	PO	.031	.022	.022	PO	.028
8	PO	PO	PO	.022	.022	PO	.029
9	PO	PO	.034	.023	PO	PO	.034
10	PO	PO	PO	.025	.146	PO	.295 B/W
11	PO	PO	PO	PO	.029	.026	.142
12	.023	.024	.031	.041	.218	PO	.283 B/W
13	PO	PO	PO	.024	.023	.023	.100
14	PO	PO	.034	.023	PO	.024	.034
15	PO	PO	PO	.025	PO	PO	.030
16	PO	PO	PO	.065	.038	PO	.291 B/W
17	PO	PO	PO	.022	.023	.023	.028
18	PO	PO	.031	.023	.024	.025	.032
19	PO	PO	.033	.029	.027	PO	.295 B/W
20	PO	PO	PO	.023	.026	.035	.035
21	PO	PO	PO	.023	.022	PO	.036
22	PO	PO	PO	.025	.029	PO	.030
23	PO	PO	PO	.135	.027	PO	.184 B/W
24	PO	PO	.033	.023	.023	PO	.033
25	PO	PO	.026	.022	.023	PO	.031
26	PO	PO	PO	.023	.024	PO	.031
27	PO	PO	.027	.034	.033	.029	.275 B/W
28	PO	PO	.036	.024	PO	PO	.036
29	PO	PO	.031	.024	.024	.024	.031
30	PO	PO	PO	.028	.026	.026	.252 B/W
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
Notes:		PRINTED NAME: <i>James Dahlquist</i>	DATE: <i>5/01/23</i>
		SIGNATURE: <i>James Dahlquist</i>	CERT #: <i>7-09147</i>
		PHONE #: <i>503 755-0218</i>	

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup>IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP-: WTP-A Month/Year: APR/2023

Required Log Inactivation: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/10:30	1.19	62	73.7	7.2	7.2	48	Y	55
2/8:30	1.16		71.9	7.2	7.4	52	Y	
3/9:10	0.96		59.5	7.4	7.4	52	Y	
4/9:00	1.18		73.1	6.7	7.2	52	Y	
5/9:45	1.08		66.9	6.3	7.2	51	Y	
6/9:25	1.21		75.0	6.7	7.2	51	Y	
7/10:15	1.12		69.4	7.5	7.3	51	Y	
8/11:00	1.19		73.7	8.6	7.3	48	Y	
9/11:00	1.19		73.7	8.4	7.3	47	Y	
10/9:15	1.15		71.3	8.6	7.2	47	Y	
11/13:50	0.99		61.3	8.6	7.2	46	Y	
12/16:00	1.27		78.7	8.0	7.2	45	Y	
13/11:20	1.15		71.3	7.5	7.2	49	Y	
14/9:15	1.10		68.2	7.3	7.2	48	Y	
15/9:15	1.15		71.3	7.5	7.3	50	Y	
16/9:00	1.16		71.9	8.0	7.3	47	Y	
17/11:00	1.18		73.1	8.0	7.3	47	Y	
18/10:00	1.15		71.3	7.6	7.3	50	Y	
19/9:00	1.04		64.4	7.0	7.2	48	Y	
20/9:00	1.00		62.0	8.1	7.3	47	Y	
21/10:30	0.92		57.4	6.8	7.2	51	Y	
22/10:00	0.89		55.1	7.2	7.3	49	Y	
23/8:15	1.15		71.3	8.1	7.3	46	Y	
24/10:00	1.14		70.6	8.8	7.3	47	Y	
25/9:45	0.83		57.4	8.7	7.3	47	Y	
26/15:00	1.38		85.5	9.1	7.4	45	Y	
27/8:00	1.02		63.2	9.4	7.4	47	Y	
28/10:00	0.90		55.8	10.6	7.5	45	Y	
29/09:15	0.89		55.1	11.2	7.4	41	Y	
30/10:00	0.92		57.0	11.5	7.4	40	Y	
31/								

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.

Download form at: [www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf](http://www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf)