

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Columbia

Conventional or Direct Filtration

Month/Year: Jan 2025


System Name: Fishhawk Lake Reserve & Community ID#41-00124 WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PO	PO	.056	.093	.073	.054	.095
2	.052	PO	.032	.147	.095	.030	.169 B/W
3	.022	PO	.022	.022	.022	.022	.054
4	PO	PO	.024	.023	.031	.026	.068
5	.025	PO	.023	.027	.040	PO	.040
6	PO	PO	.031	.025	.024	PO	.041
7	PO	PO	.024	.057	.079	.107	.131
8	.133	.165	.183	.023	.023	.024	.187
9	PO	PO	.024	.025	.025	.024	.049
10	PO	PO	.028	.024	.027	.028	.036
11	PO	PO	.028	.033	PO	PO	PO
12	PO	PO	PO	PO	PO	PO	PO
13	PO	PO	.032	.028	.033	.028	.128 B/W
14	PO	PO	.027	.026	.028	.026	.028
15	PO	PO	.031	.031	.032	.032	.171
16	PO	PO	.026	.025	.032	.027	B/W .295
17	PO	PO	.029	.027	.026	.026	.038
18	.026	PO	.031	.025	.025	PO	.034
19	PO	PO	.026	.025	.025	.025	.079 B/W 512
20	PO	PO	.027	.026	.025	.025	.031
21	PO	PO	.025	.025	.025	.025	.030
22	.025	PO	.025	.025	.025	.025	.032
23	PO	PO	.025	.030	.025	.025	↑.028 B/W
24	PO	PO	.030	.029	PO	PO	.030
25	PO	PO	.029	.029	PO	PO	.034
26	PO	PO	.029	.029	.030	.028	.092
27	PO	PO	.032	.031	.031	.030	.040
28	PO	PO	.031	.027	.027	.027	.037
29	PO	PO	.027	.029	.028	.027	.095 B/W 515
30	PO	PO	.031	.030	.030	.030	.295+ Cal turb meters
31	PO	PO	.030	.030	.036	PO	.134

<p>Conventional or Direct Filtration</p> <p>95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All turbidity readings < IFE² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No</p>		<p>Monthly Summary (Answer Yes or No)</p> <p>CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p>	
---	--	---	--

Notes:

PRINTED NAME: James Dahlquist

SIGNATURE: 

DATE: 9-5-25

PHONE #: (503) 755-0218

CERT #: 709142

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Fishhawk Lake Reserve & Community ID#41-00124 *Jan* Month/Year: *2025* WTP - : Disinfection Giardia Log Inactive: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		formula	Yes / No	[GPM]
19:30	1.17	62	72.5	8.5	7.0	43	Y	55
210:00	1.04		64.4	8.2	7.0	43	Y	
39:00	1.00		62.0	8.4	6.8	39	Y	
49:00	1.14		70.6	8.6	6.7	38	Y	
59:00	1.04		64.4	8.6	6.8	39	Y	
68:00	.98		60.7	8.9	6.8	39	Y	
77:00	1.20		74.4	9.0	6.9	38	Y	
89:00	1.20		74.4	7.7	6.9	44	Y	
98:30	1.16		71.9	8.0	6.9	42	Y	
1012:15	1.12		69.4	8.0	7.0	42	Y	
1110:00	1.17		72.5	7.8	7.0	46	Y	
1223:59	1.04		64.4	PO				
137:00	.92		57.0	8.0	6.8	39	Y	
147:00	1.20		74.4	7.1	6.8	41	Y	
1512:30	1.14		70.6	6.0	6.8	45	Y	
168:00	1.20		74.4	5.6	6.8	47	Y	
178:30	1.17		72.5	5.5	7.0	51	Y	
188:30	1.18		73.1	5.3	7.0	51	Y	
1912:15	1.18		73.1	4.9	6.9	54	Y	
209:00	1.23		76.2	4.0	6.9	54	Y	
2140:30	1.08		66.9	3.5	7.0	60	Y	
2211:00	1.15		71.3	3.5	6.9	57	Y	
2310:50	1.10		68.2	3.0	7.0	60	Y	
2421:00	1.15		71.3	3.1	7.2	65	Y	
2511:00	1.15		71.3	3.9	7.3	67	Y	
268:00	1.15		71.3	4.3	7.3	61	Y	
277:00	1.15		71.3	3.0	7.4	70	Y	
288:00	1.20		74.4	2.6	7.4	75	N	*
299:30	1.28		79.3	2.6	7.4	75	Y	
307:30	1.33		74.4	2.7	7.4	75	Y	
3111:00	1.24		76.8	3.7	7.4	72	Y	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dnce@oha.oregon.gov, 971-673-0694; or Drinking Water Services, PO Box 14360, Portland, OR 97293-0360