

March 2025

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Columbia

Conventional or Direct Filtration

Month/Year:

System Name: Fishhawk Lake Reserve & Community ID#41-00124

WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.029	PO	.035	.034	.038	.036	.056
2	.036	PO	PO	PO	.035	.034	.045
3	.035	.035	.035	.035	.035	.035	.035
4	PO	PO	.038	.043	.040	.054	.123 b/w
5	.040	.041	.067	.098	.089	.055	.105
6	PO	PO	.048	.042	.048	.043	.295 b/w
7	PO	PO	.042	.039	.039	.038	.042
8	PO	PO	.043	.038	.038	.039	.043
9	PO	PO	PO	PO	PO	PO	
10	PO	PO	.039	.147	PO	PO	.295 b/w
11	PO	PO	PO	.041	.038	.036	.128
12	.035	.035	.035	.035	.038	.037	.184 b/w
13	.036	.035	.036	.037	PO	PO	.037
14	PO	PO	.042	.058	.042	.039	.295 b/w
15	.037	PO	.039	.036	PO	PO	.052
16	PO	PO	PO	.047	PO	PO	.295 turbid out
17	PO	PO	.066	.039	.036	.127	.295 turbid out
18	.242	PO	.037	.035	.034	.034	.293
19	.035	.034	.034	.039	.037	.037	.060
20	PO	PO	.036	.035	.037	PO	.037
21	PO	PO	PO	PO	PO	PO	PO
22	PO	PO	.064	.295	.039	.100	.295 b/w
23	.199	PO	.175	.034	.034	.034	.112
24	.036	.057	.045	.040	.038	.038	.046
25	PO	PO	.038	.037	.036	.036	.052
26	.036	PO	.036	.040	.038	.036	.251
27	.036	PO	.036	.036	.036	.037	.037
28	.037	PO	.037	.045	PO	PO	.270 b/w 539-Turbid out
29	PO	PO	.294	PO	PO	PO	.295 Turbid out
30	PO	PO	.295	.041	.038	PO	.295 turbid out
31	PO	PO	.046	.083	PO	.074	.295 b/w

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: James Dahlquist

SIGNATURE: *James Dahlquist*

DATE: 4/14/25

PHONE #: (505) 755-0218

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (333-061-0040(1)(d)(B&C))

March 2025

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Fishhawk Lake Reserve & Community ID#41-00124	Month/Year:	WTP - : Disinfection Glacis Log Inactive:	1
--	-------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
1.18	[ppm or mg/L]	[minutes]	CXT	°C		formula	Yes / No	[GPM]
17:00	1.22	62	75.6	8.0	7.3	48	y	55
21:00	1.17		72.5	8.0	7.4	50	y	
3:10:00	1.18		73.1	8.7	7.4	50	y	
4:20:00	1.16		71.9	8.2	7.4	50	y	
5:22:45	1.00		62.0	8.4	7.4	50	y	
6:7:00	1.01		62.6	7.3	7.4	52	y	
7:14:00	1.10		68.2	7.2	7.2	49	y	
8:15	1.10		71.9	7.0	7.3	51	y	
9	1.18		PO				PO	
10:6:15	1.16		71.9	7.7	7.1	48	y	
11:8:30	1.02		63.2	7.9	7.2	49	y	
12:19:00	1.04		64.4	8.0	7.3	47	y	
13:12:30	.98		60.7	7.9	7.3	50	y	
14:8:15	.92		57.0	7.4	7.3	50	y	
15:9:00	.92		57.0	7.0	7.3	50	y	
16:12:00	.98		60.7	7.4	7.3	50	y	
17:9:00	.86		53.3	7.5	7.1	47	y	
18:11:30	.98		60.7	7.6	7.1	46	y	
19:13:45	.94		58.2	8.3	7.1	44	y	
20:8:15	.88		54.5	7.4	7.2	48	y	
21	PO		PO	8.1	6.9	41	PO	
22:8:00	.84		52.0	8.0	7.1	44	y	
23:7:45	.89		55.1	8.4	7.1	45	y	
24:10:00	1.03		63.8	9.0	7.0	39	y	
25:6:45	1.00		62.0	9.1	7.1	41	y	
26:13:45	1.13		70.0	9.9	7.1	41	y	
27:7:45	.96		59.5	10.5	7.1	39	y	
28:6:50	.92		57.0	10.0	7.2	40	y	
29:10:05	1.00		62.0	10.0	7.1	39	y	
30:9:15	.68		42.1	10.0	7.1	39	y	
31:7:45	1.15		71.3	9.7	7.0	38	y	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dwp.dmsa@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14360, Portland, OR 97293-0360