

April 2025

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Columbia

Conventional or Direct Filtration

Month/Year:

System Name: Fishhawk Lake Reserve & Community ID#41-00124

WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.064	.055	.043	.039	.041	.043	.064
2	.044	.130	.092	.071	.072	.068	.135 B/W
3	PO	PO	.044	.035	.035	.036	.295 Turb out
4	.036	PO	PO	.037	.038	.041	.195 B/W
5	.040	PO	PO	.039	.040	.040	.042
6	.039	.039	.040	.051	.056	.099	.295 B/W
7	PO	PO	.043	.040	.054	.053	
8	.054	.064	PO				
9	PO						
10	PO	PO	PO	.065	.040	.054	.116
11	.077	.089	.106	.063	.043	.040	.257 B/W 549
12	.039	.038	.038	.038	PO	PO	.039
13	PO	PO	PO	.038	.037	.037	.060
14	PO	PO	.037	.038	.038	PO	.039
15	PO	PO	.038	.038	.038	PO	.058
16	PO	PO	.059	.043	.042	.041	.201 B/W 550
17	PO	PO	.040	.039	.039	.039	.042
18	PO	PO	.049	.039	.038	PO	.049
19	PO	PO	.047	.039	.040	PO	.047
20	PO	PO	PO	.061	.052	.054	.295 B/W
21	.057	.059	.053	.054	.060	PO	.062
22	PO	PO	.052	.049	.047	.045	.066
23	PO	PO	.044	.043	.042	.042	.295 B/W 552
24	PO	PO	.058	.053	.052	.049	.068
25	PO	PO	.045	.051	.053	.049	.059
26	.058	PO	PO	.059	.059	.057	.059
27	PO	PO	PO	.057	.056	.057	.295 B/W 553
28	PO	PO	.083	.075	.072	.067	.107
29	PO	PO	.066	.067	.072	.077	.087
30	PO	PO	.076	.088	.081	.073	.089
31							

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: James Dahlquist

SIGNATURE: *James Dahlquist*

DATE: 5/6/25

PHONE #: (503) 755-0218

CERT #: 09147

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (333-061-0040(1)(d)(B&C))

April 2025

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Fleishhawk Lake Reserve & Community ID#41-00124

Month/Year:

WTP - :
Disinfection Glacials
Log Inactive: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
1.15	[ppm or mg/L]	[minutes]	CXT	[°C]		formula	Yes / No	[GPM]
11:45	1.02	62	63.2	8.7	7.1	45	y	55
21:00	.98		60.7	8.7	7.2	46	y	
37:15	.83		51.4	8.2	7.2	46	y	
49:10	.83		51.4	8.7	7.1	44	y	
513:50	.86		53.3	8.6	7.2	46	y	
615:45	.85		52.7	10.3	7.3	42	y	
723:00	.73		45.2	9.7	7.1	41	y	
8	.76		PO	9.7	7.2	PO		
9	PO			PO	7.1			
1010:10	.86		53.3	10.7	7.1	38	y	
111:30	.95		58.9	9.7	7.1	41	y	
129:30	1.15		71.3	9.0	7.1	41	y	
1310:00	1.00		62.0	8.6	7.2	47	y	
1411:45	.98		60.7	8.3	7.2	46	y	
157:45	1.15		71.3	8.9	7.1	44	y	
1615:00	.98		60.7	9.4	7.1	42	y	
1710:00	.96		59.5	9.4	7.2	43	y	
1812:45	.92		57.0	9.8	7.2	43	y	
1810:00	.92		57.0	10.2	7.3	42	y	
2021:00	.94		58.2	10.3	7.2	40	y	
2112:00	.95		58.9	10.7	7.2	40	y	
2221:30	.82		50.8	9.7	7.3	45	y	
239:30	.78		48.3	8.8	7.2	45	y	
2415:30	.70		43.4	9.2	7.2	42	y	
2518:00	.78		48.3	10.3	7.2	40	y	
2610:00	.62		38.4	11.0	7.3	38	y	
2712:15	.62		38.4	11.3	7.3	38	y	
289:15	.70		43.4	11.0	7.3	38	y	
298:00	.62		38.4	11.3	7.3	38	y	
308:00	.60		37.2	11.0	7.2	36	y	
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dwp.dmsa@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14360, Portland, OR 97293-0360