

May 2025

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Columbia

Conventional or Direct Filtration

Month/Year:

System Name:	Fishhawk Lake Reserve & Community						ID#41-00124	WTP: TP -
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	PO	PO	.065	PO 9/10	.093	.071	.295 B/W	
2	PO	PO	.068	.074	.081	.078	.081	
3	PO	PO	.071	.086	.085	PO	.087	
4	PO	PO	.0115	.076	.072	.071	.115	
5	PO	PO	.152	.078	.077	.068	.295 B/W	
6	PO	PO	.065	.069	.069	.076	.078	
7	PO	PO	.097	.086	.099	.105	.105	
8	PO	PO	.072	.048	.041	.038	.295 B/W	
9	PO	PO	.039	.037	.037	.037	.052	
10	.038	PO	.039	.037	.038	.038	.077	
11	.049	PO	PO	.041	.039	.038	.044	
12	.044	PO	.038	.037	.038	.039	.053	
13	PO	PO	.040	.038	.060	.040	.237 B/W	
14	PO	PO	.035	.034	.033	.033	.064	
15	PO	PO	.059	.034	.034	.034	.059	
16	.034	PO	.044	.037	.038	.037	.149 B/W	
17	PO	PO	PO	.037	.039	.039	.039	
18	PO	PO	PO	.048	.049	.051	.049	
19	PO	PO	.054	.054	PO	PO	.295 B/W	
20	PO	PO	.102	.047	.043	.041	.210	
21	PO	PO	.044	.040	.039	.039	.117	
22	PO .040	PO	.039	.040	.040	PO	.069	
23	PO	PO	.038	.036	.035	.035	.109	
24	.036	PO	PO	.041	.037	.037	.110	
25	.036	PO	.045	.037	.037	.037	.101	
26	.101	PO	PO	.037	.037	.038	.071	
27	PO	PO	.038	.037	.037	.037	.065	
28	PO	PO	.041	.038	.037	.037	.055	
29	.037	PO	.038	.037	.038	.043	.073 B/W	
30	.041	PO	.043	.039	.038	.040	.044	
31	PO	PO	.041	.038	.038	PO	.041	

Conventional or Direct Filtration

95% of 4-hour turbidity readings \leq 0.3 NTU?

Yes / No

All 4-hour turbidity readings \leq 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 \geq 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: James Dahlquist

SIGNATURE: *James Dahlquist*

DATE: 6-4-25

PHONE #: (573) 755-0218

CERT #: T-09147

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

May 2025

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Fishhawk Lake Reserve & Community ID#41-00124

Month/Year:

WTP -:

Disinfection Giardia
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1:00								
1:15	1.00	62	62	11.0	7.3	38	y	55
2:00:30	1.84		52.0	11.6	7.2	38	y	
3:16:15	1.78		48.3	12.0	7.3	36	y	
4:7:30	1.78		48.3	12.3	7.4	37	y	
5:20:30	1.02		63.2	10.7	7.4	43	y	
6:07:30	1.00		62.0	10.0	7.3	42	y	
7:11:00	1.00		62.0	11.8	7.3	40	y	
8:14:10	1.04		64.4	12.0	7.2	35	y	
9:21:00	.96		59.5	10.8	7.1	39	y	
10:14:00	.83		51.4	11.0	7.4	41	y	
11:19:00	.94		58.2	11.4	7.4	40	y	
12:00:00	.82		50.8	11.1	7.1	36	y	
13:00:00	.81		50.2	11.0	7.2	37	y	
14:14:30	.93		57.6	10.8	7.3	41	y	
15:11:15	.92		57.0	11.0	7.4	41	y	
16:10:30	1.08		66.9	10.6	7.5	45	y	
17:8:15	.98		60.7	11.5	7.5	43	y	
18:11:00	.83		51.4	11.0	7.4	41	y	
19:5:30	.65		40.3	11.2	7.4	40	y	
20:15:30	.63		39.0	11.1	7.3	38	y	
21:7:00	.70		43.4	10.9	7.3	40	y	
22:15:30	.82		50.8	11.4	7.5	38	y	
23:23:00	.68		42.1	11.6	7.3	38	y	
18:00 24:14:15	.78		48.3	11.6	7.2	36	y	
25:9:00	.69		42.7	12.0	7.3	36	y	
26:13:00	.80		49.6	12.4	7.6	40	y	
27:7:00	.78		48.3	12.9	7.2	34	y	
28:20:20	.78		48.3	12.8	7.4	37	y	
29:10:20	.82		50.8	14.0	7.3	30	y	
30:9:50	.76		47.1	14.0	7.3	30	y	
31:8:00	.70		43.4	13.4	7.3	33	y	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dws.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14360, Portland, OR 97293-0360

PAGE 2 of 2