

June 25

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:

Columbia

Conventional or Direct Filtration

Month/Year:

06/25

System Name: Fishhawk Lake Reserve & Community		ID#41-08124		WTP: TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PO	PO	PO	PO	PO	PO	—
2	PO	PO	.041	.042	.039	.038	.273
3	.037	.037	.038	.038	.038	.041	.161 B/w 567
4	.040	.039	.039	.038	.039	.039	.059 B/w 568
5	.046	PO	.042	.040	.037	.039	.059
6	.039	PO	.040	.039	.040	.045	.069 B/w 569
7	PO	PO	.046	.043	.042	.042	.040 B/w .122
8	.043	PO	PO	.044	.043	.134	.134
9	PO	PO	.049	.047	.046	.046	.073
10	PO	PO	.048	.047	.047	.047	.107 B/w
11	PO	PO	.053	.048	.046	.046	.077
12	.047	PO	.046	.045	.044	.044	.130 B/w
13	.053	PO	PO	.047	.044	.043	.053
14	.042	PO	PO	.042	.041	.041	.044
15	PO	PO	PO	PO	.042	.041	.087
16	.040	PO	.040	.040	.040	.041	.047
17	.041	PO	.042	.040 .047	.043	.042	.078
18	PO	PO	.043	.042	.046	.049	.062
19	.049	PO	.104	.062	.053	.049	.252 13W
20	PO	PO	.048	.045	.045	.045	.109
21	.045	PO	PO	.045	.071	.049	.203
22	PO	PO	PO	.063	.087	.194	.261
23	PO	PO	PO	.081	.057	.050	.266
24	.049	.047	.044	.042	PO	PO	.295 turb out
25	PO	PO	.046	.042	.042	.042	.239
26	PO	PO	.044	.047	.044	.042	.083 B/w
27	PO	PO	.043	.042	.041	PO	.041 B/w
28	PO	PO	.044	.047	.044	PO	.215 B/w
29	PO	PO	.046	.044	.043	.044	.068
30	PO	PO	.046	cal turb	.043	.043	.295 cal turbidity units
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All 4-hour turbidity readings \leq 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: James Dahlquist	
		SIGNATURE: <i>James Dahlquist</i>	DATE: 7/7/25
		PHONE #: (563) 755-0218	CERT #: T-09147

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-081-0040(1)(d)(B&C))

June 25

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Fishhawk Lake Reserve & Community ID#41-00124

Month/Year: 06/25

WTP - :
Disinfection Grade
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T) 62 min	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
06/25	[ppm or mg/L]	[minutes]	CXT	[°C]		formula	Yes / No	[GPM]
1	80							55
2 7:10	.66		40.9	13.6	7.3	33	y	
3 7:20	.80		49.6	13.1	7.4	33	y	
4 7:30	.82		50.8	14.2	7.3	30	y	
5 7:45	.86		53.3	13.6	7.3	33	y	
6 7:45	.84		52.0	14.0	7.3	30	y	
7 10:30	.70		43.4	14.9	7.3	30	y	
8 12:00	.67		41.5	16.6	7.3	27	y	
9 12:45	.76		47.1	17.4	7.3	27	y	
10 7:00	.61		37.8	17.3	7.4	28	y	
11 8:00	.59		36.5	17.0	7.3	27 27	y	
12 8:15	.62		38.4	15.6	7.5	29	y	
13 8:30	.77		47.7	14.7	7.3	31	y	
14 15:00	.72		44.6	13.7	7.3	33	y	
15 12:15	.78		48.3	12.6	7.1	43 33	y	
16 9:30	.73		45.26	13.0	7.4	34	y	
17 9:45	.68		42.16	13.4	7.4	34	y	
18 6:30	.71		44.0	14.0	7.2	29	y	
19 7:30	.70		43.4	14.4	7.5	32	y	
20 8:00	.71		44.0	13.7	7.2	32	y	
21 8:00	.78		48.3	12.9	7.1	33	y	
22 12:15	.58		35.9	12.6	7.2	34	y	
23 16:00	.60		37.2	12.8	7.2	34	y	
24 9:00	.68		42.16	15.0	7.2	26	y	
25 9:30	.50		31	14.8	7.1	27	y	
26 8:00	.74		45.8	14.8	7.2	29	y	
27 8:45	.74		45.8	14.7	7.2	29	y	
28 8:30	.68		42.1	14.6	7.2	29	y	
29 8:10	.54		33.4	14.6	7.3	31	y	
30 7:45	.78		48.3	15.7	7.2	26	y	
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dms@oha.oregon.gov, 971-673-0694; or Drinking Water Services, PO Box 14360, Portland, OR 97293-0360

PAGE 2 of 2