

Aug. 2025

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Columbia

Conventional or Direct Filtration

Month/Year:

System Name: Fishhawk Lake Reserve & Community ID#41-00124

WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PO	PO	.059	.053	.054	PO	.115
2	PO	PO	PO	.060	.058	.061	.064
3	.061	PO	PO	.172	.071	.099	.295 turbid out
4	.061	PO	.056	.051	.051	.052	.057
5	.053	PO	.080	.050	.049	.050	.295 B/w 601
6	PO	PO	.051	.058	.069	.069	.075
7	PO	PO	.106	.092	.093	.097	.160
8	PO	PO	.206	.076	.068	PO	.206
9	PO	PO	B/w	.065	.060	PO	.295 B/w
10	PO	PO	.114	.059	.058	.061	.295 B/w 114
11	.065	.064	B/w	.071	.068	.072	.295 B/w
12	.075	.075	.077	.077	.084	.089	.295 B/w
13	.092	PO	.089	.083	.084	.090	.295 B/w
14	PO	PO	.114	.099	.095	.094	.181
15	.093	PO	.091	.085	.084	B/w	.295 B/w
16	PO	PO	PO	.098	.196	PO	.295 Turbid out
17	PO	PO	PO	.235	.181	.166	.275
18	.138	PO	.118	.080	.066	.064	.295 B/w #608
19	.062	PO	.059	.057	.057	.055	.295 B/w
20	.055	PO	.055	.054	.057	.053	.263 B/w
21	.052	PO	.049	.048	.053	.049	.200 B/w
22	PO	PO	.054	.048	.048	.057	.163 B/w
23	PO	PO	.067	.050	.050	.049	.295 B/w
24	.049	PO	PO	.052	.050	PO	.295
25	PO	PO	.226	.051	.051	PO	.295 B/w
26	PO	PO	.059	.055	.057	.054	.078
27	.055	PO	.062	.057	.056	.056	.083
28	.057	PO	.059	.059	.056	.055	.295 B/w
29	.056	PO	.057	.060	.057	.057	.295 B/w
30	.056	PO	.091	.056	.060	.058	.295 B/w
31	PO	PO	PO	.056	.056	.058	.295 B/w

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: James Dahlquist

SIGNATURE: James Dahlquist

DATE: 9/5/25

PHONE #: (503) 755-0218

CERT #: T-09147

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (333-081-0040(1)(d)(B&C))

Aug 2025

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Fishhawk Lake Reserve & Community	ID#41-00124	Month/Year:	WTP - : Disinfection Glazide Log Inactive: 1
---	-------------	-------------	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T) 62	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow 55
	[ppm or mg/L]	[minutes]	CXT	°C		formula	Yes / No	[GPM]
18:00	.44		27.2	18.0	7.0	24	y	
20:00	.45		27.9	17.7	6.8	22	y	
312:00	.46		28.5	18.0	7.4	27	y	
48:00	.54		33.4	16.9	7.4	27	y	
57:00	.58		35.9	15.5	7.2	26	y	
66:45	.46		28.5	15.6	7.1	25	y	
71:15	.45		27.9	16.5	7.1	25	y	
811:30	.58		35.9	15.7	7.3	26	y	
99:45	.50		31.0	15.7	7.3	27	y	
109:00	.53		32.8	16.2	7.3	27	y	
110:06	.66		40.9	19.4	7.1	25	y	
122:30	.59		36.5	20.4	7.5	29	y	
138:15	.57		35.3	20.5	7.5	29	y	
147:45	.47		29.1	19.9	7.3	27	y	
1512:30	.45		27.9	19.4	7.3	26	y	
169:00	.44		27.2	18.7	7.2	25	y	
1723:00	.52		32.2	18.9	7.3	26	y	
188:00	.52		32.2	17.7	7.2	26	y	
187:00	.51		31.6	17.4	7.2	26	y	
208:00	.63		39.0	17.0	7.2	26	y	
2107:30	.58		35.9	17.0	7.3	27	y	
2210:00	.52		32.2	16.8	7.3	27	y	
239:30	.58		35.9	16.6	7.3	27	y	
2415:15	.70		43.4	18.0	7.4	28	y	
258:10	.58		35.9	18.4	7.4	28	y	
268:00	.60		37.2	18.7	7.1	25	y	
2716:30	.72		44.6	19.6	7.2	26	y	
289:00	.63		39.0	18.7	7.1	25	y	
2910:45	.66		40.9	18.5	7.2	26	y	
3015:30	.67		41.5	18.0	7.1	25	y	
318:45	.51		31.6	17.2	7.1	25	y	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dwp.dms@oha.oregon.gov, 971-673-0894; or Drinking Water Services, PO Box 14360, Portland, OR 97293-0360