

Oct/25

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Columbia

Month/Year: 10/25

System Name: Fishhawk Lake Reserve & Community ID#41-00124

WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.097	PO	.098	.163	.272	PO	.295
2	PO	PO	PO	.114	.155	.190	.205
3	PO	PO	B/W	.087	.076	.072	.295 B/W
4	PO	PO	PO	.068	PO	PO	.295 B/W
5	PO	PO	PO	.066	.064	.065	.164
6	PO	PO	.072	.081	.099	.291	.295 B/W
7	PO	PO	.086	PO .088	PO .088	PO .088	.295 B/W
8	PO	PO	PO .088	PO	.067	.062	.295 B/W
9	.062	.062	.062	.062	.063	PO	.295 B/W
10	PO	PO	.066	.063	.063	.063	.99
11	.064	PO	PO	.079	.081	.085	.165
12	.089	PO	PO	.079	.080	PO	.271
13	PO	PO	.086	PO	.069	.066	.295 B/W
14	PO	PO	.067	.064	.064	PO	.295 B/W
15	PO	PO	.066	.063	.062	.062	.078
16	PO	PO	PO	.062	.075	PO .069	.295 B/W
17	PO	PO	PO	.075	.195	.265	.265
18	PO	PO	PO	.062	PO	PO	.295
19	PO	PO	.068	.064	PO	PO	.212
20	PO	PO	.072	.138	.099	.207	.295 B/W
21	PO	PO	.155	PO	.069	PO	.295 B/W
22	PO	PO	.068	PO .062	PO .062	PO .062	.295 B/W
23	PO	PO	.123	PO	PO	PO	.295 turbid out
24	PO	PO	PO	.063	.065	PO	.295 B/W
25	PO	PO	PO	.077	PO	PO	.295 turbid out
26	PO	PO	PO	.092	.155	PO	.295 turbid out
27	PO	PO	PO	.132	.069	.065	.295 B/W
28	PO	PO	.072	.228	.081	PO	.295 B/W
29	PO	PO	.099	.221	.074	PO	.295 B/W
30	PO	PO	.136	.098	.114	PO	.295 B/W
31	PO	PO	PO .114	.077	.072	PO	.295

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: James Dahlquist

SIGNATURE: *James Dahlquist*

DATE: 11/6/25

PHONE #: (503) 755-0248

CERT #: T-09147

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-081-0040(1)(d)(B&C))

T-09147

Oct/25

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Fishhawk Lake Reserve & Community ID#41-00124	Month/Year: 10/25	WTP - : Disinfection: <u>Chlorine</u> Log Inactive: 1	
--	-------------------	---	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T) 62	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow 55
68	[ppm or mg/L]	[minutes]	CXT	[°C]		formula	Yes / No	[GPM]
11:45	.52		32.2	13.8	7.0	29	y	
223:00	.50		31.0	13.7	7.1	29	y	
312:00	.62		38.4	13.6	7.0	28	y	
409:45	.58	30	35.9	14.1	7.0	26	y	
59:00	.79		48.9	13.8	7.2	32	y	
607:45	.87		53.9	13.5	7.3	33	y	
78:15	.72		44.6	13.0	7.4	34	y	
814:00	.80		49.6	13.0	7.3	33	y	
915:30	1.00		62.0	14.0	7.1	28	y	
1008:00	.95		58.9	11.1	7.2	38	y	
1111:00	.86		53.3	11.1	7.2	38	y	
1210:30	.66		40.9	11.6	7.4	40	y	
1308:00	.64		39.6	11.7	7.4	39	y	
1406:45	.73		45.2	10.6	7.6	45	y	
1508:15	.72		44.6	10.2	7.2	40	y	
1611:45	.76		47.1	9.6	7.4	44	y	
1710:15	.94		58.2	8.8	7.5	48	y	
1812:30	.75		45.8	9.3	7.3	44	y	
1908:00	.70		43.4	10.0	7.3	41	y	
209:45	1.17		72.5	10.4	7.1	38	y	
2111:00	.71		44.0	10.6	7.2	41	y	
2211:15	.95		58.9	10.0	7.5	44	y	
237:30	1.03		63.8	9.0	7.2	45	y	
2410:00	.80		49.6	9.7	7.2	43	y	
2513:30	1.28		79.3	9.8	7.3	44	y	
2611:45	1.02		63.2	10.6	7.6	48	y	
2712:00	.73		45.2	11.2	7.3	39	y	
2812:00	.70		43.4	10.2	7.3	41	y	
2910:59	.90		55.8	9.5	7.3	46	y	
308:55	1.16		71.9	9.8	7.5	48	y	
3101:30	1.07		66.3	9.4	7.5	48	y	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dws.dms@oha.oregon.gov, 971-673-0694; or Drinking Water Services, PO Box 14360, Portland, OR 97293-0360
 PAGE 2 of 2