

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Columbia

Conventional or Direct Filtration

Month/Year: Jan-26

System Name: Fishhawk Lake Reserve ID#: 41-00124 WTP : TP - Direct Filtration

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	Plant Off	Plant Off	0.172	0.204	0.224	Plant Off	0.228
2	Plant Off	Plant Off	0.092	0.097	0.034	0.035	0.214
3	Plant Off	Plant Off	Plant Off	0.042	0.044	0.097	0.295 Back Wash
4	0.198	Plant Off	Plant Off	0.269	Plant Off	Plant Off	0.295
5	Plant Off	Plant Off	0.095	0.036	0.036	0.036	0.255
6	0.036	0.036	0.054	0.048	0.071	0.070	0.075
7	Plant Off	Plant Off	0.035	0.032	0.033	0.033	0.075
8	0.033	Plant Off	0.034	0.046	0.035	Plant Off	0.067
9	Plant Off	Plant Off	Plant Off	0.050	0.103	0.169	0.245
10	0.245	Plant Off	0.146	0.033	0.033	0.034	0.193
11	0.034	0.035	Back Wash	0.045	0.051	0.051	0.090 Back Wash
12	0.049	0.048	0.052	0.036	0.035	0.035	0.078
13	0.035	0.036	0.036	0.036	0.039	0.038	0.121 Back Wash
14	0.037	0.037	0.037	0.037	0.037	0.036	0.037
15	0.036	0.036	0.036	0.037	0.039	0.037	0.295 Back Wash
16	0.037	0.037	0.037	0.037	0.036	0.036	0.037
17	0.036	0.036	0.036	0.041	0.038	0.037	0.066
18	0.037	0.037	0.037	0.037	0.037	0.036	0.038
19	0.038	0.039	0.037	0.037	0.037	0.037	0.270 Back Wash
20	0.036	0.036	0.037	0.039	0.038	0.036	0.153 Back Wash
21	0.036	0.036	0.036	0.036	0.035	0.035	0.036
22	0.035	0.036	0.035	0.041	0.037	0.037	0.052
23	0.040	Plant Off	0.036	0.036	0.036	0.036	0.039
24	Plant Off	Plant Off	Plant Off	0.036	0.036	0.035	0.037
25	0.036	Plant Off	Plant Off	0.040	0.038	Plant Off	0.058 Back Wash
26	Plant Off	Plant Off	Plant Off	0.036	0.036	0.036	0.048
27	0.036	Plant Off	0.036	0.036	0.036	0.036	0.043
28	0.037	Plant Off	0.036	0.036	0.036	0.038	0.048
29	0.041	Plant Off	0.045	0.073	0.042	Plant Off	0.176 Back Wash
30	Plant Off	Plant Off	0.086	0.062	0.047	0.046	0.096
31	Plant Off	Plant Off	Plant Off	0.043	0.042	0.041	0.093

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes:

PRINTED NAME: Andrew C. Degner

SIGNATURE: *Andrew C. Degner* DATE: 2/6/26

PHONE #: (503) 758-1232 CERT #: T4 2346

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - Direct Filtration

System Name:	Fishhawk Lake	ID#: 41-00124	Month/Year:	Jan-26	Disinfection <i>Giardia</i> Log Inactive:	1
--------------	---------------	---------------	-------------	--------	--	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1/2026 17:15	1.13	62	70.1	6.7	7.30	54.2	YES	55
1/2/2026 11:57	0.83	62	51.5	6.5	7.10	49.4	YES	55
1/3/2026 11:19	0.95	62	58.9	7.4	7.10	47.2	YES	55
1/4/2026 10:52	1.25	62	77.5	8.4	7.10	45.7	YES	55
1/5/2026 8:38	1.04	62	64.5	8.7	7.10	43.7	YES	55
1/6/2026 10:18	0.89	62	55.2	8.3	7.20	45.7	YES	55
1/7/2026 9:58	1.02	62	63.2	7.8	7.20	47.9	YES	55
1/8/2026 14:30	0.94	62	58.3	7.6	7.20	48.2	YES	55
1/9/2026 12:02	1.19	62	73.8	7.7	7.20	49.2	YES	55
1/10/2026 11:18	1.06	62	65.7	8.1	7.20	47.2	YES	55
1/11/2026 9:13	1.39	62	86.2	8.0	7.30	51.1	YES	55
1/12/2026 12:30	1.23	62	76.3	8.7	7.30	47.9	YES	55
1/13/2026 15:00	1.13	62	70.1	9.4	7.20	43.7	YES	55
1/14/2026 6:15	1.03	62	63.9	9.0	7.20	44.3	YES	55
1/15/2026 7:14	1.06	62	65.7	9.1	7.30	45.8	YES	55
1/16/2026 12:02	1.11	62	68.8	8.0	7.20	47.8	YES	55
1/17/2026 18:27	1.25	62	77.5	6.9	7.20	52.3	YES	55
1/18/2026 9:36	1.22	62	75.6	6.2	7.30	56.6	YES	55
1/19/2026 10:27	1.02	62	63.2	5.1	7.30	59.6	YES	55
1/20/2026 17:35	1.14	62	70.7	5.4	7.40	61.4	YES	55
1/21/2026 10:50	0.97	62	60.1	5.2	7.30	58.8	YES	55
1/22/2026 13:57	1.1	62	68.2	4.5	7.40	65.0	YES	55
1/23/2026 7:25	0.99	62	61.4	4.1	7.20	61.3	YES	55
1/24/2026 11:30	1.02	62	63.2	4.8	7.30	60.8	YES	55
1/25/2026 15:30	1.09	62	67.6	4.6	7.40	64.4	YES	55
1/26/2026 7:38	1.23	62	76.3	3.8	7.30	66.7	YES	55
1/27/2026 6:53	1.33	62	82.5	3.8	7.30	67.5	YES	55
1/28/2026 7:58	1.54	62	95.5	4.3	7.40	69.3	YES	55
1/29/2026 15:11	1.19	62	73.8	5.4	7.80	71.4	YES	55
1/30/2026 6:50	0.88	62	54.6	6.4	7.20	49.0	YES	55
1/31/2026 9:31	0.95	62	58.9	7.5	7.20	53.0	YES	55

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350