

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Columbia

Conventional or Direct Filtration

Month/Year: Feb-26

System Name: Fishhawk Lake Reserve ID#: 41-00124 WTP : TP - Direct Filtration

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.400	0.390	Plant Off	0.380	Plant Off	Plant Off	0.580
2	Plant Off	Plant Off	0.410	0.039	0.039	0.042	0.070
3	Plant Off	Plant Off	0.400	0.039	0.038	0.037	0.071
4	0.038	0.038	0.139	0.039	0.037	0.039	0.145
5	0.039	Plant Off	0.038	0.089	0.076	0.080	0.109
6	0.083	0.089	0.220	0.198	0.037	0.037	0.295
7	0.037	Plant Off	Plant Off	0.041	0.039	0.038	0.110
8	0.040	Plant Off	Plant Off	0.068	0.295	Plant Off	0.295
9	Plant Off	Plant Off	0.127	0.038	0.041	0.039	0.295
10	0.039	0.039	0.040	0.039	0.038	0.038	0.040
11	0.039	Plant Off	0.088	0.181	0.044	0.050	0.187
12	Plant Off	Plant Off	0.039	0.059	0.068	0.067	0.068
13	Plant Off	Plant Off	0.163	0.042	0.045	0.048	0.176
14	0.051	Plant Off	Plant Off	0.066	Plant Off	Plant Off	0.295
15	Plant Off	Plant Off	0.286	0.040	0.039	Plant Off	0.286
16	Plant Off	Plant Off	0.069	0.042	0.042	0.046	0.069
17	0.046	Plant Off	0.040	0.039	0.042	0.041	0.046
18	0.040	Plant Off	0.040	0.039	0.039	0.040	0.051
19	0.040	Plant Off	0.048	0.042	0.041	0.041	0.068
20	Plant Off	Plant Off	0.040	0.040	0.040	0.040	0.041
21	0.041	Plant Off	0.056	0.045	0.044	0.043	0.056
22	0.043	Plant Off	0.040	0.040	0.040	0.041	0.046
23	Plant Off	Plant Off	0.042	0.042	0.044	0.050	0.067
24	Plant Off	Plant Off	0.062	0.060	0.118	0.190	0.194
25	0.120	Plant Off	Plant Off	0.044	0.049	0.070	0.295
26	Plant Off	Plant Off	0.071	0.144	0.071	0.060	0.295
27	0.063	Plant Off	0.049	0.057	Plant Off	Plant Off	0.063
28	Plant Off	Plant Off	0.185	0.047	0.053	0.054	0.233
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes:	PRINTED NAME: Andrew C. Degner	
	SIGNATURE: 	DATE: 3/6/26
	PHONE #: (503) 758-1232	CERT #: T4 2346

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - Direct Filtration

System Name:	Fishhawk Lake	ID#: 41-00124	Month/Year:	Feb-26	Disinfection <i>Giardia</i> Log Inactive:	1
--------------	---------------	---------------	-------------	--------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
2/1/2026 15:15	1.58	62	98.0	8.2	7.10	48.0	YES	55
2/2/2026 14:03	0.98	62	60.8	8.9	7.30	46.0	YES	55
2/3/2026 6:15	0.84	62	52.1	8.5	7.10	43.3	YES	55
2/4/2026 17:52	0.93	62	57.7	8.4	7.20	45.6	YES	55
2/5/2026 19:58	1.00	62	62.0	8.5	7.00	42.6	YES	55
1/6/2026 10:18	0.93	62	57.7	7.9	7.30	48.8	YES	55
2/7/2026 19:31	1.06	62	65.7	7.2	7.20	50.1	YES	55
2/8/2026 10:25	0.86	62	53.3	8.0	7.00	43.3	YES	55
2/9/2026 9:23	0.82	62	50.8	8.6	7.20	44.5	YES	55
2/10/2026 6:20	0.94	62	58.3	8.7	7.10	43.2	YES	55
2/11/2026 13:38	0.93	62	57.7	8.0	7.10	45.2	YES	55
2/12/2026 9:39	0.93	62	57.7	7.0	7.20	50.1	YES	55
2/13/2026 6:19	1.08	62	67.0	7.2	7.20	50.3	YES	55
2/14/2026 9:08	1.07	62	66.3	7.4	7.10	47.8	YES	55
2/15/2026 9:47	0.95	62	58.9	7.8	7.10	45.9	YES	55
2/16/2026 20:55	1.18	62	73.2	7.7	7.20	49.2	YES	55
2/17/2026 6:48	1.02	62	63.2	7.0	7.10	48.8	YES	55
2/18/2026 8:02	1.06	62	65.7	6.2	7.20	53.6	YES	55
2/19/2026 6:55	1.01	62	62.6	6.0	7.10	52.1	YES	55
2/20/2026 8:41	1.18	62	73.2	6.0	7.10	53.2	YES	55
2/21/2026 7:54	1.23	62	76.3	6.0	7.10	53.5	YES	55
2/22/2026 9:54	1.13	62	70.1	6.1	7.10	52.5	YES	55
2/23/2026 8:51	1.16	62	71.9	6.7	7.10	50.6	YES	55
2/24/2026 6:54	1.26	62	78.1	7.6	7.10	48.2	YES	55
2/25/2026 7:00	1.26	62	78.1	7.5	7.10	48.5	YES	55
2/26/2026 18:07	1.30	62	80.6	7.3	7.10	49.4	YES	55
2/27/2026 10:43	1.17	62	72.5	7.0	7.10	49.7	YES	55
2/28/2026 8:18	1.05	62	65.1	7.4	7.00	46.0	YES	55

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350