


**OHA - Drinking Water Services -Turbidity Monitoring Report Form**  
**Conventional or Direct Filtration**

County: **Columbia**  
 Month/Year: **Mar-26**

System Name: <b>Fishhawk Lake Reserve</b>		ID#: <b>41-00124</b>		WTP : <b>TP - Direct Filtration</b>			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.062	Plant Off	0.059	0.068	0.078	0.074	0.930
2	Plant Off	Plant Off	0.910	0.169	0.044	Plant Off	0.257
3	Plant Off	Plant Off	0.044	0.043	0.043	0.043	0.062
4	0.043	Plant Off	0.046	0.047	0.046	0.049	0.125
5	Plant Off	Plant Off	0.210	0.046	0.045	Plant Off	0.210
6	Plant Off	Plant Off	0.050	0.048	0.053	0.052	0.077
7	Plant Off	Plant Off	0.048	0.048	0.047	0.047	0.057
8	Plant Off	Plant Off	0.049	0.057	0.061	0.058	0.063
9	Plant Off	Plant Off	0.050	0.056	0.049	0.048	0.056
10	0.048	Plant Off	0.048	0.048	0.048	0.049	0.049
11	Plant Off	Plant Off	0.050	0.048	0.054	Plant Off	0.080
12	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off
13	Plant Off	Plant Off	Plant Off	0.059	Plant Off	Plant Off	0.127
14	Plant Off	Plant Off	0.172	Plant Off	Plant Off	Plant Off	0.174
15	Plant Off	Plant Off	Plant Off	0.053	Plant Off	0.054	0.295
16	0.072	0.076	0.075	0.052	0.051	0.052	0.295
17	0.051	0.051	0.050	0.055	0.053	0.052	0.133
18	0.052	0.051	0.118	0.053	0.052	0.051	0.118
19	0.051	0.052	0.057	0.054	0.055	0.053	0.124
20	0.052	Plant Off	0.054	0.053	0.054	0.056	0.113
21	0.056	Plant Off	0.058	0.058	0.058	0.057	0.058
22	Plant Off	0.059	0.062	0.076	0.057	0.055	0.062
23	0.054	0.054	0.054	0.054	0.054	0.054	0.054
24	0.054	0.054	0.054	0.058	0.056	0.055	0.088
25	0.056	0.058	0.067	0.059	0.058	0.057	0.100
26	Plant Off	Plant Off	0.058	0.056	0.055	0.055	0.068
27	Plant Off	Plant Off	0.056	0.055	0.055	0.055	0.059
28	Plant Off	Plant Off	0.087	0.057	0.057	0.057	0.087
29	Plant Off	Plant Off	0.059	0.056	0.057	0.057	0.07
30	Plant Off	Plant Off	0.058	0.056	0.056	0.056	0.059
31	0.056	0.056	0.062	Plant Off	0.062	0.058	0.295

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<b>Yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>
All turbidity readings < IFE <sup>2</sup> triggers	<b>Yes</b>		

<b>Notes: Due heavy precipitation on March 12th which blew out the creek, causing high raw water turbidity, the plant was not operated and no water was treated or pumped into the distribution system on March 12th.</b>	<b>PRINTED NAME: Andrew C. Degner</b>	
	<b>SIGNATURE:</b> 	<b>DATE: 4/4/26</b>
	<b>PHONE #: (503) 758-1232</b>	<b>CERT #: T4 2346</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - Direct Filtration

System Name:	Fishhawk Lake	ID#: 41-00124	Month/Year:	Mar-26	Disinfection <i>Giardia</i> Log Inactive:	1
--------------	---------------	---------------	-------------	--------	---	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
3/1/2026 9:03	0.98	62	60.8	6.7	7.00	47.8	YES	55
3/2/2026 12:50	1.18	62	73.2	7.0	7.00	48.0	YES	55
3/3/2026 18:44	0.96	62	59.5	7.7	7.20	47.9	YES	55
3/4/2026 15:11	0.93	62	57.7	8.7	7.10	43.2	YES	55
3/5/2026 9:25	0.89	62	55.2	9.0	7.10	42.1	YES	55
3/6/2026 10:09	0.98	62	60.8	8.8	7.00	41.6	YES	55
3/7/2026 6:52	0.96	62	59.5	8.6	7.20	45.2	YES	55
3/8/2026 14:54	1.16	62	71.9	9.0	7.10	43.4	YES	55
3/9/2026 10:27	1.06	62	65.7	9.6	7.10	41.3	YES	55
3/10/2026 7:40	1.13	62	70.1	8.3	7.10	45.3	YES	55
3/11/2026 8:51	1.12	62	69.4	7.5	7.10	47.8	YES	55
3/12/2026 0:00								
3/13/2026 9:01	1.23	62	76.3	8.0	7.10	46.8	YES	55
3/14/2026 7:44	1.22	62	75.6	8.0	7.20	48.4	YES	55
3/15/2026 8:38	1.15	62	71.3	8.2	7.00	44.2	YES	55
3/16/2026 7:01	1.44	62	89.3	8.4	7.00	45.0	YES	55
3/17/2026 19:13	1.24	62	76.9	9.2	6.90	40.3	YES	55
3/18/2026 6:14	1.20	62	74.4	9.5	7.00	40.8	YES	55
3/19/2026 15:25	1.47	62	91.1	9.6	7.10	43.2	YES	55
3/20/2026 11:16	1.64	62	101.7	9.8	7.10	43.5	YES	55
3/21/2026 12:43	1.23	62	76.3	10.0	7.10	41.0	YES	55
3/22/2026 19:21	1.52	62	94.2	9.6	7.10	43.5	YES	55
3/23/2026 15:00	1.32	62	81.8	8.1	7.20	48.6	YES	55
3/24/2026 19:04	1.00	62	62.0	8.5	7.30	47.3	YES	55
3/25/2026 14:14	1.01	62	62.6	9.1	7.30	45.5	YES	55
3/26/2026 14:15	1.05	62	65.1	9.0	7.20	44.4	YES	55
3/27/2026 10:23	1.08	62	67.0	8.3	7.10	45.1	YES	55
3/28/2026 12:48	1.12	62	69.4	7.5	7.10	47.8	YES	55
3/29/2026 7:18	1.00	62	62.0	8.6	7.00	42.3	YES	55
3/30/2026 7:10	1.12	62	69.4	8.4	7.10	45.0	YES	55
3/31/2026 14:25	1.16	62	71.9	8.9	7.30	46.9	YES	55

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350