


Day	Turbidity							Viral CT's							Clearwell level (ft)
	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest NTU of the day 1	Minimum Cl2 Residual at 1st User (C) [mg/L] 2	Contact Time (T) [minutes]	Actual CT C X T	Temp (°C)	Required CT [from table next page]	Peak Hour Demand Flow [gpm]	Required CT Met? 2 [Yes / No]	
1	OFF	OFF	0.06	0.07	0.05	0.05	0.08	0.77	60.65	46.70	8.4	8	4528	Yes	26.86
2	OFF	OFF	0.06	0.04	0.04	OFF	0.09	0.75	77.79	58.34	8.6	8	4361	Yes	33.18
3	OFF	OFF	0.06	0.05	OFF	OFF	0.06	0.86	74.45	64.03	9.8	8	4551	Yes	33.14
4	OFF	OFF	0.06	0.06	0.06	OFF	0.07	0.89	75.63	67.31	11.0	6	4537	Yes	33.56
5	OFF	OFF	0.07	0.07	OFF	OFF	0.07	0.99	74.09	73.35	10.9	6	4536	Yes	32.87
6	OFF	OFF	0.08	0.06	OFF	OFF	0.08	0.84	82.92	69.65	10.4	6	4439	Yes	36.00
7	OFF	OFF	0.05	0.05	OFF	OFF	0.07	0.83	76.63	63.60	10.4	6	4391	Yes	32.91
8	OFF	OFF	0.04	0.05	OFF	OFF	0.06	0.80	81.48	65.18	11.5	6	4387	Yes	34.96
9	OFF	OFF	0.06	0.06	OFF	OFF	0.09	0.74	83.66	61.91	10.7	6	4463	Yes	36.52
10	OFF	OFF	0.05	0.05	OFF	OFF	0.06	0.81	74.63	60.45	10.8	6	4702	Yes	34.32
11	OFF	OFF	0.05	0.05	OFF	OFF	0.07	0.91	72.88	66.32	11.0	6	4677	Yes	33.34
12	OFF	OFF	0.05	0.06	OFF	OFF	0.06	0.90	84.42	75.98	10.5	6	4452	Yes	36.76
13	OFF	OFF	0.05	0.06	OFF	OFF	0.07	0.74	81.86	60.58	10.2	6	4390	Yes	35.15
14	OFF	OFF	0.06	0.07	OFF	OFF	0.09	0.77	78.47	60.42	10.0	6	4378	Yes	33.60
15	OFF	OFF	0.08	0.05	OFF	OFF	0.08	0.65	76.89	49.98	9.5	8	4428	Yes	33.30
16	OFF	OFF	0.04	0.04	OFF	OFF	0.05	0.67	76.50	51.26	9.8	8	4421	Yes	33.08
17	OFF	OFF	0.05	0.05	OFF	OFF	0.07	0.68	75.94	51.64	9.4	8	4688	Yes	34.82
18	OFF	OFF	0.06	0.06	OFF	OFF	0.07	0.78	71.40	55.69	8.6	8	4644	Yes	32.43
19	OFF	OFF	0.07	0.06	OFF	OFF	0.09	0.84	65.52	55.04	8.3	8	4558	Yes	29.21
20	OFF	OFF	0.04	0.05	OFF	OFF	0.07	0.82	66.22	54.30	8.0	8	4524	Yes	29.30
21	OFF	OFF	0.04	0.06	OFF	OFF	0.06	0.82	84.01	68.89	6.9	8	4402	Yes	36.17
22	OFF	OFF	0.05	0.07	OFF	OFF	0.07	0.73	86.50	63.15	6.2	8	4463	Yes	37.76
23	OFF	OFF	0.07	0.05	0.05	OFF	0.09	0.75	69.38	52.04	7.0	8	4400	Yes	29.86
24	OFF	OFF	0.06	0.05	OFF	OFF	0.07	0.83	82.17	68.20	6.9	8	4366	Yes	35.09
25	OFF	OFF	0.06	0.06	0.06	OFF	0.10	0.9	59.99	53.99	7.0	8	4588	Yes	26.92
26	OFF	OFF	0.06	0.05	OFF	OFF	0.08	0.72	74.20	53.42	6.6	8	4397	Yes	31.91
27	OFF	OFF	0.06	0.07	OFF	OFF	0.08	0.64	85.73	54.87	6.0	8	4415	Yes	37.02
28	OFF	OFF	0.04	0.04	OFF	OFF	0.05	0.78	82.66	64.47	6.4	8	4642	Yes	37.53
29	OFF	OFF	0.04	0.05	OFF	OFF	0.06	0.8	82.16	65.73	8.3	8	4400	Yes	35.36
30	OFF	OFF	0.05	0.06	OFF	OFF	0.08	0.82	78.50	64.37	9.6	8	4410	Yes	33.86
31	OFF	OFF	0.05	0.06	OFF	OFF	0.07	0.89	74.51	66.31	10.2	6	4664	Yes	33.99

Conventional or Direct Filtration		Monthly Summary (circle Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	Virus CT's met everyday??	All Cl2 residual at entry point ≥ 0.2 mg/L?2
All the 4-hour turbidity readings < 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE triggers?	Yes / No3		
Monthly UV Summary (circle Yes or No)		PHONE#: (503) 266-6400	CERT #:6980
Was the volume of off-spec water produced less than 5% for the month?		DATE: 2/2/2026	
Yes / No		PRINTED NAME: Dean Harvey	
		SIGNATURE: 	

1 Highest NTU of the day is for optimization, not compliance. Highest is only for state-wide tracking of performance among all treatment systems.
 2 If CT not met or Cl2 at entry point (1st user) < 0.2 mg/L, notify DWS within 24 hours.
 3 IFE= Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Services - Surface Water Quality Data Form
Conventional or Direct Filtration with UV *Giardia*/*Crypto* Disinfection

County: Clackamas
 Month/Year: January-2026
 WTP ID: A

System Name: Canby Utility ID# 41- 00157

Minimum UVT during month: 97.72% % Duty sensor variation from reference sensor %: 3.30%
 Minimum Validated UVT: 54% Min. UV Intensity achieved/intended this month: 3.49 / 2.67 mW/cm2

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[mW/cm2]	[Y or N]	[mgal]	[mgal]	(Mo. Sum {B}) , (Mo. Sum {A}) * 100 [%]
1	566	3.5	Y	1.196	0	0
2	556	3.5	Y	2.051	0	0
3	377	3.63	Y	1.705	0	0
4	453	3.63	Y	1.553	0	0
5	445	3.53	Y	1.809	0	0
6	569	3.55	Y	1.566	0	0
7	472	3.73	Y	1.535	0	0
8	623	4.05	Y	1.657	0	0
9	668	4.38	Y	1.699	0	0
10	715	4.83	Y	1.434	0	0
11	612	3.79	Y	1.671	0	0
12	659	4.13	Y	1.634	0	0
13	641	3.99	Y	1.475	0	0
14	698	4.36	Y	1.455	0	0
15	581	3.68	Y	1.596	0	0
16	732	4.33	Y	1.747	0	0
17	593	3.83	Y	1.557	0	0
18	625	3.96	Y	1.582	0	0
19	554	3.49	Y	1.206	0	0
20	615	3.86	Y	1.960	0	0
21	559	3.56	Y	1.646	0	0
22	503	3.56	Y	1.528	0	0
23	438	3.78	Y	1.658	0	0
24	590	3.63	Y	1.781	0	0
25	410	3.53	Y	1.272	0	0
26	525	3.6	Y	1.849	0	0
27	534	3.51	Y	1.656	0	0
28	692	4.38	Y	1.610	0	0
29	744	4.65	Y	1.584	0	0
30	600	3.8	Y	1.567	0	0
31	700	4.4	Y	1.604	0	0
Monthly Cumulative % Off-Spec Water Produced 4						

4 If ≥ 5% of total water produced is off-spec., notify DWS within 24 hours.

For previous page calculation - Required CT for viral inactivation (for pH range of 6.0 to 9.9)						
Temp (C°)	0 - 4.9	5.0 - 9.9	10.0 - 14.9	15.0 - 19.9	20 -24.9	≥ 25.0 C
Required CT	12	8	6	4	3	2

Return by 10th of following month by email, fax or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350