


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Clatsop**
 Month/Year: **May-25**

System Name: **City of Cannon Beach** ID#: **41 -00164** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							
2							
3							
4							
5							
6			0.07				0.07
7			0.09				0.09
8			0.10				0.10
9			0.10				0.10
10			0.11				0.11
11			0.14				0.14
12			0.14				0.14
13			0.13				0.13
14			0.20				0.20
15			0.20				0.20
16			0.22				0.22
17			0.30				0.30
18			0.30				0.30
19			0.34				0.34
20			0.29				0.29
21			0.21				0.21
22			0.24				0.24
23			0.27				0.27
24			0.31				0.31
25			0.35				0.35
26			0.13				0.13
27			0.12				0.12
28			0.11				0.11
29			0.12				0.12
30			0.13				0.13
31			0.27				0.27

		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	YES	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	YES	YES	YES
The Slow Sand Filters were unused for the first 5 days of the month.		PRINTED NAME: Darryl Walker	
		SIGNATURE: 	DATE: 6/9/2025
		PHONE #: (503) 436-8082	CERT #: 6936

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - :A

System Name: City of Cannon Beach ID#: 41-00164

Month/Year: May-25

Disinfection *Giardia* Log

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
FILTERS OFF UNTIL MAY 6			#VALUE!			#VALUE!		
			#VALUE!			#VALUE!		
			#VALUE!			#VALUE!		
			#VALUE!			#VALUE!		
			#VALUE!			#VALUE!		
6	0.47	324	152.3	11.0	6.95	33.6	YES	468
7	0.46	312	143.5	11.0	6.96	33.6	YES	442
8	0.48	324	155.5	11.0	6.95	33.6	YES	393
9	0.47	336	157.9	11.0	6.91	33.1	YES	410
10	0.47	336	157.9	12.0	6.95	31.5	YES	452
11	0.48	324	155.5	12.0	6.96	31.6	YES	461
12	0.48	312	149.8	12.0	6.91	31.1	YES	562
13	0.46	312	143.5	12.0	6.95	31.5	YES	435
14	0.48	301	144.5	12.0	6.96	31.6	YES	439
15	0.47	312	146.6	12.0	6.96	31.6	YES	413
16	0.48	291	139.7	12.0	6.95	31.5	YES	419
17	0.48	312	149.8	12.0	6.96	31.6	YES	439
18	0.44	324	142.6	12.0	6.95	31.4	YES	448
19	0.45	324	145.8	12.0	6.95	31.4	YES	419
20	0.43	324	139.3	12.0	6.95	31.4	YES	478
21	0.46	324	149.0	12.0	6.96	31.6	YES	659
22	0.5	336	168.0	12.0	6.95	31.6	YES	432
23	0.53	336	178.1	12.0	6.95	31.7	YES	426
24	0.53	336	178.1	12.0	6.96	31.8	YES	481
25	0.51	324	165.2	12.0	6.95	31.6	YES	529
26	0.5	336	168.0	12.0	6.95	31.6	YES	581
27	0.52	336	174.7	12.0	6.91	31.2	YES	471
28	0.53	349	185.0	12.0	6.98	32.0	YES	461
29	0.52	364	189.3	12.0	6.96	31.8	YES	461
30	0.5	364	182.0	12.0	6.95	31.6	YES	450
31	0.49	380	186.2	12.0	6.95	31.6	YES	442

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350