

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Clatsop**
 Month/Year: **Jun-25**

System Name: City of Cannon Beach		ID#: 41		-00164		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.14				0.14
2			0.17				0.17
3			0.18				0.18
4			0.19				0.19
5			0.17				0.17
6			0.05				0.05
7			0.06				0.06
8			0.06				0.06
9			0.06				0.06
10			0.06				0.06
11			0.06				0.06
12			0.08				0.08
13			0.09				0.09
14			0.11				0.11
15			0.14				0.14
16			0.13				0.13
17			0.07				0.07
18			0.06				0.06
19			0.06				0.06
20			0.06				0.06
21			0.06				0.06
22			0.07				0.07
23			0.07				0.07
24			0.07				0.07
25			0.08				0.08
26			0.08				0.08
27			0.09				0.09
28			0.12				0.12
29			0.14				0.14
30			0.09				0.09
31							

95% of daily turbidity readings $\leq$ 1 NTU? ² YES All daily turbidity readings $\leq$ 5 NTU? YES		Monthly Summary (Answer Yes or No)	
		CT's met everyday? (see back) YES	All Cl2 residual at entry point $\geq$ 0.2 mg/l? YES
Notes:		PRINTED NAME: Darryl Walker	
		SIGNATURE: <i>Darryl Walker</i>	DATE: 7/6/25
		PHONE #: (503) 436-8082	CERT #: 6936

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :A

System Name: City of Cannon Beach ID#: 41-00164

Month/Year: Jun-25

Disinfection *Giardia* Log

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.54	336	181.4	13.0	6.96	29.1	YES	455
2	0.54	312	168.5	13.0	6.96	29.1	YES	682
3	0.5	312	156.0	13.0	6.95	28.9	YES	610
4	0.51	301	153.5	13.0	6.96	29.0	YES	682
5	0.5	312	156.0	14.0	6.96	27.1	YES	698
6	0.51	324	165.2	14.0	6.95	27.0	YES	542
7	0.52	312	162.2	14.0	6.96	27.2	YES	481
8	0.53	324	171.7	14.0	6.96	27.2	YES	497
9	0.55	336	184.8	14.0	6.96	27.3	YES	542
10	0.54	336	181.4	15.0	6.96	25.5	YES	643
11	0.5	324	162.0	15.0	6.95	25.2	YES	503
12	0.52	312	162.2	15.0	6.96	25.4	YES	701
13	0.52	312	162.2	15.0	6.96	25.4	YES	497
14	0.5	301	150.5	15.0	6.96	25.3	YES	487
15	0.52	312	162.2	15.0	6.97	25.5	YES	507
16	0.52	291	151.3	14.0	6.97	27.3	YES	520
17	0.5	312	156.0	14.0	6.99	27.4	YES	526
18	0.48	324	155.5	14.0	7.04	27.9	YES	500
19	0.5	324	162.0	14.0	7.06	28.1	YES	552
20	0.48	324	155.5	14.0	7.09	28.4	YES	643
21	0.5	324	162.0	14.0	7.10	28.5	YES	562
22	0.5	336	168.0	14.0	7.09	28.4	YES	516
23	0.48	336	161.3	13.0	7.08	30.2	YES	516
24	0.5	336	168.0	13.0	7.07	30.2	YES	487
25	0.5	324	162.0	13.0	7.07	30.2	YES	520
26	0.5	336	168.0	13.0	7.07	30.2	YES	491
27	0.56	336	188.2	13.0	7.07	30.4	YES	513
28	0.56	349	195.4	13.0	7.08	30.5	YES	513
29	0.56	364	203.8	13.0	7.09	30.6	YES	507
30	0.5	364	182.0	13.0	7.09	30.4	YES	520
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350