


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Clatsop
Month/Year: Aug-25

System Name:		City of Cannon Beach		ID#: 41 -00164		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.09				0.09
2			0.07				0.07
3			0.08				0.08
4			0.07				0.07
5			0.08				0.08
6			0.10				0.10
7			0.09				0.09
8			0.08				0.08
9			0.08				0.08
10			0.08				0.08
11			0.08				0.08
12			0.09				0.09
13			0.10				0.10
14			0.11				0.11
15			0.12				0.12
16			0.11				0.11
17			0.13				0.13
18			0.13				0.13
19			0.07				0.07
20			0.06				0.06
21			0.06				0.06
22			0.06				0.06
23			0.06				0.06
24			0.06				0.06
25			0.06				0.06
26			0.07				0.07
27			0.07				0.07
28			0.07				0.07
29			0.07				0.07
30			0.07				0.07
31			0.08				0.08

		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	YES	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	YES	YES	YES
Notes:		PRINTED NAME: Darryl Walker	
		SIGNATURE: 	9/1/2025
		PHONE #: (503) 440-1414	CERT #: 6936

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :A

Disinfection *Giardia* Log

System Name: City of Cannon Beach ID#: 41-00164

Month/Year: Aug-25

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.5	336	168.0	14.0	7.06	28.1	YES	536
2	0.5	312	156.0	14.0	7.04	27.9	YES	542
3	0.5	312	156.0	14.0	7.10	28.5	YES	568
4	0.48	301	144.5	14.0	7.10	28.5	YES	558
5	0.5	312	156.0	14.0	7.06	28.1	YES	545
6	0.5	324	162.0	14.0	7.05	28.0	YES	561
7	0.5	312	156.0	14.0	7.10	28.5	YES	539
8	0.48	324	155.5	14.0	7.09	28.4	YES	571
9	0.5	336	168.0	14.0	7.08	28.3	YES	561
10	0.51	336	171.4	14.0	7.09	28.5	YES	561
11	0.51	324	165.2	14.0	7.09	28.5	YES	558
12	0.5	312	156.0	15.0	7.09	26.6	YES	503
13	0.5	312	156.0	15.0	7.07	26.4	YES	601
14	0.52	301	156.5	14.0	7.06	28.2	YES	571
15	0.5	312	156.0	15.0	7.07	26.4	YES	581
16	0.5	291	145.5	14.0	7.01	27.6	YES	529
17	0.45	312	140.4	14.0	7.00	27.3	YES	539
18	0.51	324	165.2	14.0	6.97	27.2	YES	558
19	0.47	324	152.3	13.0	6.95	28.8	YES	565
20	0.51	324	165.2	13.0	6.93	28.7	YES	526
21	0.51	324	165.2	13.0	6.95	28.9	YES	526
22	0.51	336	171.4	13.0	6.95	28.9	YES	552
23	0.47	336	157.9	13.0	6.95	28.8	YES	549
24	0.5	336	168.0	13.0	6.95	28.9	YES	552
25	0.5	324	162.0	14.0	6.95	27.0	YES	529
26	0.52	336	174.7	14.0	6.96	27.2	YES	455
27	0.5	336	168.0	14.0	6.96	27.1	YES	478
28	0.45	349	157.1	13.0	6.95	28.7	YES	549
29	0.47	364	171.1	13.0	6.96	28.9	YES	529
30	0.5	364	182.0	13.0	6.95	28.9	YES	562
31	0.51	380	193.8	13.0	6.94	28.8	YES	559

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2