


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Clatsop**
 Month/Year: **Sep-25**

System Name: **City of Cannon Beach** ID#: **41** -00164 WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.08				0.08
2			0.08				0.08
3			0.06				0.06
4			0.05				0.05
5			0.06				0.06
6			0.06				0.06
7			0.06				0.06
8			0.06				0.06
9			0.07				0.07
10			0.07				0.07
11			0.07				0.07
12			0.08				0.08
13			0.09				0.09
14			0.09				0.09
15			0.10				0.10
16			0.10				0.10
17			0.11				0.11
18			0.11				0.11
19			0.12				0.12
20			0.13				0.13
21			0.18				0.18
22			0.18				0.18
23			0.24				0.24
24			0.24				0.24
25			0.26				0.26
26			0.08				0.08
27			0.08				0.07
28			0.07				0.07
29			0.07				0.07
30			0.09				0.09

		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	YES	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	YES	YES	YES
Notes:		PRINTED NAME: Darryl Walker	
		SIGNATURE: 	10/9/2025
		PHONE #: (503) 440-1414	CERT #: 6936

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :A

Disinfection *Giardia* Log

System Name: City of Cannon Beach ID#: 41-00164

Month/Year: Sep-25

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.5	336	168.0	13.0	6.91	28.4	YES	561
2	0.53	312	165.4	14.0	6.90	26.6	YES	669
3	0.53	312	165.4	14.0	6.90	26.6	YES	643
4	0.51	301	153.5	14.0	6.93	26.8	YES	568
5	0.5	312	156.0	14.0	6.95	27.0	YES	506
6	0.53	324	171.7	14.0	6.97	27.3	YES	471
7	0.53	312	165.4	14.0	6.98	27.4	YES	487
8	0.5	324	162.0	15.0	7.04	26.1	YES	513
9	0.5	336	168.0	15.0	7.03	26.0	YES	607
10	0.5	336	168.0	15.0	7.04	26.1	YES	480
11	0.5	324	162.0	15.0	7.01	25.8	YES	588
12	0.47	312	146.6	15.0	7.01	25.7	YES	523
13	0.47	312	146.6	14.0	7.02	27.6	YES	487
14	0.44	301	132.4	14.0	7.01	27.4	YES	471
15	0.41	312	127.9	14.0	7.00	27.2	YES	539
16	0.36	291	104.8	14.0	7.02	27.3	YES	539
17	0.42	312	131.0	15.0	6.96	25.1	YES	519
18	0.5	324	162.0	15.0	6.97	25.4	YES	561
19	0.5	324	162.0	14.0	6.90	26.5	YES	594
20	0.5	324	162.0	14.0	6.93	26.8	YES	471
21	0.54	324	175.0	14.0	6.94	27.0	YES	465
22	0.5	336	168.0	14.0	6.91	26.6	YES	487
23	0.39	336	131.0	14.0	6.94	26.6	YES	588
24	0.42	336	141.1	14.0	6.90	26.3	YES	536
25	0.59	324	191.2	14.0	6.90	26.8	YES	581
26	0.67	336	225.1	14.0	6.91	27.1	YES	594
27	0.53	336	178.1	13.0	6.93	28.8	YES	503
28	0.56	349	195.4	13.0	6.89	28.4	YES	458
29	0.5	364	182.0	13.0	6.87	28.0	YES	445
30	0.5	364	182.0	13.0	6.89	28.2	YES	533
31			#VALUE!			#VALUE!	#VALUE!	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350