

OHA - Drinking Water Services - Surface Water Quality Data Form
Unfiltered System

County: Grant
Month/Year: 23-Jun
WTP: TP - A

System Name:	Canyon City			ID#: 41	00165	Highest Reading of the day ¹ [NTU]	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	
1							0.08
2							0.09
3							0.09
4							0.10
5							0.09
6							0.08
7							0.08
8							0.11
9							0.33
10							0.54
11							0.43
12							0.44
13							0.31
14							0.23
15							0.23
16							0.19
17							0.20
18							0.21
19							0.26
20							0.39
21							0.42
22							0.23
23							0.20
24							0.18
25							0.28
26							0.43
27							0.23
28							0.22
29							0.18
30							0.19
31							0.13

RECEIVED
AUG 10 2023
DRINKING WATER SERVICES

Unfiltered		Monthly Summary (Answer Yes or No)	
All daily turbidity readings ≤ 5 NTU? Yes / No		CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
Notes:		Tim Madden	
		SIGNATURE: <i>Tim Madden</i>	July 23 2023
		PHONE #: ()	CERT #:

¹ One reading per day allowed.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :A

Disinfection *Giardia* Log

1.0

System Name: Canyon City ID#: 41 00165 Month/Year: 23-Jul

Inactiv:

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T) (79 or 106)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	minutes	C X T	[° C]		table/formula	Yes / No	[GPM]
1	0.83	79	65.6	16.9	9.30	55.0	YES	
2	0.81	79	64.0	16.7	9.30	55.6	YES	
3	0.82	79	64.8	17.2	9.50	58.0	YES	
4	0.81	79	64.0	16.5	9.30	56.3	YES	
5	0.84	79	66.4	17.2	9.50	58.1	YES	
6	0.84	79	66.4	17.4	9.20	51.4	YES	
7	0.82	79	64.8	17.9	9.30	51.4	YES	
8	0.84	79	66.4	16.5	9.40	58.6	YES	
9	0.79	79	62.4	18.0	9.40	52.8	YES	
10	0.84	79	66.4	18.4	9.40	51.7	YES	
11	0.8	79	63.2	18.7	9.20	46.9	YES	
12	0.8	79	63.2	16.1	9.40	59.9	YES	
13	0.87	79	68.7	16.1	9.40	60.4	YES	
14	0.86	79	67.9	16.3	9.40	59.6	YES	
15	0.82	79	64.8	18.7	9.40	50.6	YES	
16	0.77	79	60.8	19.7	9.10	42.2	YES	
17	0.84	79	66.4	18.0	9.20	49.4	YES	
18	0.96	79	75.8	18.5	9.20	48.4	YES	
19	0.92	79	72.7	18.5	9.30	50.0	YES	
20	0.89	79	70.3	18.8	9.20	47.1	YES	
21	0.99	79	78.2	19.8	9.10	43.0	YES	
22	1.2	79	94.8	17.6	9.30	54.8	YES	
23	1.12	79	88.5	19.1	9.00	44.0	YES	
24	1.1	79	86.9	17.4	9.30	54.9	YES	
25	1.12	79	88.5	17.6	9.30	54.3	YES	
26	1.17	79	92.4	16.5	9.40	60.9	YES	
27	1.2	79	94.8	17.4	9.30	55.5	YES	
28	1.16	79	91.6	17.2	9.20	54.0	YES	
29	1.17	79	92.4	16.7	9.30	57.9	YES	
30	1.13	79	89.3	16.4	9.20	56.7	YES	
31	1.38	79	109.0	16.1	9.30	61.7	YES	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised Sep. 14, 2022 W.G.

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO box 14150, Portland, OR 97293-0350

RECEIVED

AUG 10 2023

DRINKING WATER SERVICES