

OHA - Drinking Water Services - Surface Water Quality Data Form
Unfiltered System

County: Grant
Month/Year: 24-Apr

System Name:	Canyon City		ID#: 41 00165		WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							0.13
2							0.12
3							0.17
4							0.22
5							0.19
6							0.18
7							0.17
8							0.14
9							0.11
10							0.10
11							0.10
12							0.12
13							0.13
14							0.12
15							0.12
16							0.14
17							0.16
18							0.12
19							0.14
20							0.12
21							0.12
22							0.16
23							0.15
24							0.12
25							0.12
26							0.14
27							0.15
28							0.16
29							0.16
30							0.17
31							0.13

Unfiltered

All daily turbidity readings ≤ 5 NTU? Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

Tim Madden

SIGNATURE: Tim

(541)620-0365

24-Apr

D-09145

¹ One reading per day allowed.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :A
 Disinfection *Giardia* Log
 Inactiv: 1.0

System Name: Canyon City ID#: 41 00165 Month/Year: 24-Apr

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T) (79 or 106)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	minutes	C X T	[° C]		table/formula	Yes / No	[GPM]
1	0.84	106	89.0	11.3	9.20	76.3	YES	
2	0.94	106	99.6	11.1	7.80	47.2	YES	
3	0.87	106	92.2	9.2	7.80	53.2	YES	
4	0.83	106	88.0	8.9	7.10	42.1	YES	
5	0.8	106	84.8	10.4	6.40	30.0	YES	
6	0.97	106	102.8	9.6	6.00	28.1	YES	
7	0.98	106	103.9	9.7	6.80	36.6	YES	
8	0.82	106	86.9	9.1	7.00	40.1	YES	
9	0.72	106	76.3	10.4	6.50	30.8	YES	
10	0.89	106	94.3	9.1	6.70	36.4	YES	
11	0.93	106	98.6	10.4	8.70	68.3	YES	
12	0.89	106	94.3	12.2	7.80	43.6	YES	
13	0.76	106	80.6	13.0	7.60	37.8	YES	
14	0.78	106	82.7	10.7	8.40	59.0	YES	
15	0.78	106	82.7	9.7	6.90	37.1	YES	
16	0.67	106	71.0	10.0	6.40	30.3	YES	
17	0.9	106	95.4	10.5	7.20	39.6	YES	
18	0.84	106	89.0	10.7	6.90	35.0	YES	
19	0.67	106	71.0	12.3	7.80	42.3	YES	
20	0.65	106	68.9	10.7	7.90	48.6	YES	
21	0.68	106	72.1	11.5	7.60	41.6	YES	
22	0.78	106	82.7	14.2	8.20	43.7	YES	
23	0.68	106	72.1	12.2	7.90	44.1	YES	
24	0.76	106	80.6	14.7	9.00	56.5	YES	
25	0.66	106	70.0	12.9	9.20	67.7	YES	
26	0.97	106	102.8	11.7	9.30	78.2	YES	
27	1.05	106	111.3	13.8	9.20	66.7	YES	
28	1.02	106	108.1	12.8	8.50	54.9	YES	
29	1.04	106	110.2	11.2	8.70	65.5	YES	
30	0.98	106	103.9	10.9	8.40	59.6	YES	
31		106						

If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised Sep. 14, 2022 W.G.

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350