

OHA - Drinking Water Services - Surface Water Quality Data Form
Unfiltered System

County: Grant
Month/Year: 25-Mar

System Name: Canyon City ID#: 41 00165 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							0.10
2							0.10
3							0.11
4							0.12
5							0.09
6							0.10
7							0.09
8							0.09
9							0.10
10							0.09
11							0.11
12							0.10
13							0.11
14							0.10
15							0.12
16							0.13
17							0.11
18							0.10
19							0.10
20							0.11
21							0.10
22							0.09
23							0.10
24							0.09
25							0.08
26							0.13
27							0.15
28							0.13
29							0.09
30							0.09
31							0.09

Unfiltered

Monthly Summary (Answer Yes or No)

All daily turbidity readings ≤ 5 NTU?

Yes / No

CT's met everyday? (see back)

Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l?

Yes / No

Notes:

Tim Madden

SIGNATURE:

4/4/2025

(541)620-0365

D-09145

¹ One reading per day allowed.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :A

Disinfection *Giardia* Log

Inactiv:

1.0

System Name: Canyon City

ID#: 41

00165

Month/Year: 25-Mar

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T) (79 or 106)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	minutes	C X T	[° C]		table/formula	Yes / No	[GPM]
1	0.68	106	72.1	7.8	5.60	26.7	YES	
2	0.72	106	76.3	9.3	5.60	24.5	YES	
3	0.74	106	78.4	8.2	6.80	39.3	YES	
4	0.78	106	82.7	9.5	6.10	28.7	YES	
5	0.84	106	89.0	7.2	6.50	38.2	YES	
6	0.82	106	86.9	9.2	7.30	44.3	YES	
7	0.76	106	80.6	8.5	6.60	36.1	YES	
8	0.73	106	77.4	11.3	7.60	42.4	YES	
9	0.78	106	82.7	9.2	8.30	63.0	YES	
10	0.74	106	78.4	9.5	7.80	51.3	YES	
11	0.74	106	78.4	9.8	8.40	62.4	YES	
12	0.97	106	102.8	7.6	8.00	64.4	YES	
13	1.37	106	145.2	8.9	7.70	55.4	YES	
14	1.14	106	120.8	8.4	8.70	80.4	YES	
15	1.02	106	108.1	8.0	7.60	54.6	YES	
16	0.75	106	79.5	7.6	8.50	75.3	YES	
17	0.94	106	99.6	8.8	8.60	73.6	YES	
18	0.76	106	80.6	7.5	8.10	65.6	YES	
19	0.9	106	95.4	8.7	6.70	37.4	YES	
20	0.91	106	96.5	7.5	7.10	46.6	YES	
21	0.84	106	89.0	9.0	5.60	25.3	YES	
22	0.72	106	76.3	7.6	6.70	39.4	YES	
23	0.79	106	83.7	7.9	6.40	35.1	YES	
24	0.72	106	76.3	8.9	6.70	36.2	YES	
25	0.73	106	77.4	8.4	8.30	66.1	YES	
26	0.71	106	75.3	11.9	9.10	69.5	YES	
27	0.62	106	65.7	11.9	8.40	53.4	YES	
28	0.45	106	47.7	9.7	6.40	30.2	YES	
29	1.12	106	118.7	6.4	6.10	36.2	YES	
30	1.25	106	132.5	10.8	6.50	31.8	YES	
31	1.41	106	149.5	10.7	7.00	38.6	YES	

³ If Cl₂ at entry point < 0.2 mg/L or CT not met, notify DWS within 24 hours.

Revised Sep. 14, 2022 W.G.

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350