OHA - Drinking Water Services - Surface Water Quality Data Form
Unfiltered System

System Name:	**Canyon City**	**ID#: 41 00165**	**County:** Grant
			Month/Year: 25-Oct
			WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [1] [NTU]
1							0.14
2							0.12
3							0.11
4							0.15
5							0.14
6							0.19
7							0.15
8							0.11
9							0.14
10							0.17
11							0.21
12							0.16
13							0.18
14							0.18
15							0.15
16							0.17
17							0.16
18							0.18
19							0.20
20							0.17
21							0.15
22							0.19
23							0.16
24							0.14
25							0.14
26							0.14
27							0.18
28							0.21
29							0.17
30							0.23
31							0.16

Unfiltered	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? **Yes / No**	**Yes / No**	**Yes / No**

Notes:	**Tim Madden**	
	SIGNATURE:	25-Oct
	(541)620-0365	D-09145

[1] One reading per day allowed.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: Canyon City **ID#:** 41 00165 **Month/Year:** 25-Oct

WTP- :A
Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl_2 Residual at 1st User (C) [3]	Contact Time (T) (79 or 106)	Actual CT	Temp	pH	Required CT	CT Met? [3]	Peak Hourly Demand Flow
	[ppm or mg/L	minutes	C X T	[° C]		table/formula	Yes / No	[GPM]
1	1	106	106.0	13.9	9.40	70.9	YES	
2	0.87	106	92.2	13.2	9.50	75.8	YES	
3	0.81	106	85.9	13.7	9.60	75.6	YES	
4	0.8	106	84.8	13.4	9.60	77.0	YES	
5	0.83	106	88.0	12.7	9.70	83.9	YES	
6	1.18	106	125.1	12.5	9.80	91.7	YES	
7	1.17	106	124.0	12.3	9.80	92.4	YES	
8	0.89	106	94.3	12.7	9.80	87.6	YES	
9	0.92	106	97.5	12.4	9.80	89.1	YES	
10	0.95	106	100.7	12.2	9.80	90.6	YES	
11	1.11	106	117.7	11.5	9.80	97.0	YES	
12	1.17	106	124.0	10.7	9.80	103.3	YES	
13	1.05	106	111.3	11.3	9.80	97.7	YES	
14	0.95	106	100.7	11.7	9.80	93.9	YES	
15	0.87	106	92.2	12.4	9.70	85.3	YES	
16	0.87	106	92.2	11.7	9.70	89.6	YES	
17	0.99	106	104.9	12.4	9.80	89.8	YES	
18	1.11	106	117.7	10.2	9.80	106.2	YES	
19	0.92	106	97.5	10.9	9.60	91.8	YES	
20	0.94	106	99.6	11.7	9.60	87.0	YES	
21	0.94	106	99.6	10.7	9.70	96.8	YES	
22	0.87	106	92.2	11.1	9.60	90.0	YES	
23	0.96	106	101.8	12.0	9.70	88.7	YES	
24	1.1	106	116.6	12.1	9.60	86.3	YES	
25	0.95	106	100.7	10.3	9.50	92.6	YES	
26	0.95	106	100.7	9.8	9.40	92.4	YES	
27	0.97	106	102.8	10.6	9.60	94.3	YES	
28	0.99	106	104.9	10.2	9.70	100.9	YES	
29	0.92	106	97.5	10.2	9.60	96.4	YES	
30	1.06	106	112.4	10.9	9.60	93.4	YES	
31	1.01	106	107.1	10.7	9.50	90.7	YES	

[3] If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised Sep. 14, 2022 W.G.

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350