

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas

Month/Year: Jan-21

System Name:	Canyonville, City Of		ID#: 41	00169	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.000	0.000	0.043	0.035	0.039	0.000	0.043
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.000	0.036	0.091	0.092	0.092
5	0.071	0.056	0.041	0.034	0.058	0.035	0.071
6	0.030	0.028	0.028	0.049	0.030	0.028	0.049
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.039	0.036	0.030	0.039
12	0.028	0.027	0.031	0.039	0.030	0.029	0.039
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.000	0.040	0.032	0.040
15	0.028	0.027	0.029	0.040	0.034	0.026	0.040
16	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.030	0.041	0.030	0.041
21	0.028	0.028	0.026	0.030	0.046	0.029	0.046
22	0.026	0.028	0.029	0.042	0.032	0.029	0.042
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.037	0.028	0.028	0.037
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28	0.000	0.000	0.000	0.031	0.063	0.034	0.063
29	0.033	0.031	0.035	0.090	0.084	0.089	0.090
30	0.080	0.062	0.050	0.029	0.028	0.000	0.080
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: BRILL KELLY

SIGNATURE: *Brill Kelly* DATE: 2-5-21

PHONE #: (541) 580-2551 CERT #: P-8301

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl (333-061-0040(1)(e)(B&C))

PAGE 1 of 2

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: 1/21

Required Log
Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
January	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/10:23 ^A _m	2.34	21	49	9.6	7.70	42	yes	370
2/ off	-	-	-	-	-	-	-	off
3/ off	-	-	-	-	-	-	-	off
4/9:56 ^A _m	2.22	21	47	10.7	7.59	31	yes	370
5/9:11 ^A _m	2.18	21	46	9.9	7.62	41	yes	370
6/08:40 ^A _m	2.04	21	43	10.5	7.58	30	yes	370
7/ off	-	-	-	-	-	-	-	off
8/ off	-	-	-	-	-	-	-	off
9/ off	-	-	-	-	-	-	-	off
10/ off	-	-	-	-	-	-	-	off
11/8:58 ^A _m	2.09	21	44	10.3	7.64	30	yes	370
12/3:40 ^P _m	2.18	21	46	11.5	7.69	31	yes	370
13/ off	-	-	-	-	-	-	-	off
14/3:30 ^P _m	2.05	21	43	12.6	7.64	30	yes	370
15/3:30 ^P _m	2.09	21	44	10.7	7.65	30	yes	370
16/ off	-	-	-	-	-	-	-	off
17/ off	-	-	-	-	-	-	-	off
18/ off	-	-	-	-	-	-	-	off
19/ off	-	-	-	-	-	-	-	off
20/1:35 ^P _m	2.39	21	50	9.1	7.71	42	yes	370
21/11:20 ^A _m	2.21	21	46	8.7	7.74	41	yes	370
22/8:15 ^A _m	2.50	21	52	8.6	7.81	42	yes	370
23/ off	-	-	-	-	-	-	-	off
24/ off	-	-	-	-	-	-	-	off
25/8:15 ^A _m	2.05	21	43	7.6	7.81	41	yes	370
26/ off	-	-	-	-	-	-	-	off
27/ off	-	-	-	-	-	-	-	off
28/8:50 ^A _m	2.16	21	45	8.7	7.87	41	yes	370
29/11:00 ^A _m	2.12	21	45	8.1	7.56	41	yes	370
30/10:35 ^A _m	2.26	21	47	9.6	7.65	41	yes	370
31/ off	-	-	-	-	-	-	-	off

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf