

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Feb-22

System Name: Canyonville, City Of ID#: 41 00169 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	off	0.026	0.014	0.012	0.026
2	0.016	0.015	0.020	0.020	0.024	0.014	0.024
3	off	off	off	off	off	off	off
4	off	off	off	0.018	0.015	0.015	0.018
5	off	off	off	off	off	off	off
6	off	off	off	off	off	off	off
7	off	off	off	off	off	off	off
8	off	off	off	0.012	0.018	0.014	0.018
9	0.014	0.019	0.028	0.068	0.018	0.015	0.068
10	0.013	off	off	off	off	off	0.013
11	off	off	off	off	off	off	off
12	off	off	off	0.014	0.018	0.026	0.026
13	0.033	0.021	0.023	0.017	0.015	0.014	0.033
14	off	off	off	off	off	off	off
15	off	off	off	off	0.014	0.015	0.015
16	0.017	0.015	0.022	0.020	0.018	0.014	0.022
17	off	off	off	0.025	0.016	off	0.025
18	off	off	off	0.026	0.018	off	0.026
19	off	off	off	off	off	off	off
20	off	off	off	off	off	off	off
21	off	off	off	off	off	off	off
22	off	off	off	0.048	0.018	0.015	0.048
23	0.014	0.017	0.032	0.025	0.018	0.014	0.032
24	0.016	0.017	off	off	0.017	0.016	0.017
25	off	off	off	0.021	0.022	0.017	0.022
26	off	off	off	off	off	off	off
27	off	off	off	0.019	0.019	0.015	0.019
28	0.014	0.014	off	off	off	off	0.014
29							
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: BLIM KELLY

SIGNATURE: *[Signature]* DATE: 3-7-22

PHONE #: (541) 580-2581 CERT #: D-8441 T-8301

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year:

Required Log
Inactivation: O

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/ 2:50 P M	1.82	21	38	7.8	7.44	33	yes	370
2/ 8:05 A M	1.71	21	36	6.7	7.43	33	yes	370
3/ off	-	-	-	-	-	-	-	off
4/ 10:35 A M	1.65	21	35	8.1	7.43	32	yes	370
5/ off	-	-	-	-	-	-	-	off
6/ off	-	-	-	-	-	-	-	off
7/ off	-	-	-	-	-	-	-	off
8/ 3:40 P M	1.64	21	35	7.2	7.47	32	yes	370
9/ 3:35 P M	1.66	21	35	7.7	7.47	32	yes	370
10/ 2:00 P M	1.63	21	34	8.0	7.39	32	yes	370
11/ off	-	-	-	-	-	-	-	off
12/ 1:00 P M	1.70	21	36	8.4	7.43	33	yes	370
13/ 2:10 P M	1.67	21	35	7.7	7.39	32	yes	370
14/ off	-	-	-	-	-	-	-	off
15/ 3:50 P M	1.62	21	34	8.2	7.45	32	yes	370
16/ 3:50 P M	1.67	21	35	8.3	7.42	32	yes	370
17/ 1:15 P M	1.65	21	35	9.1	7.38	32	yes	370
18/ 3:45 P M	1.66	21	35	8.8	7.42	32	yes	370
19/ off	-	-	-	-	-	-	-	off
20/ off	-	-	-	-	-	-	-	off
21/ off	-	-	-	-	-	-	-	off
22/ 3:40 P M	1.61	21	34	7.4	7.49	32	yes	370
23/ 10:30 A M	1.67	21	35	6.4	7.49	32	yes	370
24/ 3:45 P M	1.66	21	35	6.2	7.47	32	yes	370
25/ 1:30 P M	1.70	21	36	6.0	7.48	32	yes	370
26/ off	-	-	-	-	-	-	-	off
27/ 1:00 P M	1.68	21	35	6.1	7.47	32	yes	370
28/ 3:45 P M	1.70	21	36	9.8	7.48	32	yes	370
29/	-	-	-	-	-	-	-	-
30/	-	-	-	-	-	-	-	-
31/	-	-	-	-	-	-	-	-

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.