

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: Mar. 22

System Name:	Canyonville, City Of		ID#: 41	00169		WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	off	off	off	0.020	0.030	0.019	0.030
2	off	off	off	off	0.021	0.017	0.021
3	off	off	off	0.033	0.051	0.027	0.051
4	off	off	off	0.050	0.031	0.035	0.050
5	off	off	off	off	off	off	off
6	off	off	off	off	off	off	off
7	off	off	off	off	off	off	off
8	off	off	off	0.016	0.014	0.014	0.016
9	0.019	0.017	0.052	0.020	0.014	0.015	0.052
10	0.013	0.015	0.015	off	0.017	0.014	0.017
11	off	off	off	off	off	off	off
12	off	off	off	off	off	off	off
13	off	off	off	off	off	off	off
14	off	off	off	off	off	off	off
15	off	off	off	0.016	0.014	0.014	0.016
16	0.014	0.014	0.035	0.017	0.014	0.015	0.035
17	0.014	0.013	0.015	0.019	0.016	off	0.019
18	off	off	off	off	off	off	off
19	off	off	off	off	0.016	0.015	0.016
20	0.016	0.015	off	off	off	off	0.016
21	off	off	off	off	off	off	off
22	off	off	off	off	off	off	off
23	off	off	off	0.016	0.015	0.013	0.016
24	0.014	0.014	0.014	0.015	0.023	0.015	0.023
25	0.014	0.013	off	off	off	off	0.014
26	off	off	off	off	off	off	off
27	off	off	off	off	off	off	off
28	off	off	off	off	off	off	off
29	off	off	off	0.140	0.014	0.015	0.140
30	0.019	0.017	0.019	0.015	0.016	0.013	0.019
31	off	off	off	0.016	0.012	0.016	0.016

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / No		

Notes:

PRINTED NAME: BRIAN KELLY  
 SIGNATURE: *Brian Kelly* DATE: 4-6-22  
 PHONE #: (541) 560-2561 CERT #: *D-8441 T-8301*

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

# OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year:

March 2022

Required Log Inactivation: 0.5/1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
Mar-22								
1/ 2:00 P	1.50	21	32	11.0	7.47	23	yes	370
2/ 2:50 P	1.43	21	30	11.5	7.49	23	yes	370
3/ 3:25 P	1.37	21	29	11.1	7.51	23	yes	370
4/ 10:10 A	1.40	21	29	10.4	7.53	23	yes	370
5/ OFF	-	-	-	-	-	-	-	OFF
6/ OFF	-	-	-	-	-	-	-	OFF
7/ OFF	-	-	-	-	-	-	-	OFF
8/ 3:45 P	1.65	21	35	8.6	7.47	32	yes	370
9/ 1:50 P	1.68	21	35	9.8	7.45	32	yes	370
10/ 2:15 P	1.62	21	35	9.8	7.46	32	yes	370
11/ OFF	-	-	-	-	-	-	-	OFF
12/ OFF	-	-	-	-	-	-	-	OFF
13/ OFF	-	-	-	-	-	-	-	OFF
14/ OFF	-	-	-	-	-	-	-	OFF
15/ 3:40 P	1.40	21	29	10.9	7.44	23	yes	370
16/ 3:45 P	1.36	21	29	10.9	7.47	23	yes	370
17/ 3:50 P	1.33	21	28	10.8	7.43	23	yes	370
18/ OFF	-	-	-	-	-	-	-	OFF
19/ 2:00 P	1.33	21	28	11.0	7.42	23	yes	370
20/ 10:06 A	1.42	21	30	10.1	7.39	23	yes	370
21/ OFF	-	-	-	-	-	-	-	OFF
22/ OFF	-	-	-	-	-	-	-	OFF
23/ 3:15 P	1.35	21	29	13.8	7.35	23	yes	370
24/ 2:40 P	1.40	21	29	14.1	7.37	23	yes	370
25/ 2:00 P	1.38	21	29	15.5	7.38	16	yes	370
26/ OFF	-	-	-	-	-	-	-	OFF
27/ OFF	-	-	-	-	-	-	-	OFF
28/ OFF	-	-	-	-	-	-	-	OFF
29/ 3:00 P	1.33	21	28	13.7	7.50	23	yes	370
30/ 2:15 P	1.29	21	27	13.1	7.51	23	yes	370
31/ 1:40 P	1.41	21	29	15.4	7.24	16	yes	370

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.