

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Apr. 22

System Name: Canyonville, City Of ID#: 41 00169 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2	off	off	off	off	off	off	off
3	off	off	off	off	off	off	off
4	off	off	off	off	off	off	off
5	off	off	off	0.021	0.044	0.023	0.041
6	0.020	0.021	0.018	0.018	0.029	0.020	0.029
7	0.018	0.018	0.017	0.017	0.017	0.017	0.018
8	off	off	off	0.018	0.017	off	0.018
9	off	off	off	off	off	off	off
10	off	off	off	off	off	off	off
11	off	off	off	0.017	0.018	0.018	0.018
12	0.020	0.032	off	0.029	0.022	0.023	0.032
13	0.018	off	off	off	0.053	0.048	0.053
14	0.039	off	off	0.033	0.027	0.041	0.041
15	off	off	off	0.034	0.029	0.024	0.034
16	off	off	off	off	off	off	off
17	off	off	off	off	off	0.047	0.047
18	0.017	0.024	0.045	0.076	0.027	0.022	0.076
19	off	off	off	0.031	0.031	off	0.031
20	off	off	off	0.078	0.025	0.025	0.078
21	off	off	off	off	off	off	off
22	off	off	off	off	off	off	off
23	off	off	off	0.025	0.020	0.017	0.025
24	0.036	off	off	0.030	0.020	0.018	0.030
25	off	off	off	off	off	off	off
26	off	off	off	off	off	off	off
27	off	off	off	0.042	0.021	0.020	0.042
28	0.019	0.018	0.019	0.021	0.026	0.021	0.026
29	off	off	off	off	0.020	0.020	0.020
30	off	off	off	off	off	off	off
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: BRIAN KELLY

SIGNATURE: *Brian Kelly* DATE: 5-5-22

PHONE #: (541) 580-2581 CERT #: *2-841*
8301

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year:

April 2022

Required Log Inactivation: 0.5/1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/ 3:45 P	1.27	21	27	11.8	7.45	23	yes	370
2/ off	-	-	-	-	-	-	-	off
3/ off	-	-	-	-	-	-	-	off
4/ off	-	-	-	-	-	-	-	off
5/ 2:15 P	1.38	21	29	10.8	7.56	23	yes	370
6/ 2:00 P	1.33	21	28	11.1	7.51	23	yes	370
7/ 4:00 P	1.33	21	28	13.1	7.42	23	yes	370
8/ 2:30 P	1.35	21	28	14.2	7.47	23	yes	370
9/ off	-	-	-	-	-	-	-	off
10/ off	-	-	-	-	-	-	-	off
11/ 1:30 P	1.41	21	30	10.6	7.53	23	yes	370
12/ 3:40 P	1.49	21	31	10.2	7.49	23	yes	370
13/ 3:30 P	1.41	21	30	11.9	7.44	23	yes	370
14/ 3:45 P	1.51	21	32	11.4	7.34	23	yes	370
15/ 3:45 P	1.22	21	26	11.1	7.40	23	yes	370
16/ off	-	-	-	-	-	-	-	off
17/ 9:00 P	1.31	21	28	11.5	7.40	23	yes	370
18/ 3:40 P	1.37	21	29	11.6	7.35	23	yes	370
19/ 3:00 P	1.30	21	28	11.9	7.38	23	yes	370
20/ 3:45 P	1.32	21	28	11.7	7.33	23	yes	370
21/ off	-	-	-	-	-	-	-	off
22/ off	-	-	-	-	-	-	-	off
23/ 1:30 P	1.28	21	27	13.1	7.39	23	yes	370
24/ 1:00 P	1.35	21	28	12.2	7.42	23	yes	370
25/ off	-	-	-	-	-	-	-	off
26/ off	-	-	-	-	-	-	-	off
27/ 3:45 P	1.48	21	31	11.3	7.55	23	yes	370
28/ 3:30 P	1.30	21	28	12.2	7.53	23	yes	370
29/ 3:30 P	1.28	21	27	12.6	7.55	23	yes	370
30/ off	-	-	-	-	-	-	-	off
31/								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.