

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Doug/95

Conventional or Direct Filtration

Month/Year: June 2022

System Name: Canyonville

ID#: 41-00169

WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	off	0.030	0.037	0.031	0.037
2	0.029	0.030	0.031	0.031	0.033	0.031	0.033
3	0.031	0.032	0.031	0.032	0.174	0.037	0.174
4	off	off	off	0.032	0.032	off	0.032
5	off	-	-	-	-	-	off
6	off	-	-	-	-	-	off
7	off	off	off	0.032	0.035	0.035	0.035
8	0.032	0.033	0.033	off	0.035	0.035	0.035
9	0.033	0.034	0.033	0.036	0.048	0.036	0.048
10	off	off	off	0.035	0.036	off	0.036
11	off	-	-	-	-	-	off
12	off	-	-	-	-	-	off
13	off	-	-	-	-	-	off
14	off	off	0.037	0.032	0.034	0.031	0.037
15	0.032	0.031	0.032	0.031	0.044	0.035	0.044
16	0.035	0.037	0.032	0.036	0.037	0.033	0.037
17	off	off	off	off	0.033	0.036	0.036
18	off	-	-	-	-	-	off
19	off	-	-	-	-	-	off
20	off	off	off	0.032	0.031	0.030	0.032
21	0.029	0.029	0.030	0.032	0.042	0.030	0.042
22	0.029	0.031	0.031	0.056	0.029	0.028	0.056
23	0.029	off	off	0.029	0.035	0.031	0.035
24	0.029	off	off	off	0.034	0.033	0.034
25	off	-	-	-	-	-	off
26	off	-	-	-	-	-	off
27	off	off	off	0.040	0.038	0.035	0.040
28	0.035	0.035	0.055	0.041	0.042	0.040	0.055
29	off	-	-	-	-	-	off
30	-	-	-	-	-	-	-
31	-	-	-	-	-	-	-

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No
 All 4-hour turbidity readings ≤ 1 NTU? Yes / No
 All turbidity readings < IFE² triggers Yes / No

CT's met everyday? (see back) Yes / No
 All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: BRUN KELLV
 SIGNATURE: [Signature] DATE: 7-7-22
 PHONE #: (541) 580-2581 CERT #: 8301/8441

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year:

June 2022

Required Log Inactivation: 0.5/1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
June	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/4:00 P	1.15	21	24	16.6	7.49	15	yes	370
2/3:30 P	1.22	21	26	16.5	7.56	15	yes	370
3/1:00 P	1.11	21	23	17.9	7.46	15	yes	370
4/10:00 A	1.13	21	24	18.0	7.46	15	yes	370
5/ off	-	-	-	-	-	-	-	off
6/ off	-	-	-	-	-	-	-	off
7/3:15 P	1.14	21	24	16.4	7.57	15	yes	370
8/1:30 P	1.17	21	25	16.6	7.53	15	yes	370
9/2:15 P	1.15	21	24	18.9	7.45	15	yes	370
10/3:45 P	1.11	21	23	19.0	7.46	15	yes	370
11/ off	-	-	-	-	-	-	-	off
12/ off	-	-	-	-	-	-	-	off
13/ off	-	-	-	-	-	-	-	off
14/3:20 P	1.12	21	24	17.8	7.41	15	yes	370
15/2:30 P	1.11	21	23	18.1	7.55	15	yes	370
16/1:45 P	1.12	21	24	18.8	7.46	15	yes	370
17/3:45 P	1.10	21	23	16.0	7.55	15	yes	370
18/ off	-	-	-	-	-	-	-	off
19/ off	-	-	-	-	-	-	-	off
20/11:30 A	1.01	21	21	15.3	7.58	15	yes	370
21/2:00 P	1.10	21	23	15.5	7.75	18	yes	370
22/8:30 A	1.07	21	22	17.1	7.74	18	yes	370
23/3:45 P	1.09	21	23	18.3	7.76	18	yes	370
24/3:45 P	1.09	21	23	18.1	7.78	18	yes	370
25/ off	-	-	-	-	-	-	-	off
26/ off	-	-	-	-	-	-	-	off
27/1:20 P	1.42	21	30	20.2	7.81	28	yes	500
28/8:15 A	1.44	21	30	20.3	7.83	28	yes	500
29/ off	-	-	-	-	-	-	-	off
30/7:00 A	1.44	21	30	20.4	7.85	28	yes	500
31/								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.