

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: Jul-22

System Name: Canyonville, City Of ID#: 41 00169 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.045	0.043	0.044	off	off	off	0.045
2	off	off	off	0.045	0.043	0.043	0.045
3	0.044	0.047	0.058	0.046	0.044	off	0.058
4	off	off	0.043	0.044	0.042	off	0.044
5	off	0.043	0.054	off	off	off	0.054
6	off	off	off	off	off	off	off
7	0.044	0.043	0.044	0.045	0.043	0.045	0.045
8	off	off	off	off	off	off	off
9	off	off	off	off	off	off	off
10	off	off	off	off	0.040	0.041	0.041
11	0.042	0.039	0.038	0.033	0.032	0.035	0.042
12	off	off	off	off	off	off	off
13	off	off	off	0.040	0.033	0.032	0.040
14	0.031	0.031	0.033	0.032	off	0.033	0.033
15	0.031	off	off	0.032	0.062	0.032	0.062
16	0.033	off	off	0.031	0.031	off	0.033
17	off	off	off	off	off	off	off
18	off	off	off	0.031	0.035	0.032	0.035
19	0.030	0.030	0.030	0.042	0.031	0.029	0.042
20	0.030	off	off	0.030	0.029	off	0.030
21	off	off	off	0.030	0.033	0.030	0.033
22	off	off	off	off	off	off	off
23	off	off	0.028	0.028	0.025	0.024	0.028
24	0.023	0.022	0.023	0.024	0.025	off	0.025
25	off	off	off	off	off	off	off
26	off	off	0.025	0.024	0.058	0.025	0.058
27	0.024	0.024	0.024	0.025	0.056	0.024	0.056
28	0.024	0.024	0.024	off	0.025	0.024	0.025
29	off	off	0.025	0.085	0.026	0.024	0.086
30	0.022	0.027	off	0.022	0.024	off	0.027
31	off	off	0.022	0.025	0.025	0.024	0.025

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / No		

Notes:

PRINTED NAME: BRIM KELLY

SIGNATURE: *[Signature]* DATE: 8-8-22

PHONE #: (541) 580-2581 CERT #: P-8141 / T-8311

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2

# OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: July 22

Required Log Inactivation: 0.5/1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
<u>July 22</u>	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/ 7:30 A	2.05	21	43	19.0	7.85	41	yes	500
2/ 10:00 A	2.06	21	43	18.3	7.88	41	yes	500
3/ 7:30 A	2.06	21	43	17.1	7.89	41	yes	500
4/ 10:15 A	2.07	21	43	17.5	7.90	41	yes	500
5/ 07:45 A	2.04	21	43	17.7	7.87	41	yes	500
6/ off	-	-	-	-	-	-	-	off
7/ 6:15 P	2.10	21	44	17.5	7.90	41	yes	500
8/ off	-	-	-	-	-	-	-	off
9/ off	-	-	-	-	-	-	-	off
10/ 4:00 P	2.05	21	43	18.0	7.89	41	yes	500
11/ 1:25 P	2.03	21	43	19.1	7.88	41	yes	500
12/ off	-	-	-	-	-	-	-	off
13/ 11:00 A	1.71	21	36	20.2	7.86	30	yes	500
14/ 3:00 P	1.74	21	37	20.3	7.93	30	yes	500
15/ 2:50 P	2.03	21	43	19.7	7.94	41	yes	500
16/ 10:45 A	2.13	21	45	19.3	7.90	41	yes	500
17/ off	-	-	-	-	-	-	-	off
18/ 3:35 P	2.05	21	43	19.0	7.96	41	yes	500
19/ 2:30 P	2.04	21	43	19.4	7.91	41	yes	500
20/ 12:35 P	2.06	21	43	19.8	7.86	41	yes	500
21/ 3:40 P	2.06	21	43	19.9	7.87	41	yes	500
22/ off	-	-	-	-	-	-	-	off
23/ 9:50 A	2.04	21	43	18.1	7.95	41	yes	500
24/ 8:00 A	2.06	21	43	17.9	7.96	41	yes	500
25/ off	-	-	-	-	-	-	-	off
26/ 12:30 P	2.00	21	42	20.6	7.93	30	yes	500
27/ 8:40 A	1.68	21	35	20.7	7.89	29	yes	500
28/ 3:45 P	1.65	21	35	22.2	7.64	29	yes	500
29/ 3:15 P	1.60	21	34	23.0	7.79	29	yes	500
30/ 8:45 A	1.65	21	35	23.2	7.77	29	yes	500
31/ 8:00 A	1.49	21	31	22.4	7.76	28	yes	500

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.