

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: Sept. 22

System Name:	Canyonville, City Of		ID#:	41 00169		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	off	0.070	0.030	0.031	0.070
2	0.038	off	off	0.031	0.031	0.032	0.038
3	0.033	off	0.032	0.030	0.034	off	0.034
4	off	off	0.031	0.032	0.033	0.030	0.032
5	0.032	off	0.030	0.030	0.032	off	0.032
6	off	off	off	0.029	0.029	0.030	0.030
7	off	off	off	off	off	off	off
8	off	off	0.028	0.026	0.039	0.028	0.039
9	off	off	off	off	off	off	off
10	off	off	off	0.021	0.024	0.025	0.025
11	0.022	0.025	0.024	0.023	0.024	off	0.025
12	off	off	off	off	0.073	0.028	0.073
13	0.027	0.026	off	off	0.028	0.028	0.028
14	0.029	off	off	off	0.027	0.028	0.029
15	0.024	0.025	0.026	0.030	0.029	off	0.030
16	off	off	off	0.029	0.030	0.031	0.031
17	off	off	off	0.030	0.029	0.029	0.030
18	off	off	off	0.029	0.031	0.030	0.031
19	0.029	off	off	0.029	0.028	0.029	0.029
20	off	off	off	0.030	0.031	0.030	0.031
21	off	off	off	0.031	0.032	0.030	0.032
22	0.031	off	off	0.032	0.031	0.033	0.033
23	off	off	off	0.031	0.030	0.032	0.032
24	0.032	off	0.033	0.031	0.033	off	0.033
25	off	off	0.033	0.034	0.033	off	0.034
26	off	off	off	off	off	off	off
27	off	off	off	0.035	0.036	0.035	0.036
28	0.039	0.038	0.038	0.040	0.041	off	0.041
29	off	off	off	off	0.042	0.044	0.044
30	0.044	off	off	0.043	0.044	off	0.044
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / No		
Notes:	PRINTED NAME: <u>Brian Kelly</u> SIGNATURE: <u>[Signature]</u> DATE: <u>10-3-22</u> PHONE #: <u>(541) 560-2561</u> CERT #: <u>0844</u>	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(c)(B&C))

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: September 2022 Required Log Inactivation: 0.5/1.0

Date / Time	Minimum Cl ₂ Residual at 1" User (C) ¹	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
Sept.	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/2:15 P	2.10	21	44	19.9	7.70	41	Yes	500
3/2:17 P	2.17	21	46	20.0	7.80	31	Yes	500
5/9:13 A	2.14	21	45	19.2	7.78	41	Yes	500
7/9:50 A	1.99	21	42	19.0	7.80	41	Yes	500
9/9:20 A	2.05	21	43	18.9	7.77	41	Yes	500
11/1:00 P	2.05	21	43	19.7	7.96	41	Yes	500
21 OFF	-	-	-	-	-	-	-	OFF
3/2:30 P	2.05	21	43	18.7	7.91	41	Yes	500
5/ OFF	-	-	-	-	-	-	-	OFF
10/11:30 A	1.17	21	25	17.6	7.81	19	Yes	370
11/9:00 A	1.11	21	23	18.1	7.86	19	Yes	370
12/2:45 P	1.12	21	24	19.4	7.83	19	Yes	370
2/4:00 P	1.11	21	23	19.1	7.85	19	Yes	370
4/3:30 P	1.24	21	26	18.3	7.87	19	Yes	370
5/8:20 A	1.24	21	26	17.2	7.86	19	Yes	370
6/1:45 P	1.83	21	38	17.4	7.80	20	Yes	370
7/11:30 A	1.54	21	32	17.0	7.90	19	Yes	370
8/10:30 A	1.55	21	33	16.5	7.89	19	Yes	370
9/8:20 A	1.60	21	34	15.6	7.80	19	Yes	370
10/2:45 P	1.45	21	30	16.0	7.88	19	Yes	370
11/2:10 P	2.06	21	43	16.6	7.92	20	Yes	370
12/12:45 P	2.08	21	44	16.8	7.85	20	Yes	370
1/3:30 P	2.20	21	46	16.3	7.80	21	Yes	370
2/7:45 A	2.10	21	44	15.9	7.83	20	Yes	370
3/7:45 A	1.96	21	41	15.7	7.84	20	Yes	370
26/ OFF	-	-	-	-	-	-	-	OFF
27/2:45 P	1.18	21	25	17.4	7.84	18	Yes	370
28/2:30 P	1.42	21	30	17.5	7.85	19	Yes	370
29/3:35 P	1.16	21	25	17.5	7.80	19	Yes	370
30/10:30 A	1.17	21	25	17.2	7.82	19	Yes	370
31/								

¹ If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWP by end of next business day.
 Download form at: www.public.health.or.gov/Health/Environments/DrinkingWater/Monitoring/Documents/hurb-covv-direct.pdf