

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: Oct. 22

System Name: Canyonville, City Of		ID#: 41	00169	WTP : TP -			A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	0.048	0.050	0.049	off	0.050
2	off	off	0.049	0.049	0.051	off	0.051
3	off	off	off	0.049	0.050	0.051	0.051
4	off	off	off	0.048	0.048	0.049	0.049
5	off	off	off	0.049	0.046	0.049	0.049
6	0.051	off	off	0.050	0.048	0.046	0.051
7	off	off	off	0.044	0.055	0.049	0.055
8	off	off	off	0.046	0.046	0.046	0.046
9	off	off	off	off	off	off	off
10	off	off	0.049	0.051	0.052	0.051	0.052
11	off	off	off	off	off	off	off
12	off	off	off	off	0.044	0.045	0.045
13	0.044	0.045	0.045	0.050	0.048	0.048	0.050
14	0.046	0.045	0.046	0.045	0.047	off	0.047
15	off	off	off	0.056	0.054	0.054	0.056
16	0.051	off	off	0.054	0.051	0.053	0.054
17	off	off	off	off	off	off	off
18	off	off	off	0.054	0.054	0.056	0.056
19	0.055	0.051	0.050	0.052	off	off	0.055
20	off	off	off	off	0.054	0.059	0.059
21	0.058	0.055	off	off	off	off	0.058
22	off	off	off	off	off	off	off
23	off	off	off	off	off	off	off
24	off	off	off	off	0.118	0.069	0.118
25	0.062	0.059	0.059	0.058	0.054	0.055	0.062
26	off	off	off	0.108	0.211	0.129	0.211
27	off	off	off	off	off	off	off
28	off	off	off	off	off	off	off
29	off	off	0.057	0.064	0.069	0.069	0.069
30	off	off	off	off	off	off	off
31	off	off	off	0.056	0.053	0.051	0.065

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: BRIM KELLY
	SIGNATURE: <i>BRIM KELLY</i> DATE: 11-8-22
	PHONE #: (541) 580-2581 CERT #: 9 8381

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))
 PAGE 1 of 2

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year:

OCT. 22

Required Log Inactivation: 0.5/100

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
OCT.	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/10:00 A	1.33	21	28	17.0	7.87	19	yes	370
2/10:05 A	1.24	21	26	16.8	7.83	19	yes	370
3/2:45 P	1.16	21	24	16.8	7.80	19	yes	370
4/2:30 P	1.18	21	25	16.8	7.80	19	yes	370
5/1:30 P	1.19	21	25	16.7	7.78	19	yes	370
6/2:00 P	1.18	21	25	16.9	7.78	19	yes	370
7/11:45 A	1.16	21	24	16.3	7.80	19	yes	370
8/12:25 P	1.16	21	24	16.4	7.86	19	yes	370
9/ OFF	-	-	-	-	-	-	-	OFF
10/1:15 P	1.12	21	24	15.3	7.82	19	yes	370
11/ OFF	-	-	-	-	-	-	-	OFF
12/4:00 P	1.12	21	24	16.9	7.85	19	yes	370
13/9:00 A	1.29	21	27	15.3	7.81	19	yes	370
14/3:30 P	1.48	21	31	14.6	7.83	28	yes	370
15/11:45 A	1.46	21	31	14.7	7.87	28	yes	370
16/11:15 A	1.45	21	31	14.2	7.88	28	yes	370
17/ OFF	-	-	-	-	-	-	-	OFF
18/3:50 P	1.68	21	35	14.8	7.88	29	yes	370
19/9:35 A	1.63	21	34	13.8	7.86	29	yes	370
20/3:30 P	1.45	21	31	14.9	7.81	28	yes	370
21/3:00 P	1.45	21	31	14.0	7.80	28	yes	370
22/ OFF	-	-	-	-	-	-	-	OFF
23/ OFF	-	-	-	-	-	-	-	OFF
24/3:30 P	1.55	21	33	12.3	7.67	29	yes	370
25/9:50 A	1.57	21	33	12.1	7.65	29	yes	370
26/2:45 P	1.45	21	31	13.1	7.69	28	yes	370
27/ OFF	-	-	-	-	-	-	-	OFF
28/ OFF	-	-	-	-	-	-	-	OFF
29/9:15 A	1.65	21	35	12.1	7.70	29	yes	370
30/ OFF	-	-	-	-	-	-	-	OFF
31/3:30 P	1.82	21	38	14.1	7.62	30	yes	370

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.