

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: May 2023  
 WTP: TP - A

System Name:	Canyonville, City Of		ID#: 41	00169		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	.012	X	X	X	X	X	.012
2	X	X	X	.024	.011	.011	.024
3	.010	.011	.012	X	X	X	.012
4	X	X	X	.012	.011	.011	.012
5	.012	X	X	X	X	X	.012
6	X	X	.037	.013	.011	.013	.037
7	.011	.013	X	X	X	X	.013
8	X	X	X	X	X	X	off
9	X	X	X	.011	.010	.012	.012
10	.014	.012	.014	.012	.013	X	.014
11	X	X	X	X	X	X	off
12	X	X	X	.014	.013	.013	.014
13	.012	.012	.011	X	X	X	.012
14	X	X	X	X	X	X	off
15	X	X	X	.016	.014	.016	.016
16	.015	.016	.016	.017	.018	.016	.018
17	.014	.013	X	X	.017	X	.017
18	X	X	X	.017	.014	.015	.017
19	.018	.016	.016	.016	.015	.017	.017
20	.141	.174	.166	.189	X	X	.189
21	X	X	X	.143	.015	.015	.143
22	.016	.013	.014	.013	.016	.014	.016
23	.014	.014	.015	.032	.014	.013	.032
24	.015	X	X	X	.019	.014	.019
25	.014	.012	.015	.012	X	X	.015
26	X	X	X	.016	.015	.014	.016
27	.014	.014	.012	.015	.014	.014	.015
28	.013	X	X	X	X	X	.013
29	X	X	X	.029	.015	.013	.029
30	.014	.013	.014	.013	.014	X	.014
31	X	X	X	.017	.014	.013	.017

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: BRIAN KELLY

SIGNATURE: [Signature] DATE: 6-7-23

PHONE #: (541) 50-2581 CERT #: 0-5441 / T-8301

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2

## OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year:

Required Log  
Inactivation: O

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/2400	2.20	21	46	15.7	7.62	21	yes	370
2/1400	2.09	21	44	13.0	7.54	25	yes	370
3/0500	2.09	21	44	13.4	7.52	25	yes	370
4/0857	1.85	21	39	13.6	7.48	25	yes	370
5/2400	1.71	21	36	13.2	7.56	25	yes	370
6/1007	1.55	21	33	14.0	7.53	24	yes	370
7/0300	1.89	21	40	13.6	7.52	25	yes	370
8/ off	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	off
9/0926	1.81	21	38	13.4	7.57	25	yes	370
10/1445	1.65	21	35	13.9	7.62	30	yes	370
11/ off	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	off
12/0956	1.65	21	35	15.0	7.61	20	yes	370
13/1300	2.08	21	44	16.3	7.63	20	yes	370
14/ off	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	<del>    </del>	off
15/0153	1.76	21	34	16.5	7.63	20	yes	370
16/0515	2.00	21	42	18.4	7.58	17	yes	370
17/0420	1.00	21	21	21.4	7.59	11	yes	370
18/1056	0.88	21	19	18.6	7.52	15	yes	370
19/1600	1.16	21	24	18.2	7.52	15	yes	370
20/0800	1.48	21	31	18.9	7.51	16	yes	370
21/1105	1.20	21	25	18.3	7.48	15	yes	370
22/0900	1.51	21	32	15.5	7.58	16	yes	370
23/0850	1.73	21	36	15.3	7.51	16	yes	370
24/1515	1.76	21	37	15.7	7.52	16	yes	370
25/0830	1.98	21	42	15.3	7.50	17	yes	370
26/1036	1.60	21	33	15.5	7.54	16	yes	370
27/1130	1.53	21	32	17.2	7.59	16	yes	370
28/2400	1.15	21	24	17.2	7.62	19	yes	370
29/1121	1.22	21	25	17.2	7.56	15	yes	370
30/0905	1.35	21	28	17.2	7.42	16	yes	370
31/1530	1.98	21	42	16.7	7.62	20	yes	370

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

17r2