

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: June 2023

System Name: Canyonville, City Of ID#: 41 00169 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.013	.014	.013	.014	.013	.013	.014
2	.013	.013	.014	.022	.018	.021	.022
3	.018	X	X	X	X	X	.018
4	X	X	X	X	.017	.016	.017
5	.014	.014	.040	.027	.027	X	.040
6	X	X	X	.024	.022	.023	.024
7	X	X	X	.027	.024	.017	.047
8	.063	X	X	X	.029	.028	.063
9	.027	.028	.029	.034	X	X	.034
10	X	X	X	.027	.029	.027	.029
11	.034	X	X	X	X	.036	.036
12	X	X	X	.031	.028	.029	.031
13	.030	.030	.035	.034	.040	.034	.040
14	X	X	X	X	.044	.042	.044
15	.038	.039	.042	.042	.045	.045	.045
16	X	X	X	.044	.045	.044	.045
17	.041	X	X	X	X	.047	.047
18	X	X	X	.045	.046	.045	.046
19	.043	.045	.048	X	X	X	.048
20	X	X	X	.045	.042	.042	.045
21	.046	.042	.042	.046	X	X	.046
22	X	X	X	.041	.040	.042	.042
23	.043	.042	.042	.049	.047	.047	.049
24	X	X	X	.046	.045	X	.046
25	X	X	.045	.047	.054	.059	.059
26	X	X	X	X	.046	.046	.046
27	.046	.046	X	X	.049	.050	.050
28	.054	X	X	X	.048	.046	.054
29	.044	.047	.050	.054	X	X	.054
30	X	X	X	.050	.047	.047	.050
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / No		

Notes:

PRINTED NAME: BRW KELLY

SIGNATURE: *BRW Kelly* DATE:

PHONE #: (541) 580-2561 CERT #: *P-4441 T-8301*

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: June 2023

Required Log Inactivation: 0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/1600	2.19	21	46	15.9	7.67	21	yes	370
2/1006	2.20	21	46	15.1	7.64	41	yes	500
3/1230	2.87	21	60	15.4	7.81	44	yes	500
4/1300	2.08	21	44	16.2	7.59	33	yes	500
5/1115	2.40	21	50	16.4	7.58	35	yes	500
6/0823	2.80	21	59	16.9	7.61	44	yes	500
7/1300	2.62	21	55	18.1	7.57	36	yes	500
8/1600	2.40	21	50	18.5	7.62	42	yes	500
9/0900	2.45	21	51	18.1	7.54	35	yes	500
10/1017	2.10	21	44	18.0	7.65	41	yes	500
11/2030	2.40	21	50	18.6	7.60	42	yes	500
12/1011	2.50	21	52	18.4	7.58	36	yes	500
13/1350	2.50	21	52	19.5	7.67	43	yes	500
14/1505	2.45	21	51	18.7	7.65	42	yes	500
15/1600	2.46	21	51	17.5	7.68	43	yes	500
16/1058	2.49	21	52	16.8	7.68	43	yes	500
17/1212	2.42	21	51	17.98	7.57	35	yes	500
18/1439	2.62	21	55	17.05	7.66	43	yes	500
19/610	2.31	21	49	15.01	7.66	42	yes	500
20/0916	2.19	21	46	15.1	7.60	41	yes	500
21/0830	2.26	21	47	13.7	7.57	26	yes	370
22/1006	2.22	21	47	14.4	7.57	26	yes	370
23/0618	2.44	21	52	17.0	7.59	18	yes	370
24/0847	2.67	21	56	18.2	7.76	41	yes	500
25/0621	2.37	21	50	18.5	7.78	42	yes	500
26/1241	2.29	21	48	18.4	7.76	42	yes	500
27/0630	2.53	21	53	18.1	7.71	43	yes	500
28/1438	2.43	21	51	19.3	7.72	42	yes	500
29/0800	2.46	21	52	19.0	7.71	42	yes	500
30/1002	2.27	21	47	19.6	7.71	42	yes	500
31/								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.