

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: July 2023
WTP: TP - A

System Name:	Canyonville, City Of		ID#: 41	00169		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.048	.050	.053	0	0	.051	.053
2	0	0	0	.066	.051	.050	.066
3	.049	.050	0	0.00	0.052	0.050	.052
4	0.049	0.052	0.058	.050	.051	X	.080
5	X	X	X	.051	.052	.053	.053
6	.054	X	X	X	.053	.053	.058
7	.050	.052	X	X	.055	.059	.058
8	.060	X	X	.051	.049	.047	.060
9	X	X	X	.054	.048	.059	.059
10	.048	.046	.048	X	X	X	.048
11	X	X	.071	.050	.049	.048	.071
12	.049	.051	.058	.056	X	X	.058
13	X	X	X	.050	.047	.046	.050
14	.044	.045	.044	.051	.050	.052	.052
15	.053	X	X	X	X	.049	.053
16	.047	.045	.048	.045	.049	.051	.051
17	X	X	X	X	.046	.045	.046
18	.048	.049	.051	.050	.051	.051	.051
19	X	X	X	.045	.045	.046	.046
20	.049	X	X	X	.046	.045	.049
21	.048	.049	.051	X	X	X	.051
22	.049	.045	.044	X	X	X	.049
23	.122	.052	.054	.053	X	X	.122
24	X	X	X	.046	.048	.047	.048
25	.048	.045	.052	.052	X	X	.052
26	X	X	X	.044	.043	.044	.044
27	.043	.046	.047	X	.044	.047	.048
28	.047	X	X	X	0.046	0.045	.047
29	.046	X	X	.045	.045	.054	.054
30	X	X	X	.049	.046	.045	.049
31	.047	X	X	.046	.051	.050	.051

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> Yes / No		

Notes:

PRINTED NAME: BRIM KELLY
SIGNATURE: *Brim Kelly* DATE: 8-3-23
PHONE #: (541) 560-2581 CERT #: 98441

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))
PAGE 1 of 2

OHA - Drinking Water Program — Surface Water Quality Data Form July 2023

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: Required Log Inactivation: O

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/								
2/1246	2.21	26	46	20.0	7.62	31	yes	500
3/1243	2.35	21	49	19.55	7.87	41	yes	500
4/0936	2.61	21	55	19.0	7.70	43	yes	500
5/0917	2.45	21	51	20.7	7.74	32	yes	500
6/1700	2.17	21	45	21.2	7.67	31	yes	500
7/1325	2.04	21	43	20.4	7.62	30	yes	500
8/1146	2.22	21	46	20.2	7.67	31	yes	500
9/1351	2.31	21	48	20.2	7.70	32	yes	500
10/0839	2.20	21	46	18.7	7.70	41	yes	500
11/0826	2.17	21	45	19.1	7.70	41	yes	500
12/1160	2.33	21	49	19.4	7.65	42	yes	500
13/0941	2.13	21	45	19.9	7.68	41	yes	500
14/1545	2.16	21	45	21.5	7.69	31	yes	500
15/1845	2.26	21	47	22.3	7.59	26	yes	500
16/1409	2.16	21	45	21.9	7.67	31	yes	500
17/0953	2.31	21	48	21.8	7.72	32	yes	500
18/1101	2.17	21	45	21.0	7.69	31	yes	500
19/1109	2.08	21	44	21.0	7.72	30	yes	500
20/1614	1.73	21	36	21.3	7.63	30	yes	500
21/0842	1.970	21	41	21.5	7.60	30	yes	500
22/0620	1.97	21	41	21.5	7.60	30	yes	500
23/0633	2.10	21	44	21.5	7.58	26	yes	500
24/1031	1.88	21	40	21.3	7.73	30	yes	500
25/0745	1.70	21	36	21.0	7.63	30	yes	500
26/1001	1.87	21	39	21.0	7.73	30	yes	500
27/1631	1.85	21	38	20.4	7.60	30	yes	500
28/1416	2.42	21	50	20.6	7.73	32	yes	500
29/1057	1.95	21	41	20.1	7.74	30	yes	500
30/1105	2.08	21	43	20.5	7.77	30	yes	500
31/1155	1.93	21	40	20.0	7.75	30	yes	500

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.