

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Douglas  
Month/Year: August 2023  
WTP : TP - A

System Name:	Canyonville, City Of		ID#: 41	00169		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	.056	off	.052	.049	.049	.050	.056
2	off	off	off	.050	.053	.056	.056
3	.060	off	off	.049	.051	.053	.060
4	off	off	off	.055	X	X	.055
5	X	X	X	.066	.059	.059	.066
6	.057	.057		X	.060	.058	.060
7	X	X	X	.057	.053	.054	.057
8	.061	X	X	.060	.057	.056	.061
9	.053	X	X	.056	.060	.061	.061
10	off	off	off	.055	.050	.051	.055
11	.052	off	off	.050	.053	.056	.056
12	off	off	off	.050	.050	.050	.050
13	.048	off	off	.114	.055	.054	.114
14	.055	off	off	.051	.049	.050	.055
15	.053	.052	X	.052	.052	.053	.053
16	.052	.052	X	.053	.058	.058	.058
17	.062	X	X	.055	.054	.054	.062
18	.056	.059	off	.058	.059	.062	.062
19	X	X	X	.057	.057	.055	.057
20	X	X	X	.054	.056	.060	.060
21	X	X	X	.057	.056	.055	.057
22	.059	.055	X	X	X	X	.059
23	X	X	.055	.058	.055	.055	.058
24	.058	.061	.109	.075	X	X	.109
25	X	X	X	.057	.059	.057	.059
26	.058	.064	X	X	X	X	.064
27	.062	.061	.063	X	X	.062	.063
28	.065	.068	.059	X	.064	.060	.068
29	.061	X	X	X	.062	.065	.065
30	.066	X	X	.064	.061	.060	.066
31	.060	.061	X	.067	X	X	.067

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="checkbox"/> Yes / No		

Notes:

PRINTED NAME: BRIAN KELLY

SIGNATURE: [Signature] DATE: 9-8-23

PHONE #: (541) 580-2581 CERT #: 7-831

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2

## OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: August 2023

Required Log Inactivation: O

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T			Use tables	Yes / No	[GPM]
1/0815	2.13	21	44	20.1	7.76	31	yes	500
2/0903	1.98	21	41	20.6	7.77	30	yes	500
3/0941	2.17	21	45	20.7	7.75	31	yes	500
4/0903	2.20	21	46	20.7	7.76	31	yes	500
5/1025	1.79	21	37	21.0	7.75	30	yes	500
6/1436	1.78	21	37	20.9	7.67	30	yes	500
7/1021	1.73	21	34	21.6	7.74	30	yes	500
8/1051	1.88	21	39	21.6	7.74	30	yes	500
9/1031	1.85	21	38	21.5	7.75	30	yes	500
10/1016	1.89	21	39	21.3	7.76	30	yes	500
11/1127	1.76	21	36	21.7	7.77	30	yes	500
12/1011	1.74	21	<del>37</del> 36	21.7	7.75	30	yes	500
13/1211	1.70	21	35	21.5	7.70	30	yes	500
14/1022	2.02	21	42	21.9	7.68	30	yes	500
15/1103	2.03	21	42	22.8	7.68	30	yes	500
16/1151	1.74	21	36	23.1	7.65	30	yes	500
17/0942	2.03	21	42	23.4	7.67	30	yes	500
18/1155	1.72	21	36	23.5	7.68	30	yes	500
19/10:31	1.79	21	37	22.5	7.74	30	yes	500
20/0921	1.63	21	34	21.4	7.77	29	yes	500
21/10:12	1.62	21	34	21.02	7.78	29	yes	500
22/8:15	1.71	21	35	20.0	7.77	29	yes	500
23/0858	1.87	21	39	20.1	7.82	30	yes	500
24/1206	2.00	21	42	18.6	7.82	41	yes	500
25/1009	2.07	21	43	19.3	7.84	41	yes	500
26/0715	2.17	21	45	20.2	7.75	31	yes	500
27/10:32	2.04	21	42	20.1	7.76	30	yes	500
28/1503	2.01	21	42	20.3	7.76	30	yes	500
29/1340	1.86	21	39	20.1	7.76	30	yes	500
30/1155	2.09	21	43	19.7	7.77	41	yes	500
31/1015	1.99	21	41	19.1	7.78	41	yes	500

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.