

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas

Month/Year: Sep

System Name: Canyonville, City Of ID#: 41 00169

WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.063	.065	X	X	.069	X	.069
2	X	X	X	.072	.080	X	.080
3	X	X	X	.084	.073	.070	.084
4	X	X	X	.068	.067	.076	.076
5	X	X	X	.064	.063	X	.064
6	X	X	X	.062	.064	.076	.076
7	X	X	X	.075	.069	.075	.075
8	X	X	X	.081	.081	.072	.081
9	X	X	X	.066	.065	X	.066
10	X	X	.066	.072	.078	.077	.078
11	X	X	X	.070	.068	.066	.070
12	X	X	X	.067	.073	.074	.074
13	X	X	X	.064	.069	.070	.070
14	X	X	X	.071	.073	X	.073
15	X	X	X	.070	.071	.071	.071
16	X	X	X	X	.073	.076	.076
17	.075	.075	X	.070	X	X	.075
18	X	X	X	.070	.073	.075	.075
19	X	X	X	.071	.073	X	.073
20	X	X	X	.072	.071	X	.072
21	X	X	X	.073	.074	.069	.074
22	X	X	X	.070	.072	.078	.078
23	X	X	.075	X	.075	.074	.075
24	.071	X	X	X	.074	.075	.075
25	X	X	X	X	.096	.108	.108
26	X	X	X	X	X	X	
27	X	X	X	X	X	.136	.136
28	.096	.087	X	.079	.080	.076	.096
29	.076	.077	.075	.076	X	X	.077
30	X	X	X	X	.086	.086	.086
31							

off

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: BRIAN KELLY	DATE: 10-9-23
	SIGNATURE: <i>Brian Kelly</i>	CERT #: 10-8441 / 8361
	PHONE #: (541) 580-2581	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))
PAGE 1 of 2

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year:

Sep 2023

Required Log
Inactivation: O

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/14:30	1.96	21	41	19.07	7.77	41	yes	500
2/10:45	1.98	21	41	19.3	7.81	41	yes	500
3/10:38	2.11	21	44	19.5	7.84	41	yes	500
4/12:18	2.19	21	45	19.3	7.79	41	yes	500
5/09:48	2.43	21	51	18.8	7.85	42	yes	500
6/09:41	2.17	21	45	18.2	7.79	41	yes	500
7/10:21	2.61	21	54	17.9	7.86	43	yes	500
8/11:46	2.36	21	49	18.1	7.82	42	yes	500
9/10:46	2.61	21	54	17.9	7.85	43	yes	500
10/07:39	2.40	21	50	18.3	7.83	42	yes	500
11/11:03	2.57	21	53	18.6	7.83	43	yes	500
12/11:06	2.32	21	49	18.6	7.80	41	yes	500
13/09:58	2.59	21	54	18.8	7.83	43	yes	500
14/09:19	2.24	21	47	19.1	7.78	41	yes	500
15/09:10	2.40	21	50	18.9	7.78	42	yes	500
16/16:27	2.22	21	46	19.5	7.70	41	yes	500
17/09:33	2.64	21	55	18.6	7.73	43	yes	500
18/09:25	2.51	21	52	19.0	7.79	43	yes	500
19/09:56	2.27	21	47	18.6	7.74	41	yes	500
20/09:18	2.07	21	43	17.8	7.81	41	yes	500
21/10:14	2.44	21	51	16.6	7.89	42	yes	500
22/11:41	2.18	21	45	15.7	7.84	41	yes	500
23/07:53	2.34	21	49	15.56	7.88	42	yes	500
24/16:19	2.17	21	45	15.88	7.84	41	yes	500
25/16:33	2.17	21	45	15.79	7.81	41	yes	500
26/ off	0							
27/20:24	2.24	21	47	16.08	7.77	41	yes	500
28/10:06	2.17	21	45	15.06	7.74	41	yes	500
29/08:09	1.92	21	40	15.23	7.66	20	yes	370
30/13:34	2.03	21	42	15.86	7.68	20	yes	376
31/								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.