

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: OCT 2023  
 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	.083	.080	X	X	X	X	.085
2	.080	.076	.082	X	X	X	.082
3	X	X	X	.083	.078	.081	.083
4	.079	.080	X	X	X	X	.080
5	X	X	X	.081	.079	.081	.081
6	.079	.080	.082	X	X	X	.082
7	X	X	.100	.089	.094	X	.100
8	X	X	X	X	.144	X	.144
9	X	X	X	X	.225	.085	.225
10	.083	.085	.085	.087	.098	.094	.094
11	.092	.099	X	.110	.113	X	.110
12	X	X	X	X	.116	.099	.116
13	.095	.093	X	X	.124	.096	.124
14	.095	X	X	X	X	.095	.095
15	.091	.093	X	X	X	X	.093
16	X	X	X	.031	.032	.038	.038
17	.050	.065	X	X	.052	X	.065
18	X	X	X	.031	.030	.027	.031
19	X	X	X	X	.025	.024	.025
20	X	X	X	.027	.025	.024	.027
21	X	X	.023	X	X	X	.023
22	X	X	.026	.028	.030	X	.030
23	X	X	X	.076	.060	.059	.076
24	X	X	X	.045	.033	.031	.045
25	X	X	X	.047	X	X	.047
26	X	X	X	.084	.040	.034	.084
27	.030	.026	X	X	X	X	.030
28	X	X	X	.033	.028	.026	.033
29	.026	X	X	X	X	.022	.026
30	.025	X	X	X	.026	.025	.026
31	.022	X	X	X	.023	.022	.023

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes: PRINTED NAME: BRIAN KELLY  
 SIGNATURE: [Signature] DATE: 11-3-23  
 PHONE #: (541) 580-2581 CERT #: 8 5441 8301

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))  
 PAGE 1 of 2

## OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: *oct 2023*

Required Log Inactivation: 0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/0430	1.75	21	36	14.7	7.71	30	yes	370
2/08:30	1.887	21	39	13.4	7.713	30	yes	370
3/1157	1.72	21	36	14.3	7.69	30	yes	370
4/0430	1.95	21	40	15.3	7.71	20	yes	370
5/1040	1.85	21	38	15.8	7.66	20	yes	370
6/0800	1.99	21	41	15.5	7.70	20	yes	370
7/0739	1.82	21	38	15.8	7.67	20	yes	370
8/1619	1.78	21	37	16.7	7.67	20	yes	370
9/0516	1.90	21	39	16.7	7.68	20	yes	370
10/1550	1.69	21	35	15.9	7.69	20	yes	370
11/1009	1.56	21	32	15.1	7.67	19	yes	370
12/1509	1.70	21	35	15.7	7.68	20	yes	370
13/1652	1.94	21	40	14.5	7.72	30	yes	370
14/1947	2.06	21	43	14.3	7.68	30	yes	370
15/0400	1.49	21	31	16.2	7.73	19	yes	370
16/1131	2.06	21	43	14.8	7.69	30	yes	370
17/1531	1.64	21	33	16.4	7.61	19	yes	370
18/1013	1.66	21	34	16.3	7.66	19	yes	370
19/1341	1.81	21	38	16.0	7.68	20	yes	370
20/1110	1.86	21	39	15.4	7.69	20	yes	370
21/06:22	2.031	21	42	15.5	7.707	20	yes	370
22/06:09	1.81	21	38	15.4	7.64	20	yes	370
23/16:33	1.52	21	31	15.2	7.65	19	yes	370
24/1212	1.50	21	31	15.3	7.65	19	yes	370
25/1213	1.83	21	38	14.5	7.72	30	yes	370
26/1157	1.84	21	38	14.0	7.72	30	yes	370
27/0500	1.69	21	35	11.6	7.77	30	yes	370
28/1044	1.64	21	34	12.2	7.75	29	yes	370
29/1814	1.73	21	36	11.3	7.74	30	yes	370
30/1556	1.77	21	37	10.3	7.77	30	yes	370
31/1541	1.78	21	37	10.8	7.50	25	yes	370

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.