

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: Nov. 23
 WTP : TP - A

System Name:	Canyonville, City Of		ID#: 41	00169	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	X	X	X	X	.264	.016	.264
2	.023	X	X	X	.025	.025	.025
3	X	X	X	X	.032	.026	.032
4	X	X	X	X	X	X	df
5	X	X	X	X	.065	.051	.065
6	.046	.042	X	X	X	X	.082
7	X	X	X	X	.033	.030	.033
8	.032	.031	.031	.029	.027	X	.032
9	X	X	X	X	.055	.029	.055
10	.031	.029	X	X	X	X	.031
11	X	X	X	.025	.022	.022	.025
12	.027	.030	X	X	X	X	.030
13	X	X	X	.031	.031	.030	.031
14	.035	.028	X	X	X	X	.035
15	X	X	X	.027	.030	.025	.030
16	.030	X	X	X	X	X	.030
17	X	X	X	.037	.024	.023	.032
18	.031	.024	.024	X	X	X	.031
19	X	X	.029	.081	.070	.046	.081
20	.040	X	X	X	X	X	.040
21	X	X	X	.044	.023	.024	.044
22	.028	.028	.026	X	X	X	.028
23	X	X	X	X	X	X	df
24	X	X	X	.035	.032	.029	.035
25	.032	.031	.030	.031	X	X	.032
26	X	X	X	X	.038	.031	.038
27	.032	.036	X	X	X	X	.036
28	X	X	X	X	X	X	df
29	X	X	X	X	.033	.031	.033
30	.032	.034	.033	.030	.030	.031	.034
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: BRIAN KELLY
	SIGNATURE: <i>Brian Kelly</i> DATE: 12-4-23
	PHONE #: (541) 560-2581 CERT #: 0841 / 8301

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: Nov. 2023

Required Log
Inactivation: O

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/1650	1.89	21	39	11.1	7.53	25	yes	370
2/03:04	1.90	21	39	12.43	7.48	25	yes	370
3/1349	2.02	21	42	14.2	7.52	25	yes	370
4/ off								off
5/1314	1.72	21	36	15.2	7.46	16	yes	370
6/1025	1.81	21	38	15.3	7.39	16	yes	370
7/1505	1.67	21	35	15.0	7.38	16	yes	370
8/1200	1.74	21	36	13.4	7.37	25	yes	370
9/1524	1.82	21	38	13.7	7.40	25	yes	370
10/0300	1.76	21	36	12.4	7.39	25	yes	370
11/0936	1.79	21	37	12.9	7.39	25	yes	370
12/0300	1.78	21	37	12.6	7.39	25	yes	370
13/1043	1.67	21	35	13.2	7.39	25	yes	370
14/0300	1.66	21	34	13.6	7.38	25	yes	370
15/0827	1.42	21	29	13.9	7.39	24	yes	370
16/2400	1.79	21	37	13.6	7.39	25	yes	370
17/1043	1.73	21	36	14.0	7.38	25	yes	370
18/0450	1.666	21	34	12.7	7.37	25	yes	370
19/07:29	1.603	21	33	13.01	7.39	25	yes	370
20/2400	1.49	21	31	11.9	7.40	24	yes	370
21/1400	1.77	21	37	11.3	7.39	25	yes	370
22/0400	1.72	21	36	10.9	7.38	25	yes	370
23/ off								off
24/0914	1.63	21	34	11.5	7.39	24	yes	370
25/1245	1.65	21	34	8.5	7.48	32	yes	370
26/1323	1.78	21	37	9.3	7.48	33	yes	370
27/0300	1.77	21	37	9.2	7.49	33	yes	
28/ off								off
29/1336	1.94	21	40	8.6	7.49	33	yes	370
30/1604	1.97	21	41	7.8	7.54	33	yes	370
31/								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.