

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: Jan 2024  
 WTP: TP - A

System Name: Canyonville, City Of ID#: 41 00169

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	X	X	X	X	X	X	off
2	X	X	X	.061	.054	.056	.061
3	.054	.053	.055	.053	.054	.055	.055
4	.174	.056	X	X	X	X	
5	X	X	X	X	X	X	off
6	X	X	X	.085	.078	.056	.085
7	.064	.062	X	X	X	X	.064
8	X	X	X	X	X	X	off
9	.063	.068	.065	X	.093	.062	.093
10	.062	X	X	X	X	X	.062
11	X	X	X	X	X	X	off
12	X	X	X	X	X	X	off
13	.082	X	X	X	X	X	.082
14	X	X	X	X	X	X	.090
15	.081	.068	.068	X	.076	.060	.081
16	.070	.064	.066	.066	.078	.068	.078
17	.076	X	X	X	X	X	.076
18	X	X	X	X	.120	.071	.120
19	.072	.086	.072	.073	.074	.105	.105
20	.200	.078	.077	.070	.076	X	.200
21	X	X	X	X	X	X	off
22	X	X	X	.165	.075	.073	.165
23	.079	X	X	X	X	X	.079
24	.081	.075	.076	.075	.075	X	.081
25	X	X	X	X	X	X	off
26	X	X	X	.087	.081	.081	.087
27	.080	.098	X	X	X	X	.098
28	X	X	X	X	X	X	off
29	X	X	X	.097	.082	.081	.097
30	.083	.080	.078	.083	.083	X	.083
31	X	X	X	X	X	X	off

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		

Notes:

PRINTED NAME: BRIM KELLY  
 SIGNATURE: [Signature] DATE: 2-2-24  
 PHONE #: (541) 580-2581 CERT #: 08441 / 8301

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))  
 PAGE 1 of 2

# OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: January 2024

Required Log Inactivation: 0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/ off								off
2/ 1047	2.12	21	44	12.2	7.53	26	yes	370
3/ 1549	2.08	21	43	10.6	7.57	25	yes	370
4/ 0300	2.33	21	48	11.0	7.57	26	yes	370
5/ off								off
6/ 0921	2.14	21	44	11.5	7.50	26	yes	370
7/ 0200	2.18	21	45	9.86	7.46	26	yes	370
8/ off								off
9/ 1517	2.42	21	50	11.1	7.47	26	yes	370
10/ 2425	2.38	21	49	10.6	7.36	26	yes	370
11/ off								off
12/ 2700	2.52	21	52	11.2	7.48	27	yes	370
13/ 0921	2.83	21	59	10.7	7.67	33	yes	370
14/ 2001	4.10	21	86	11.7	7.54	28	yes	370
15/ 13:16	4.08	21	85	11.83	7.43	28	yes	370
16/ 0800	3.08	21	64	10.8	7.47	28	yes	370
17/ 2400	2.70	21	56	11.2	7.50	27	yes	370
18/ 1540	2.94	21	61	11.9	7.51	28	yes	370
19/ 0830	2.74	21	57	12.4	7.49	27	yes	370
20/ 2421	2.15	21	45	12.2	7.45	26	yes	370
21/ off								off
22/ 11:38	1.72	21	36	12.7	7.51	25	yes	370
23/ 2101	1.84	21	38	13.1	7.50	25	yes	370
24/ 0900	2.18	21	45	12.7	7.50	26	yes	370
25/ off								off
26/ 0442	1.67	21	35	13.2	7.53	25	yes	370
27/ 0200	1.83	21	38	12.8	7.53	25	yes	370
28/ off								off
29/ 1042	1.61	21	33	13.2	7.51	24	yes	370
30/ 0900	2.03	21	42	13.5	7.50	25	yes	370
31/ off								off

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.