

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: 4/24

System Name: Canyonville, City Of ID#: 41 00169 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	X	X	X	X	X	X	off
2	X	X	X	.024	.022	.021	.024
3	.023	.021	.023	.035	X	X	.035
4	X	X	X	X	X	X	off
5	X	X	X	.030	.030	.035	.042
6	.028	.027	.025	.027	.025	X	.028
7	X	X	X	X	X	X	off
8	X	X	X	X	.024	.024	.024
9	.024	.024	.024	.030	.145	X	.145
10	X	X	X	X	X	X	off
11	X	X	X	.026	.024	.022	.026
12	.023	.021	.023	.057	X	X	.057
13	X	X	X	X	X	X	off
14	X	X	X	X	X	X	off
15	X	X	X	.031	.030	.029	.031
16	.034	.035	.035	.029	X	X	.035
17	X	X	X	X	X	X	off
18	X	X	X	.031	.030	.030	.031
19	.029	.032	.032	.037	X	X	.037
20	X	X	X	X	X	X	off
21	X	X	X	X	.052	.070	.052
22	.060	.066	.063	.044	.036	X	.066
23	X	X	X	.042	.024	.027	.042
24	.027	.026	.024	.028	X	X	.028
25	X	X	X	X	X	X	off
26	X	X	X	.034	.026	.028	.034
27	.027	.026	.023	.025	.033	.030	.033
28	X	X	X	X	X	X	off
29	X	X	X	X	X	X	off
30	X	.025	.024	.024	.021	.026	.039
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: BRIM KELLY	
	SIGNATURE: <i>BRIM KELLY</i>	DATE: 5-7-24
	PHONE #: (541) 560-2581	CERT #: 0 5441 / 8301

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

5

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: April 2024

Required Log Inactivation: 0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/ off								off
2/0901	1.71	21	35	13.8	7.54	25	yes	370
3/0830	1.88	21	39	13.9	7.57	25	yes	370
4/066								off
5/1021	1.85	21	38	13.2	7.61	30	yes	370
6/11:47	1.78	21	37	10.8	7.62	30	yes	370
7/ off								off
8/1308	1.74	21	37	12.5	7.67	30	yes	370
9/0918	1.87	21	39	12.7	7.65	30	yes	370
10/ off								off
11/0923	1.95	21	40	13.3	7.71	30	yes	370
12/09:53	1.93	21	40	14.03	7.647	30	yes	370
13/ off								off
14/ off								off
15/0916	2.03	21	42	13.8	7.69	30	yes	370
16/1000	1.87	21	39	12.5	7.67	30	yes	370
17/ off								off
18/0909	1.87	21	39	12.8	7.69	30	yes	370
19/0800	1.87	21	39	13.4	7.65	30	yes	370
20/ off								off
21/1530	1.92	21	40	13.5	7.72	30	yes	370
22/0900	1.82	21	38	12.7	7.64	30	yes	370
23/1249	1.86	21	39	13.8	7.70	30	yes	370
24/1100	1.89	21	39	14.4	7.61	30	yes	370
25/ off								off
26/1153	1.77	21	37	14.3	7.66	30	yes	370
27/0240	1.82	21	38	14.3	7.70	30	yes	370
28/ off								off
29/ off								off
30/1405	1.71	21	35	14.6	7.71	29	yes	370
31/ off								off

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.