

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: May 2024
 WTP: TP - A

System Name: Canyonville, City Of ID#: 41 00169

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.024	.021	.026	.064	.027	.023	.108
2	.023	X	X	X	X	X	.023
3	X	X	X	.025	.022	.025	.037
4	.026	X	X	X	X	X	.026
5	X	X	X	X	X	X	off
6	X	X	X	X	.026	.026	.057
7	.023	.024	.025	.031	X	.022	.141
8	.023	.021	X	X	X	X	.023
9	X	X	X	.024	.023	.021	.049
10	.027	.028	X	X	X	X	.028
11	X	X	X	X	X	X	off
12	X	X	X	.028	.026	.027	.069
13	.029	.030	.035	X	X	X	.035
14	X	X	.030	.022	.022	.024	.091
15	.025	.024	.025	X	.021	.024	.068
16	.023	.024	X	X	X	X	.024
17	X	X	X	.026	.025	.024	.069
18	.029	.027	.023	X	X	X	.039
19	X	X	X	X	X	X	off
20	X	X	X	.025	.022	.022	.047
21	.023	.024	.022	.025	.024	.021	.035
22	.024	.025	.024	.028	X	X	.048
23	X	X	X	X	X	X	off
24	X	X	X	.024	.024	.025	.049
25	.023	.022	.022	.024	.023	.023	.081
26	.022	.023	X	X	X	X	.023
27	X	X	X	.023	.023	.021	.071
28	.023	.021	.021	.030	.024	.022	.042
29	.024	.021	X	X	X	X	.024
30	X	X	X	.024	.024	.025	.097
31	.024	.023	X	.034	.023	.023	.044

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: BRIAN KELLY
 SIGNATURE: *[Signature]* DATE: 6-3-24
 PHONE #: (541) 580-2581 CERT #: *[Cert #]*

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))
 PAGE 1 of 2

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: May 2024

Required Log Inactivation: 0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/ 1100	1.68	21	35	12.2	7.75	30	yes	370
2/ 0200	1.75	21	36	14.4	7.49	25	yes	370
3/ 0954	1.65	21	34	14.7	7.49	24	yes	370
4/ 0100	1.75	21	37	14.8	7.51	25	yes	370
5/								
6/ 1429	1.71	21	35	14.7	7.47	25	yes	370
7/ 0700	1.63	21	34	12.4	7.59	25	yes	370
8/ 0200	1.83	21	38	14.0	7.59	25	yes	370
9/ 0957	1.73	21	36	13.5	7.61	30	yes	370
10/ 0200	1.90	21	40	16.6	7.59	17	yes	370
11/								
12/ 0849	1.77	21	37	16.1	7.59	16	yes	370
13/ 0900	1.92	21	40	17.2	7.60	20	yes	370
14/ 0806	1.88	21	39	16.5	7.59	16	yes	370
15/ 1348	1.82	21	38	16.4	7.59	16	yes	370
16/ 0700	1.82	21	38	17.9	7.58	17	yes	370
17/ 0855	1.77	21	37	17.8	7.59	16	yes	370
18/ 08:05	1.54	21	32	15.5	7.55	16	yes	370
19/								
20/ 1044	1.48	21	31	14.9	7.56	24	yes	370
21/ 12:25	1.55	21	32	13.9	7.59	24	yes	370
22/ 1409	1.52	21	31	15.3	7.60	19	yes	370
23/								
24/ 0936	1.54	21	32	15.4	7.60	19	yes	370
25/ 12:09	1.50	21	32	15.5	7.56	16	yes	370
26/ 0400	1.57	21	33	14.5	7.57	24	yes	370
27/ 1101	1.53	21	32	14.7	7.60	29	yes	370
28/ 1407	1.57	21	33	16.1	7.55	16	yes	370
29/ 0500	1.56	21	32	15.4	7.58	16	yes	370
30/ 1033	1.49	21	31	15.6	7.55	16	yes	370
31/ 1516	1.52	21	31	15.3	7.56	16	yes	370

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.