

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: July 2024

System Name: Canyonville, City Of ID#: 41 00169 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1							
2	X	X	.045	.040	.041	.042	.065
3	.054	.057	.051	.041	.041	.040	.057
4	.038	.042	.044	X	X	X	.057
5	.042	.040	.040	.039	X	X	.045
6	X	X	X	.061	.040	.039	.081
7	.042	.042	.042	.061	.058	.056	.078
8	X	X	X	X	X	X	.061
9	.042	.046	.042	.047	.044	.045	.055
10	.045	X	X	.040	.048	.041	.056
11	.042	.044	X	X	X	X	.050
12	X	X	X	.043	.041	.041	.060
13	.042	.050	.068	.061	.062	X	.081
14	X	X	X	X	X	X	.066
15	.047	.046	.050	.049	.056	.056	.086
16	.055	.058	X	X	.053	.050	.074
17	.051	.048	.052	.056	X	X	.059
18	X	X	X	X	.017	.018	.092
19	.018	.016	.017	.018	.020	X	.024
20	X	X	X	X	.017	.019	.023
21	.018	.020	.022	.022	X	X	.025
22	X	X	X	.020	.020	.020	.033
23	.020	.020	.022	X	.019	.020	.073
24	.016	X	X	X	.020	.018	.027
25	.019	.016	.017	.019	X	X	.029
26	X	X	X	.016	.018	.018	.028
27	.017	.026	X	X	X	X	.032
28	X	X	X	.017	.016	.018	.051
29	.018	.025	.022	.023	.021	X	.030
30	X	X	X	X	.017	X	.035
31	X	X	X	.018	.020	.033	.072

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / No		

Notes:

PRINTED NAME: BRIAN KELLY

SIGNATURE: *[Signature]* DATE: 8-1-24

PHONE #: (541) 580-2581 CERT #: *[Cert #]*

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2

## OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: July 2024

Required Log Inactivation: 0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT			Use tables	Yes / No	[GPM]
1/ off								
2/ 0749	2.49	21	52	19.3	7.77	43	yes	500
3/ 1203	2.62	21	55	18.6	7.77	43	yes	500
4/ 1100	2.30	21	48	18.4	7.75	42	yes	500
5/ 10:30	2.30	21	48	19.2	7.71	42	yes	475
6/ 1025	2.13	21	44	20.1	7.73	31	yes	500
7/ 1120	2.26	21	47	20.6	7.67	31	yes	500
8/ 2855	2.04	21	42	22.2	7.59	25	yes	480
9/ 0850	2.28	21	47	21.3	7.69	31	yes	480
10/ 1121	2.27	21	47	22.6	7.69	31	yes	480
11/ 0700	2.62	21	55	21.5	7.88	32	yes	480
12/ 1006	1.65	21	34	20.8	7.56	29	yes	480
13/ 09:45	2.29	21	48	19.78	7.81	42	yes	480
14/ 2058	1.81	21	38	21.7	7.72	30	yes	480
15/ 1500	1.90	21	40	22.0	7.69	30	yes	480
16/ 1545	1.80	21	37	22.8	7.63	30	yes	470
17/ 1030	1.58	21	33	21.2	7.54	24	yes	470
18/ 1313	1.54	21	32	21.9	7.52	24	yes	470
19/ 1530	1.58	21	33	21.9	7.62	29	yes	470
20/ 1452	1.62	21	34	22.0	7.74	30	yes	470
21/ 0848	1.95	21	41	21.3	7.78	30	yes	470
22/ 1040	1.92	21	40	21.1	7.83	30	yes	470
23/ 0500	1.85	21	38	20.2	7.67	30	yes	470
24/ 1622	1.72	21	36	20.6	7.59	30	yes	470
25/ 0900	2.11	21	44	19.6	7.67	41	yes	470
26/ 0855	1.98	21	41	19.8	7.70	41	yes	470
27/ 0300	2.25	21	47	19.3	7.68	41	yes	470
28/ 1007	1.96	21	41	20.1	7.65	30	yes	470
29/ 1500	1.86	21	39	20.9	7.54	25	yes	470
30/ 1248	1.46	21	30	21.4	7.58	23	yes	470
31/ 0956	2.85	21	59	22.4	7.69	33	yes	470

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.