

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: August 2024

System Name:	Canyonville, City Of		ID#: 41	00169	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.040	—	—	—	—	.020	.040
2	.019	.022	.021	.030	.020	.029	.133
3	—	—	—	—	—	—	.032
4	.024	.025	.026	.029	.030	.030	.040
5	—	—	—	—	—	—	.056
6	.026	.023	.071	.039	.065	.067	.105
7	—	—	—	BW	.025	.023	.075
8	.023	.025	.033	—	—	—	.073
9	—	—	—	.037	.033	.039	.061
10	.067	.034	.033	.030	—	—	.071
11	—	—	—	.062	.060	.026	.074
12	.040	.033	.032	—	—	—	.064
13	—	—	—	.033	.025	.026	.056
14	.037	—	FTW	.031	.030	.032	.152
15	—	—	—	—	—	FTW	.037
16	.026	.026	.026	.027	.026	.025	.223
17	—	—	—	—	—	.076	.086
18	.053	—	—	BW	—	—	.103
19	—	—	—	.043	.036	.037	.110
20	.034	—	—	—	.037	.033	.090
21	.029	.029	.059	—	—	—	.096
22	—	—	—	.030	.030	.032	.064
23	.035	.056	—	—	—	—	.084
24	—	—	FTW	—	.071	.061	.103
25	—	—	BW	.047	.040	.036	.135
26	—	—	—	—	—	—	—
27	—	—	FTW	.034	.033	—	.082
28	.036	—	.081	.039	.036	.037	.149
29	.039	—	—	—	—	—	.096
30	—	—	.045	.041	—	—	.157
31	.037	.037	.036	.036	FTW	.040	.101

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No
All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> Yes / No		
Notes:	PRINTED NAME: BZIM KELLY	
	SIGNATURE: <i>Bzim Kelly</i>	DATE: 9-5-24
	PHONE #: (541) 580-2581	CERT #: P-5861 / 78301

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

5

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: August 2024

Required Log Inactivation: 0.

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T			Use tables	Yes / No	[GPM]
1/1834	1.52	21	31	23.0	7.60	29	yes	470
2/0800	2.48	21	52	22.8	7.86	32	yes	470
3/2127	1.95	21	40	24.4	7.79	30	yes	470
4/1130	2.11	21	44	22.8	7.62	31	yes	470
5/2209	2.01	21	42	23.9	7.61	30	yes	470
6/0937	2.63	21	55	21.49	7.80	32	yes	470
7/1532	2.38	21	49	22.4	7.66	32	yes	470
8/0800	1.83	21	38	21.5	7.64	30	yes	470
9/1045	1.67	21	35	21.3	7.71	30	yes	470
10/0929	1.85	21	38	21.0	7.71	30	yes	470
11/1129	1.58	21	33	21.8	7.68	28	yes	470
12/0800	1.84	21	38	21.0	7.69	30	yes	470
13/1215	1.57	21	32	21.1	7.68	29	yes	470
14/0859	1.84	21	38	20.1	7.76	30	yes	470
15/2048	1.68	21	35	21.2	7.70	30	yes	470
16/1042	1.91	21	40	20.2	7.73	30	yes	470
17/1809	2.14	21	44	21.2	7.72	31	yes	470
18/0200	1.83	21	38	20.1	7.73	30	yes	470
19/0931	1.40	21	29	20.2	7.68	28	yes	470
20/1615	1.78	21	37	20.5	7.61	30	yes	470
21/0800	2.26	21	47	19.0	7.74	42	yes	470
22/1122	2.04	21	42	19.7	7.72	41	yes	470
23/0400	1.90	21	39	20.2	7.82	30	yes	470
24/1255	2.20	21	46	17.8	7.77	41	yes	470
25/0944	2.28	21	47	17.5	7.83	41	yes	470
26/Off								
27/0831	2.34	21	49	18.9	7.77	42	yes	470
28/1001	2.46	21	51	18.7	7.78	43	yes	470
29/0100	2.47	21	51	18.4	7.75	43	yes	470
30/1614	2.39	21	50	18.5	7.73	42	yes	470
31/1703	2.65	21	53	21.0	7.72	32	yes	470

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.