

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: Nov 2024
WTP: TP - A

System Name:	Canyonville, City Of		ID#: 41 00169				
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	—	.070	.079	—	.079
2	—	—	—	—	—	—	—
3	—	—	—	—	.072	.071	.072
4	.073	.075	.072	.071	.077	—	.077
5	—	—	—	—	—	—	—
6	—	—	—	.072	.066	.068	.072
7	.068	.072	.073	.074	—	—	.074
8	—	—	—	—	.232	.065	.232
9	.064	.067	—	—	—	—	.067
10	—	—	—	.072	.071	.069	.072
11	.070	—	—	—	—	—	.070
12	—	—	—	—	—	—	—
13	—	—	—	.079	.111	—	.111
14	—	—	—	.181	.080	.078	.181
15	.092	—	—	.128	—	.103	.128
16	.132	.113	—	—	—	—	.132
17	—	—	—	.135	.084	.120	.135
18	.081	.078	.074	.075	—	—	.081
19	—	—	—	—	—	.126	.126
20	.200	—	—	—	—	.118	.200
21	—	—	—	—	—	—	—
22	—	—	—	—	—	—	—
23	.085	.087	.100	—	.093	.091	.100
24	.086	.086	—	.095	.106	.093	.106
25	.101	—	—	.098	.094	—	.101
26	—	—	—	—	.107	.094	.107
27	.090	—	—	.116	.140	.123	.140
28	—	—	—	—	—	—	—
29	—	—	—	—	—	—	—
30	—	—	—	.229	.144	.169	.229
31	—	—	—	—	—	—	—

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 0.3 NTU?	Yes/No <u>Yes</u>	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 1 NTU?	Yes/No <u>Yes</u>	Yes/No <u>Yes</u>	Yes/No <u>Yes</u>
All turbidity readings < IFE ² triggers	Yes/No <u>Yes</u>		
Notes:		PRINTED NAME: BRIAN KELLY	
		SIGNATURE: <u>[Signature]</u>	DATE: 12-10-24
		PHONE #: (541) 580-2581	CERT #: <u>0-5441</u> <u>7-8301</u>

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: November 2024

Required Log Inactivation: O

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Minimum Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T			Use tables	Yes / No	[GPM]
1/1048	1.33	21	27	12.7	7.44	23	yes	370
2/			Plant off					
3/1151	1.20	21	25	13.6	7.36	23	yes	370
4/1345	1.66	21	35	12.2	7.37	24	yes	370
5/			Plant off					
6/1135	1.64	21	34	12.6	7.34	24	yes	370
7/0845	1.64	21	34	11.0	7.36	24	yes	370
8/1445	1.40	21	29	11.5	7.34	23	yes	370
9/			Plant off					
10/0805	1.55	21	32	11.5	7.34	23	yes	370
11/			Plant off					
12/			Plant off					
13/1259	2.172	21	45	12.4	7.36	25	yes	370
14/1450	2.04	21	42	12.7	7.18	25	yes	370
15/1145	2.04	21	42	12.3	7.07	25	yes	370
16/			Plant off					
17/1251	1.69	21	35	12.7	7.13	24	yes	370
18/0830	2.33	21	49	11.0	7.04	21	yes	370
19/1605	2.53	21	53	11.6	6.90	22	yes	370
20/1600	2.88	21	60	11.9	7.01	22	yes	370
21/			Plant off					
22/			Plant off					
23/0755	2.48	21	52	12.0	7.35	26	yes	370
24/0725	2.41	21	50	12.1	7.23	26	yes	370
25/1512	2.24	21	47	11.8	7.31	26	yes	370
26/1530	1.98	21	41	12.3	7.28	25	yes	370
27/0946	2.08	21	43	12.3	7.27	25	yes	370
28/			plant off					
29/			plant off					
30/0951	1.94	21	41	10.4	7.35	25	yes	370
31/			plant off					

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.