

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Dec 2024System Name: 

ID#: 41

WTP: TP - 

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.132	.112	-	-	-	-	.132
2	-	-	-	BW -	.099	.096	.099
3	.093	-	-	-	-	-	.093
4	-	-	-	.096	BW -	.101	.101
5	-	-	-	-	.099	-	.099
6	-	-	-	-	-	-	-
7	-	-	-	.110	.097	.097	.110
8	.100	.098	-	-	-	-	.100
9	-	-	-	-	.103	.099	.103
10	.095	-	-	.100	.097	-	.100
11	-	-	-	-	-	-	-
12	-	-	-	.124	.108	.104	.124
13	.103	.101	.099	-	-	-	.103
14	-	-	-	.184	-	-	.184
15	-	-	-	.104	.107	-	.107
16	-	-	-	.207	.116	.108	.207
17	.146	-	-	.111	.182	.160	.182
18	-	-	-	-	.115	.105	.115
19	-	-	.101	.096	.102	-	.102
20	-	-	-	-	-	-	-
21	-	-	.136	.109	.125	-	.136
22	-	-	.147	.109	.104	.109	.147
23	.111	-	-	.150	.162	-	.162
24	-	-	.129	-	-	-	.129
25	.133	-	-	-	-	-	.133
26	-	-	-	-	.122	.266	.266
27	.135	.115	.284	.126	-	-	.284
28	.134	.133	-	.137	.157	-	.157
29	-	-	-	-	-	-	-
30	-	-	-	-	.166	-	.166
31	-	.164	-	-	-	-	.164

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?Yes / NoAll 4-hour turbidity readings $\leq$ 1 NTU?Yes / NoAll turbidity readings < IFE² triggersYes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)Yes / NoAll Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?Yes / No

Notes:

PRINTED NAME: BRIAN KELLYSIGNATURE: Brian KellyDATE: 1-7-25PHONE #: (541) 580-2581CERT #: P-8441
7-8301¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: City of Canyonville

ID#: 4100169

Month/Year: Dec. 2024

Disinfection Giardia
Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1				Plant off				
2 1237	1.99	21	42	8.68	7.4	33	Yes	370
3				Plant off				
4 0808	1.8	21	38	8.85	7.4	33	Yes	370
5 1540	2.2	21	46	8.43	7.4	34	yes	370
6				Plant off				
7 0844	2.3	21	48	9.4	7.7	41	Yes	370
8				off				
9	2.0	21	42	10.4	7.7	30	Yes	370
10 0730	2.0	21	42	8.42	7.7	41	Yes	370
11 1055				Plant off				
12	2.0	21	42	8.13	7.7	41	Yes	370
13				Plant off				
14 1117	1.98	21	42	8.53	7.7	41	yes	370 KR
15 1042	2.08	21	44	10.11	7.4	25	yes	370 KR
16 1121	1.5	21	31	10.66	7.29	24	yes	370 LH
17 1301	1.7	21	36	11.3	7.39	25	yes	370 LH
18 1344	1.8	21	38	12.3	7.27	25	yes	370 LH
19 0832	1.8	21	38	12.2	7.04	20	yes	370 LH
20				Plant off				
21 0848	1.5	21	31	11.8	7.1	23	yes	370 LH
22 0927	1.8	21	38	11.9	7.1	25	yes	370 LH
23 1105	1.8	21	38	11.8	7.3	25	yes	370 KR
24 2047	1.5	21	31	12.2	7.2	23	yes	370 LH
25 0753	1.8	21	38	11.9	7.2	25	yes	370 LH
26 1135	1.6	21	33	12.2	7.1	24	yes	370 LH
27 1031	1.9	21	40	12.7	7.2	25	yes	370 LH
28 1121	1.8	21	38	12.7	7.3	25	yes	370 KR
29				Plant off				
30 1218	1.4	21	29	12.8	7.2	23	yes	370 LH
31				Plant off				

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350