

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Douglas  
Month/Year: March 2025

| System Name: | Canyonville, City Of |            | ID#: 41    | 00169      | WTP : TP - A |            |                                               |
|--------------|----------------------|------------|------------|------------|--------------|------------|-----------------------------------------------|
| Day          | 12 AM [NTU]          | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU]   | 8 PM [NTU] | Highest Reading of the Day <sup>1</sup> [NTU] |
| 1            | .025                 | —          | —          | .031       | .025         | .030       | .031                                          |
| 2            | .027                 | —          | —          | —          | —            | —          | .027                                          |
| 3            | —                    | —          | —          | .026       | .029         | .024       | .029                                          |
| 4            | .023                 | .025       | —          | —          | —            | —          | .025                                          |
| 5            | —                    | —          | —          | —          | —            | —          | —                                             |
| 6            | —                    | —          | —          | .033       | .032         | .027       | .033                                          |
| 7            | .030                 | .042       | —          | .034       | .029         | .024       | .042                                          |
| 8            | —                    | —          | —          | —          | —            | —          | —                                             |
| 9            | —                    | —          | —          | .031       | .023         | .023       | .031                                          |
| 10           | —                    | —          | —          | —          | —            | —          | —                                             |
| 11           | —                    | —          | —          | .031       | .026         | .025       | .031                                          |
| 12           | .028                 | —          | —          | —          | .022         | .025       | .025                                          |
| 13           | —                    | —          | —          | —          | —            | —          | —                                             |
| 14           | —                    | —          | —          | .047       | .083         | —          | .083                                          |
| 15           | —                    | —          | .069       | —          | .064         | .044       | .069                                          |
| 16           | —                    | —          | —          | —          | —            | —          | —                                             |
| 17           | —                    | —          | —          | —          | —            | —          | —                                             |
| 18           | —                    | —          | —          | —          | —            | .154       | .160                                          |
| 19           | .107                 | —          | —          | .056       | .050         | —          | .336                                          |
| 20           | .063                 | .048       | —          | .106       | .053         | —          | .172                                          |
| 21           | .058                 | .099       | .047       | .147       | .034         | .058       | .299                                          |
| 22           | —                    | —          | —          | —          | —            | —          | —                                             |
| 23           | —                    | —          | .043       | .041       | .054         | .056       | .043                                          |
| 24           | .039                 | .034       | .033       | .068       | .038         | —          | .068                                          |
| 25           | —                    | —          | —          | .025       | .025         | .024       | .025                                          |
| 26           | —                    | —          | —          | —          | —            | —          | —                                             |
| 27           | —                    | —          | —          | .083       | .053         | .044       | .083                                          |
| 28           | .038                 | .048       | —          | —          | —            | —          | .048                                          |
| 29           | —                    | —          | —          | —          | —            | .106       | .106                                          |
| 30           | .046                 | .045       | .088       | —          | .035         | .030       | .088                                          |
| 31           | .041                 | —          | —          | —          | —            | —          | .041                                          |

| Conventional or Direct Filtration                  |                 | Monthly Summary (Answer Yes or No) |                                                              |
|----------------------------------------------------|-----------------|------------------------------------|--------------------------------------------------------------|
| 95% of daily turbidity readings $\leq$ 0.3 NTU?    | <u>Yes</u> / No | CT's met everyday? (see back)      | All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l? |
| All daily turbidity readings $\leq$ 1 NTU?         | <u>Yes</u> / No | <u>Yes</u> / No                    | <u>Yes</u> / No                                              |
| All turbidity readings < IFE <sup>2</sup> triggers | <u>Yes</u> / No |                                    |                                                              |
| Notes:                                             |                 | PRINTED NAME: BRIAN KELLY          |                                                              |
|                                                    |                 | SIGNATURE: <i>Brian Kelly</i>      | DATE: 4-7-25                                                 |
|                                                    |                 | PHONE #: (541) 580-2581            | CERT #: P-8491<br>1-8301                                     |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

# OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year:

March 2025

Required Log  
Inactivation: O

| Date / Time | Minimum Cl <sub>2</sub><br>Residual at<br>1 <sup>st</sup> User (C) <sup>3</sup> | Contact<br>Time<br>(T) | Actual<br>CT | Temp      | pH   | Required CT   | CT Met? <sup>3</sup> | Peak Hourly<br>Demand<br>Flow |
|-------------|---------------------------------------------------------------------------------|------------------------|--------------|-----------|------|---------------|----------------------|-------------------------------|
|             | [ppm or mg/L]                                                                   | [minutes]              | C X T        |           |      | Use<br>tables | Yes / No             | [GPM]                         |
| 1/ 0915     | 1.86                                                                            | 21                     | 39           | 12.2      | 7.37 | 25            | Yes                  | 370                           |
| 2/ 0021     | 1.97                                                                            | 21                     | 41           | 12.6      | 7.39 | 25            | Yes                  | 370                           |
| 3/ 1135     | 1.88                                                                            | 21                     | 39           | 12.4      | 7.39 | 25            | Yes                  | 370                           |
| 4/ 0021     | 1.95                                                                            | 21                     | 40           | 12.0      | 7.40 | 25            | Yes                  | 370                           |
| 5/          |                                                                                 | Plant off              |              | off       |      |               |                      |                               |
| 6/ 0941     | 1.82                                                                            | 21                     | 38           | 11.62     | 7.42 | 25            | Yes                  | 370                           |
| 7/ 0941     | 1.84                                                                            | 21                     | 38           | 10.89     | 7.45 | 25            | Yes                  | 370                           |
| 8/          |                                                                                 | Plant off              |              | off       |      |               |                      |                               |
| 9/ 0949     | 2.00                                                                            | 21                     | 42           | 11.78     | 7.43 | 25            | Yes                  | 370 800                       |
| 10/         |                                                                                 | Plant off              |              | off       |      |               |                      |                               |
| 11/ 1007    | 2.04                                                                            | 21                     | 42           | 11.72     | 7.43 | 25            | Yes                  | 370                           |
| 12/ 1515    | 1.97                                                                            | 21                     | 41           | 11.89     | 7.45 | 25            | Yes                  | 370                           |
| 13/ 11      |                                                                                 | Plant off              |              | off Today |      |               |                      |                               |
| 14/ 1015    | 2.19                                                                            | 21                     | 46           | 11.0      | 7.45 | 26            | Yes                  | 370                           |
| 15/ 0804    | 2.06                                                                            | 21                     | 43           | 10.86     | 7.48 | 25            | Yes                  | 370                           |
| 16/         |                                                                                 | Plant off              |              | off       |      |               |                      |                               |
| 17/         |                                                                                 | Plant off              |              | off       |      |               |                      |                               |
| 18/ 1855    | 2.47                                                                            | 21                     | 52           | 11.68     | 7.21 | 26            | Yes                  | 300                           |
| 19/ 1300    | 1.76                                                                            | 21                     | 37           | 10.58     | 7.50 | 25            | Yes                  | 370                           |
| 20/ 1345    | 2.25                                                                            | 21                     | 47           | 10.65     | 7.61 | 31            | Yes                  | 370                           |
| 21/ 0835    | 2.37                                                                            | 21                     | 50           | 10.71     | 7.68 | 31            | Yes                  | 370                           |
| 22/         |                                                                                 | Plant off              |              | off       |      |               |                      |                               |
| 23/ 0819    | 2.39                                                                            | 21                     | 50           | 12.05     | 7.68 | 31            | Yes                  | 370                           |
| 24/ 0830    | 2.20                                                                            | 21                     | 46           | 12.14     | 7.67 | 31            | Yes                  | 370                           |
| 25/ 1000    | 2.14                                                                            | 21                     | 45           | 14.57     | 7.62 | 30            | Yes                  | 370                           |
| 26/         |                                                                                 | Plant off              |              | off       |      |               |                      |                               |
| 27/ 13:30   | 2.18                                                                            | 21                     | 46           | 13.31     | 7.61 | 31            | Yes                  | 370                           |
| 28/ 12:45   | 2.20                                                                            | 21                     | 46           | 13.39     | 7.64 | 31            | Yes                  | 370                           |
| 29/ 1813    | 2.27                                                                            | 21                     | 47           | 13.01     | 7.40 | 26            | Yes                  | 370                           |
| 30/ 1351    | 2.10                                                                            | 21                     | 44           | 11.14     | 7.45 | 26            | Yes                  | 370                           |
| 31/ 1500    | 2.06                                                                            | 21                     | 43           | 12.39     | 7.31 | 25            | Yes                  | 370                           |

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.