

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: APRIL 2025

System Name: Canyonville, City Of ID#: 41 00169 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	—	—	—	—	—
2	—	—	—	—	—	—	—
3	—	—	—	—	.069	.082	.082
4	.0242	—	.0231	.0226	.037	.032	.242
5	.026	.026	.024	.022	.024	.028	.028
6	.060	—	—	—	—	—	.060
7	—	—	—	.080	.044	.036	.080
8	.043	—	—	—	—	—	.043
9	—	—	—	.053	.032	.031	.053
10	.029	.030	—	—	—	—	.030
11	—	—	—	.063	.035	—	.063
12	—	—	—	—	—	—	—
13	—	—	—	—	.027	.023	.027
14	—	—	—	—	.029	.027	.029
15	.028	.043	.037	.051	.039	.031	.051
16	—	—	—	—	—	—	—
17	—	—	—	.028	.027	.024	.028
18	.029	.025	—	—	—	—	.029
19	—	—	—	—	—	—	—
20	—	—	—	.039	.031	.026	.039
21	.025	.028	.024	.026	.025	.028	.028
22	—	—	—	—	—	—	—
23	—	—	—	—	—	—	—
24	—	—	.035	.038	.034	.030	.038
25	.029	.029	.028	.026	.025	.028	.029
26	.026	—	—	—	—	—	.026
27	—	—	—	—	—	—	—
28	—	—	.029	.040	.033	.028	.040
29	.031	.032	.028	.024	.029	.034	.032
30	—	—	—	—	—	—	—
31	—	—	—	—	—	—	—

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings $\leq$ 0.3 NTU? Yes / NoCT's met everyday?
(see back)All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?All daily turbidity readings $\leq$ 1 NTU? Yes / No

Yes / No

Yes / No

All turbidity readings < IFE² triggers Yes / No

Notes:

PRINTED NAME: RAYMOND C PAGE

SIGNATURE: Raymond C Page

DATE: 5-5-25

PHONE #: 541 261 4745

CERT #: 6358

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program — Surface Water Quality Data Form

CITY OF CANYONVILLE ID OR4100169 WTP-: WTP-A Month/Year: **APRIL 2025**

Required Log
Inactivation: O

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C XT			Use tables	Yes / No	[GPM]
1/		Plant off						
2/		Plant off						
3/ 1610	2.48	21	52	12.27	7.37	26	Yes	370
4/ 1010	2.22	21	47	11.26	7.47	26	Yes	370
5/ 0950	2.30	21	48	11.18	7.50	26	Yes	370
6/ 0148	2.49	21	52	14.36	7.46	26	Yes	370
7/ 1135	2.24	21	47	13.30	7.49	26	Yes	370
8/ 1230	2.64	21	55	13.84	7.51	27	Yes	370
9/ 1430	1.94	21	41	12.55	7.43	25	Yes	370
10/ 0430	2.92	21	61	14.18	7.51	28	Yes	370
11/ 1125	2.04	21	43	13.98	7.44	25	Yes	370
12/		Plant off						
13/ 13:13	1.93	21	40	14.1	7.45	25	Yes	370
14/ 11:15	2.05	21	43	13.43	7.53	25	Yes	370
15/ 0830	2.25	21	47	13.86	7.46	26	Yes	370
16/ 0230	2.49	21	52	15.99	7.48	26	Yes	370
17/ 1310	1.94	21	41	13.81	7.40	25	Yes	370
18/ 0500	2.21	21	46	14.96	7.47	26	Yes	370
19/		Plant off						
20/ 0904	1.77	21	37	14.6	7.42	25	Yes	370
21/ 1245	2.00	21	42	13.6	7.56	25	Yes	370
22/		Plant off						
23/		Plant off						
24/ 0819	1.69	21	35	14.66	7.61	30	Yes	370
25/ 0904	1.85	21	38	14.91	7.54	25	Yes	370
26/ 0021	1.44	21	30	14.81	7.64	29	Yes	370
27/		Plant off						
28/ 0819	1.53	21	32	14.45	7.56	24	Yes	370
29/ 0915	1.84	21	38	14.60	7.48	25	Yes	370
30/		Plant off						
31/								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.