

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: May-25

System Name:	City of Canyonville			ID 41-00169			WTP : TP -
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	—	—	—	—	—
2	—	—	—	.041	.037	.029	.041
3	.033	.034	.032	.031	.033	.031	.034
4	.028	.024	—	—	—	—	.028
5	—	—	—	—	—	—	—
6	—	—	—	.045	.037	.032	.045
7	.035	.031	.032	.031	.029	.030	.035
8	.029	.029	.028	—	—	—	.029
9	—	—	—	—	—	—	—
10	—	—	.063	.041	.037	.041	.063
11	.037	.033	.034	.030	.030	.033	.037
12	.029	.027	.029	—	—	—	.029
13	—	—	—	—	—	—	—
14	—	—	—	.031	.030	.040	.040
15	.034	.030	.027	.030	.032	—	.034
16	—	—	—	—	—	—	—
17	—	—	—	—	—	—	—
18	—	—	.064	.045	.041	.041	.064
19	.039	.033	.034	.034	.033	.034	.039
20	.034	.035	—	—	—	—	.035
21	—	—	—	—	—	—	—
22	—	—	.077	.054	.047	.040	.077
23	.042	.037	.034	.033	.035	.034	.042
24	.035	.036	—	—	—	—	.036
25	—	—	—	—	—	—	—
26	—	—	.064	.047	.042	.037	.064
27	.042	.041	.035	.036	.044	.034	.044
28	.035	.037	.036	.032	—	—	.037
29	—	—	—	.061	.046	.041	.061
30	.037	.036	.035	.033	.032	.033	.037
31	.032	—	—	—	—	—	.032

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity readings < IFE ² triggers	☒ Yes / ☐ No		
Notes:		PRINTED NAME: <u>TRIMOND C. PATE</u> SIGNATURE: <u>[Signature]</u> DATE: <u>6-5-25</u> PHONE #: <u>(541) 661-1745</u> CERT #: <u>6358</u>	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:

City of Canyonville

ID#: 41

00169

Month/Year:

May-25

Disinfection Giardia
Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1			Plant off					
2 0838	1.37	21	28	16.04	7.53	16	Yes	370
3 0657	1.543	21	32	16.84	7.46	16	Yes	370
4 0632	1.650	21	34	14.54	7.54	25	Yes	370
5			Plant off					
6 0855	1.47	21	30	15.56	7.55	16	Yes	370
7 0818	1.78	21	37	16.27	7.65	20	Yes	370
8 0829	1.68	21	35	16.4	7.63	20	Yes	370
9			Plant off					
10 0735	1.42	21	25	16.6	7.71	19	Yes	370
11 0632	1.71	21	35	17.5	7.70	20	Yes	370
12 0830	1.91	21	40	18.9	7.67	20	Yes	370
13			Plant off					
14 0924	1.33	21	27	15.5	7.80	19	Yes	370
15 0830	1.65	21	34	14.95	7.76	30	Yes	370
16			Plant off					
17			Plant off					
18 0632	1.41	21	29	15.7	7.94	19	Yes	370
19 1045	1.80	21	38	15.8	7.95	20	Yes	370
20 0021	2.01	21	42	16.79	7.8	20	Yes	370
21			Plant off					
22 0641	1.75	21	36	16.91	7.8	20	Yes	370
23 0832	1.59	21	33	16.3	7.72	19	Yes	370
24 0021	1.84	21	38	16.9	7.8	20	Yes	370
25			Plant off					
26 641	1.2	21	25	17.2	7.76	19	Yes	370
27 0021	2.01	21	42	18.16	7.72	20	Yes	370
28 0021	2.01	21	42	18.67	7.71	20	Yes	370
29 1415	1.56	21	33	18.4	7.56	19	Yes	370
30 1030	2.00	21	42	18.9	7.68	20	Yes	370
31 0021	1.85	21	38	20.08	7.55	12	Yes	370

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350