

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: June 2025

System Name:	City of Canyonville			ID 41-00169	WTP: TP -		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	0.154	0.044	0.039	0.037	.154
2	.035	.034	.031	.029	.031	.030	.035
3	.030	.032	—	—	—	—	.032
4	—	—	—	.046	.036	.032	.046
5	.032	.031	.033	.033	.031	.032	.033
6	.032	.033	.033	—	—	—	.033
7	—	—	—	.058	.038	.034	.058
8	.033	.032	.034	.032	.033	.031	.034
9	.034	.034	.038	.038	.041	.035	.041
10	—	—	—	—	—	—	—
11	.040	—	.068	.036	.033	.033	.068
12	.031	.031	.031	.030	.029	.029	.031
13	.028	.030	.032	—	—	—	.032
14	—	—	—	—	.032	.032	.032
15	.032	.033	.032	.031	.030	.030	.033
16	.031	.030	.028	.030	.029	.028	.031
17	.031	—	—	—	—	—	.031
18	—	—	—	.039	.034	.032	.039
19	.031	.033	.032	.031	.030	.032	.033
20	.029	.033	.032	.030	.030	—	.033
21	—	—	—	.047	.039	.051	.051
22	.074	—	—	—	—	—	.074
23	—	—	—	—	.107	.036	.107
24	.032	.032	.033	.034	.032	.033	.034
25	.032	.033	.032	.034	.032	.034	.034
26	.032	—	—	—	—	—	.032
27	—	—	—	.041	.034	.034	.041
28	.033	.034	.034	.034	.033	.034	.034
29	.033	.033	.034	.034	—	—	.034
30	—	—	.041	.034	.034	.036	.041
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: <u>RAYMOND C PAGE</u> SIGNATURE: <u>[Signature]</u> DATE: <u>7-7-25</u> PHONE #: <u>(541) 661-1745</u> CERT #: <u>6358</u>	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:

City of Canyonville

ID#: 41

00169

Month/Year: June 2025

Disinfection Giardia
Log Inactive:

0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
10915	1.34	21	28	19.7	7.80	19	Yes	370
20021	1.49	21	31	18.7	7.57	16	Yes	370
30021	2.12	21	44	18.1	7.71	20	Yes	370
40955	1.22	21	25	18.6	7.70	19	Yes	370
50021	1.80	21	37	19.24	7.58	16	Yes	370
60021	1.87	21	39	19.36	7.70	20	Yes	370
71157	1.40	21	29	19.55	7.54	16	Yes	370
80803	1.48	21	31	21.96	7.4	12	Yes	370
90910	1.61	21	34	22.80	7.32	12	Yes	370
10				PLANT OFF				
110826	1.27	21	26	22.8	7.55	12	Yes	370
120021	1.97	21	41	20.9	7.47	13	Yes	370
130838	1.46	21	30	19.91	7.66	19	Yes	370
141346	0.963	21	20	19.87	7.53	15	Yes	370
150021	1.77	21	37	19.86	7.49	16	Yes	370
161048	1.26	21	26	18.71	7.45	19	Yes	370
170135	1.49	21	31	18.90	7.35	15	Yes	370
181535	1.47	21	31	19.53	7.39	16	Yes	370
190810	1.87	21	39	19.34	7.61	20	Yes	370
201338	1.51	21	32	18.42	7.68	19	Yes	370
211026	1.41	21	30	18.11	7.80	19	Yes	370
220021	1.54	21	32	18.08	7.80	19	Yes	370
231626	1.43	21	30	17.76	7.28	16	Yes	370
241153	1.32	21	27	19.06	7.52	16	Yes	370
250839	1.53	21	32	19.91	7.58	16	Yes	370
260021	2.10	21	44	20.35	7.53	13	Yes	370
271120	2.21	21	46	20.37	7.92	16	Yes	370
280949	1.50	21	31	20.71	7.55	12	Yes	370
290931	1.46	21	30	20.88	7.56	12	Yes	370
301602	1.40	21	29	21.53	7.38	12	Yes	370
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350