

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: July 2025

System Name:	City of Canyonville			ID 41-00169			WTP: TP -
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.035	.035	.036	.038	—	—	.038
2	.036	.036	.036	.036	.039	.038	.039
3	.041	—	—	—	—	—	.041
4	—	—	.047	.042	.040	.038	.047
5	.037	.036	.037	.039	.037	—	.039
6	—	—	.040	.037	.036	—	.040
7	—	—	—	.040	—	.036	.040
8	.034	.032	.033	.036	.036	.033	.036
9	.036	—	—	—	—	—	.036
10	—	—	—	.028	—	.036	.036
11	.028	.026	.030	.033	.037	.028	.037
12	.024	.026	.025	.024	.026	—	.026
13	—	—	—	—	—	—	—
14	—	—	—	.031	.029	.032	.032
15	.036	.038	.038	.054	.033	.034	.054
16	.031	.033	.031	.031	.032	.031	.033
17	.033	—	—	—	.038	.035	.038
18	.034	.039	—	.034	.039	.037	.039
19	—	—	—	—	—	—	—
20	—	—	.050	.042	.040	.036	.050
21	.039	.039	.036	.037	—	.039	.039
22	.038	—	—	—	—	—	.038
23	—	—	.210	.043	.049	.044	.210
24	.044	.042	.042	.045	.041	.042	.045
25	.042	.045	.043	—	—	—	.045
26	—	—	—	—	.054	.049	.054
27	.046	.048	.047	.048	.048	.045	.048
28	.046	—	—	—	.098	.020	.098
29	.022	.022	.023	—	—	—	.023
30	—	—	—	—	.026	.022	.026
31	.023	.020	.023	.023	.022	.021	.023

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: RAYMOND C PAGE

SIGNATURE: Raymond C Page

DATE: 8-5-25

PHONE #: (541) 661-9745

CERT #: 6358

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:

City of Canyonville

ID#: 41

00169

Month/Year:

July 2025

Disinfection Giardia

Log Inactive:

0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
10021	1.45	21	30	21.55	7.37	12	Yes	370
20821	1.43	21	30	22.85	7.43	12	Yes	370
30021	1.80	21	37	22.70	7.41	12	Yes	370
0635 40635	1.07	21	22	22.33	7.64	14	Yes	370
50021	1.28	21	26	20.67	7.58	12	Yes	370
60706	1.15	21	24	20.31	7.69	14	Yes	370
70846	1.21	21	25	20.92	7.63	14	Yes	370
80823	1.45	21	30	21.87	7.34	24	Yes	500
90021	2.33	21	48	22.97	7.31	26	Yes	500
100849	1.36	21	28	22.88	7.54	23	Yes	500
11023	1.21	21	25	22.14	7.34	23	Yes	500
120735	1.51	21	32	22.15	7.35	23	Yes	500
13			Plant off					
140917	1.37	21	28	23.48	7.36	23	Yes	500
150801	1.60	21	33	23.65	7.78	29	Yes	500
160828	1.41	21	29	23.24	7.96	28	Yes	500
171613	1.40	21	29	24.10	7.19	23	Yes	500
181600	1.34	21	28	23.55	8.07	28	Yes	480
19			Plant off					
200713	1.49	21	31	23.51	7.78	29	Yes	500
211030	1.74	21	36	21.47	7.78	28	Yes	500
220021	1.78	21	37	21.48	7.84	30	Yes	500
230824	1.51	21	31	21.64	7.81	29	Yes	500
240855	1.53	21	32	21.82	7.78	29	Yes	500
250825	1.55	21	32	21.96	7.79	29	Yes	500
261600	1.577	21	33	22.33	7.79	29	Yes	500
270021	1.58	21	33	21.59	7.83	29	Yes	500
281627	1.47	21	30	21.74	7.79	29	Yes	500
290817	1.64	21	34	21.17	7.80	30	Yes	500
301255	1.23	21	25	21.57	7.53	23	Yes	500
310840	1.45	21	30	21.89	7.52	24	Yes	500

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350