

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: August 2025

System Name:

City of Canyonville

ID 41-00169

WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.022	0FF	0FF	0FF	0FF	0FF	0.022
2	0FF	0FF	0FF	0.029	0.026	0.024	0.029
3	0.023	0.024	0.024	0.024	0.023	0.022	0.024
4	0.025	—	—	—	—	—	0.025
5	—	—	—	0.029	0.027	0.027	0.029
6	0.025	0.025	0.025	0.025	0.027	0.026	0.027
7	—	—	—	—	0.040	0.034	0.040
8	0.033	0.031	0.034	0.032	—	—	0.034
9	—	—	—	—	—	0.034	0.034
10	—	—	0.033	0.035	0.034	0.032	0.035
11	0.035	0.036	0.041	0.042	0.037	0.037	0.042
12	0.036	0.037	0.036	0.038	0.038	—	0.038
13	—	—	—	—	—	—	—
14	—	—	0.044	0.043	0.061	0.044	0.061
15	0.043	0.043	0.044	0.043	0.045	0.042	0.045
16	0.044	—	—	—	—	—	0.044
17	—	—	—	—	0.050	0.051	0.051
18	0.047	0.049	0.047	0.048	0.047	0.045	0.049
19	0.047	—	—	—	—	—	0.047
20	—	—	—	0.053	0.049	0.048	0.053
21	0.048	0.050	0.049	0.049	0.049	0.049	0.050
22	0.048	—	—	—	—	—	0.048
23	—	—	0.030	0.025	0.024	0.023	0.030
24	0.025	0.025	0.022	0.024	0.025	0.025	0.025
25	0.026	—	—	—	—	—	0.026
26	—	—	—	0.029	0.029	0.029	0.029
27	0.028	0.028	0.029	0.027	0.027	0.028	0.029
28	0.029	0.030	—	—	—	—	0.030
29	—	—	0.036	0.031	0.030	0.030	0.036
30	0.027	0.027	0.026	0.029	0.030	0.029	0.030
31	—	—	—	—	—	—	—

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Raymond C. Page

SIGNATURE: Raymond C. Page

DATE: 9-8-25

PHONE #: (541) 661-4745

CERT #: 6358

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:

City of Canyonville

ID#: 41

00169

Month/Year:

August 2025

Disinfection Giardia
Log Inactive:

0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1 0021	1.50	21	31	22.66	7.58	24	Yes	500
2 1131	1.43	21	30	22.92	7.51	23	yes	500
3 0959	1.45	21	30	21.33	7.53	23	yes	500
4 0021	1.46	21	30	21.29	7.57	24	Yes	500
5 0907	1.16	21	24	21.46	7.55	23	yes	500
6 0827	1.49	21	31	20.26	7.54	24	yes	500
7 1547	1.42	21	29	21.34	7.59	23	yes	500
8 0930	1.48	21	31	20.68	7.77	28	yes	500
9 1918	1.44	21	30	21.68	7.58	24	yes	500
10 0637	1.18	21	24	21.30	7.57	12	yes	370
11 1021	1.36	21	28	21.73	7.53	23	yes	500
12 0848	1.43	21	30	22.3	7.53	24	yes	500
13			Plant off					
14 0741	1.37	21	28	23.6	7.55	23	yes	500
15 0739	1.45	21	30	21.7	7.51	24	yes	500
16 0021	1.60	21	33	22.03	7.58	24	yes	500
17 1618	1.24	21	26	22.4	7.54	23	yes	500
18 0021	1.46	21	30	21.88	7.58	24	yes	500
19 0021	1.49	21	31	21.26	7.56	24	yes	500
20 1043	1.31	21	27	21.5	7.54	23	yes	500
21 1326	1.44	21	30	21.08	7.59	24	yes	500
22 0021	1.47	21	30	21.37	7.56	24	yes	500
23 0631	1.42	21	29	21.7	7.54	23	yes	500
24 0900	1.48	21	31	22.3	7.52	23	yes	500
25 0021	1.48	21	31	23.38	7.51	23	yes	500
26 0843	1.28	21	26	23.6	7.49	23	yes	500
27 0909	1.50	21	31	22.9	7.51	24	yes	500
28 0021	1.54	21	32	23.5	7.54	24	yes	500
29 1301	1.46	21	31	22.1	7.55	24	yes	500
30 0809	1.42	21	29	21.3	7.50	24	yes	500
31			Plant off					

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2