

OHA - Drinking Water Services - Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Douglas

Month/Year: September 202

System Name:

City of Canyonville

ID 41-00169

WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	—	—	.043	.030	.031	.027	.043
2	.029	.028	.029	.030	.032	.031	.032
3	.030	—	—	—	—	—	.030
4	—	—	.038	.035	.034	.031	.038
5	.032	.033	.032	.032	.033	.034	.034
6	.033	—	—	—	—	—	.033
7	—	—	—	.039	.034	.034	.039
8	.034	.033	.034	.035	.035	—	.035
9	—	—	.043	—	—	—	.043
10	—	—	.077	.072	.068	.047	.077
11	.037	.036	.037	.037	.035	.033	.037
12	—	—	—	—	—	—	—
13	—	—	.094	.039	.036	.034	.094
14	.032	—	.030	.031	.032	.032	.032
15	—	—	—	—	—	—	—
16	—	—	.045	.031	.028	.028	.045
17	.028	.030	.031	.030	.029	—	.031
18	—	—	—	—	—	—	—
19	—	—	—	.058	.058	.060	.060
20	.060	.061	.062	.063	—	—	.063
21	—	—	—	—	—	—	—
22	—	—	—	—	.030	.029	.030
23	.029	.028	.029	.028	.029	.036	.030
24	—	—	—	—	—	—	—
25	—	—	—	—	.032	.031	.032
26	.032	.031	.034	.035	.040	—	.040
27	—	—	—	—	—	—	—
28	—	—	—	—	—	.035	.035
29	.033	.035	.034	.033	.052	.050	.052
30	—	—	—	—	—	—	—
31	—	—	—	—	—	—	—

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings $<$ IFE² triggers

Yes / No

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: RAYMOND C PAGE

SIGNATURE: Raymond C Page

DATE: 10-6-25

PHONE #: (541) 661-1745

CERT #: 6358

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Canyonville	ID#: 41	00169	Month/Year: <u>September 2025</u>	Disinfection <i>Giardia</i> Log Inactive:	0
--------------	---------------------	---------	-------	-----------------------------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
10749	1.22	21	25	22.2	7.56	23	Yes	500
20830	1.45	21	30	20.91	7.49	24	Yes	500
30021	1.45	21	30	21.94	7.55	24	Yes	500
40709	1.14	21	24	22.10	7.51	22	Yes	500
50445	1.50	21	31.5	22.52	7.53	24	Yes	500
60021	1.58	21	33	22.85	7.57	24	Yes	500
70848	1.2	21	25	22.6	7.53	23	Yes	500
80920	1.44	21	30	21.3	7.52	24	Yes	500
90901	1.39	21	29	21.8	7.62	28	Yes	500
100829	1.44	21	30	21.7	7.47	24	Yes	500
110813	1.58	21	33	21.01	7.53	24	Yes	500
12			Plant off					
13830	1.2	21	25	21.53	7.56	23	Yes	500
140834	1.71	21	36	20.20	7.53	24	Yes	500
15			Plant off					
160652	1.3	21	27	20.7	7.58	23	Yes	500
170807	2.03	21	42	19.17	7.45	33	Yes	500
18			Plant off					
190849	1.62	21	34	20.26	7.51	24	Yes	500
200501	1.94	21	40	19.73	7.48	33	Yes	500
21			Plant off					
221414	1.66	21	34	20.44	7.52	24	Yes	500
230842	1.77	21	37	17.65	7.47	33	Yes	500
24			Plant off					
251527	1.69	21	35	19.22	7.52	33	Yes	500
260814	1.62	21	34	17.71	7.43	32	Yes	500
27			Plant off					
281754	1.61	21	33	18.83	7.49	32	Yes	500
290836	1.83	21	38	17.27	7.45	33	Yes	500
30			Plant off					
31								

³ If Cl₂ at entry point <0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 15th of following month by email, fax, or mail to:

Bartel Field