

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: OCTOBER 2025

System Name:

City of Canyonville

ID 41-00169

WTP: TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-	-	-	-	.038	-	.038
2	-	-	.047	.035	.036	.034	.047
3	.036	.033	.037	.039	.038	.044	.044
4	.032	-	-	-	-	-	.032
5	-	-	-	-	-	-	-
6	-	-	.049	.039	.038	.038	.049
7	.036	.036	.039	.038	.040	.037	.040
8	.036	.038	-	-	-	-	.038
9	-	-	-	-	-	-	-
10	-	-	.041	.040	.040	.043	.043
11	.046	.043	.043	.048	.050	.048	.050
12	-	-	-	-	-	-	-
13	-	-	-	-	-	-	-
14	-	-	.054	.047	.046	.045	.054
15	.044	.045	.046	.046	.058	.050	.058
16	-	-	-	-	-	-	-
17	-	-	-	-	-	-	-
18	-	-	.022	.021	.021	.019	.022
19	.020	.018	.019	-	-	.055	.055
20	.055	-	.054	-	-	-	.055
21	-	-	-	-	-	-	-
22	-	-	.033	.029	.025	.028	.033
23	.023	.022	.024	.029	.027	-	.029
24	-	-	-	-	.079	.047	.079
25	-	-	-	-	-	-	-
26	-	-	-	-	-	-	-
27	-	-	-	-	.058	.072	.072
28	.055	.052	.056	.051	.043	-	.056
29	-	-	-	.140	-	.072	.140
30	.089	.073	.071	.076	.066	.057	.089
31	.046	-	-	-	-	-	.046

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

☒ Yes ☐ No

All 4-hour turbidity readings $\leq$ 1 NTU?

☒ Yes ☐ No

All turbidity readings $<$ IFE² triggers

☒ Yes ☐ No

CT's met everyday?
(see back)

☒ Yes ☐ No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

☒ Yes ☐ No

Notes:

PRINTED NAME: RAYMOND PAGE

SIGNATURE: [Signature]

DATE: 11-3-25

PHONE #: (541) 661-1745

CERT #: 6358

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-081-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:

City of Canyonville

ID#: 41

00169

Month/Year: October 2025

Disinfection Giardia
Log Inactive:

0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		formula	Yes / No	[GPM]
1 1552	1.40	21	29	15.94	7.47	16	Yes	370
2 0830	1.08	21	22	15.23	7.44	15	Yes	370
3 0812	1.53	21	32	14.41	7.49	24	Yes	370
4 0021	1.42	21	29	14.49	7.54	23	Yes	370
5			Plant	off				
6 0836	1.13	21	23	15.12	7.50	15	Yes	370
7 0802	1.33	21	27	13.39	7.46	23	Yes	370
8 0021	1.38	21	28	13.55	7.52	23	Yes	370
9			Plant	off				
10 0710	1.1	21	23	14.13	7.49	23	Yes	370
11 0611	1.29	21	27	12.38	7.47	23	Yes	370
12			Plant	off				
13			Plant	off				
14 0705	1.16	21	24	12.95	7.5	23	Yes	370
15 0801	1.28	21	26	11.4	7.47	23	Yes	370
16			Plant	off				
17			Plant	off				
18 0624	1.23	21	25	12.4	7.48	23	Yes	370
19 1724	1.39	21	29	12.26	7.5	23	Yes	370
20 0815	1.46	21	30	12.49	7.49	24	Yes	370
21				off				
22 0617	1.41	21	29	12.82	7.49	24	Yes	370
23 0728	1.57	21	32	10.85	7.47	24	Yes	370
24 1320	1.33	21	27	11.56	7.53	23	Yes	370
25			Plant	off				
26			Plant	off				
27 1608	1.39	21	29	11.5	7.5	23	Yes	370
28 0814	1.94	21	40	9.74	7.44	33	Yes	370
29 0840	1.48	21	31	10.3	7.46	24	Yes	370
30 0803	1.8	21	37	11.9	7.41	25	Yes	370
31 0021	1.25	21	26	12.17	7.41	23	Yes	370

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov, 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350